



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

D'ARCY DIXON PIGNANELLI
Executive Director

Division of Facilities Construction and Management

F. KEITH STEPAN
Director

ADDENDUM #1

Date: 11 July 2006

To: Contractors

From: Jim Russell, Project Manager, DFCM

Reference: Draper Prison Security Fence Lighting Upgrade
DFCM Project No. 05082100

Subject: **Addendum No. 1**

Pages	Addendum	1 page
	Total	1 page

Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

- 1.1.1 All type F-D pole bases are to removed to three feet below grade
- 1.1.2 All type F-D fixtures are to remain property of the Owner. All type F-D poles are to be removed from the site and become property of the Contractor.
- 1.1.3 Type F-1 fixtures are to be fed from an existing breaker in Panel "C" of the Olympus facility
- 1.1.4 The Contractor is to verify the scale for the plans prior to submitting his bid.

End of Addendum