



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

F. KEITH STEPAN
Director

ADDENDUM #1

Date: March 27, 2007

To: Contractors

From: Craig Wessman, Project Manager, DFCM

Reference: Salt Lake Community College
Jordan and Redwood Rd. Campuses - Boiler Controls Replacement
DFCM Project No. 06164660

Subject: **Addendum No. 1**

Pages	Addendum	1	page
	<u>Engineer's Addendum No. 1</u>	<u>1</u>	<u>page</u>
	Total	2	pages

Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

1.1 SCHEDULE CHANGES – There are no project schedule changes per this Addendum.

1.2 GENERAL: Van Boerum & Frank Associates Addendum No. 1.

End of Addendum #1

March 26, 2007

Boiler Controls Replacement
Salt Lake Community College
Jordan and Redwood Campus

J. Howard Van Boerum, P.E.
John D. Frank, P.E.
Kim P. Harris, P.E.
David P. Baranowski, P.E.
Richard G. Reeder, P.E.
Joseph V. Simmons, P.E.
Byron R. Torgersen, P.E.
Jeffrey S. Watkins, P.E.
Donald K. Bradshaw, P.E.
Benjamin L. Davis, P.E.
Ladd M. Birch, P.E.
Michael S. Mooney
Neil H. Spencer, P.E.
Wade W. Bennion, P.E.
Steven T. Shepherd, P.E.

Addendum No. 1

1. Refer to the specifications section 15975 page 2 paragraphs D and E. With the current vents, the system will not define which of the 3 valves is leaking. However, the burner will be locked out if any valve leaks.
2. Refer to the specification section 15975 page 3 paragraph M.5. Delete the fuel metering.
3. Refer to the specifications section 15975 page 4 paragraph A. Delete the measuring and monitoring of NO.
4. Refer to the specifications section 15975 page 3 paragraph 3. Delete NO and SO₂.