



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

KIMBERLY HOOD
Executive Director

Division of Facilities Construction and Management

F. KEITH STEPAN
Director

ADDENDUM

Date: 12-18-2006

To: Contractors

From: Craig Wessman, Project Manager,
Boiler Controls Replacement
Salt Lake Community College
Jordan and Redwood Campus
DFCM Project. # 06164660

Subject: **Addendum No.1**

Pages: Addendum 1 Page

Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

SCHEDULE HAS NOT BEEN CHANGED

Addendum No. 1

Refer to the Specifications 15975, Page 4, Paragraph A under "Exhaust Gas Analysis." The EGA will also continuously measure and display NO.

End of Addendum