



State of Utah

JON M. HUNTSMAN, JR.  
Governor

GARY R. HERBERT  
Lieutenant Governor

Department of Administrative Services

RICHARD K. ELLIS  
Executive Director

Division of Facilities Construction and Management

F. KEITH STEPAN  
Director

## ADDENDUM

Date: 21 September 2006

To: Contractors

From: Jim Russell, Project Manager, DFCM

Reference: Orange Street, Bonneville, and Fremont AP&P Centers Lighting Upgrades  
Department of Corrections  
DFCM Project No.06178120

Subject: **Addendum No. 1**

Pages	Addendum Cover	1 page
	<u>Engineers Addendum - Electrical</u>	<u>3 page</u>
	<b>Total</b>	<b>4 pages</b>

---

**Note:** *This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.*

**SCHEDULE CHANGES** – There are no changes to the Project Schedule per this addendum.

**1.1 GENERAL** - A Fugitive Dust Plan will not be required on this project.

**1.2 SPECIFICATIONS** – See attached “Electrical Addendum #1 – Electrical Drawings”

End of Addendum #1

AP&P Lighting Upgrades  
Salt Lake City, Utah

Electrical Addendum No. 1

Electrical Drawings

Sheet EG001

Light Fixture Schedule

1. Change Type Z to a 13"x13" surface mount square fixture. LBL Lighting #7C33 W 226 1 0 H T with a contractor allowance price of \$410.00. Type Z2 shall be LBL Lighting #7C33 W 226 1 E H T with a contractor allowance price of \$525.00.

Sheet EL1B1

1. Change Keyed Note 11 to "Not Used". Do not remove the existing battery packs from the existing fixtures. Provide new 3000 lumen emergency battery packs with the new fixtures as specified.

Sheet EL1B2

1. In the gymnasium, the (2) existing lowbay fixtures with wire guards shall be salvaged and returned to the owner. The other existing fixtures, which are removed, shall be discarded.
2. In the gymnasium, mount the new fixtures to the bottom of the trusses rather than between them. The outer two rows shall be mounted to the bottom of the third truss from the wall, approximately 10' in from the wall. Mount the center row on the centermost truss in the room.
3. Change Keyed Note 7 to "Not Used". Do not remove the existing battery packs from the existing fixtures. Provide new 3000 lumen emergency battery packs with the new fixtures as specified.

Sheet EL1F1

1. In each bedroom corridor, provide and install (2) new exit signs to replace the existing exit sign/emergency bug-eye combination units. There is (1) single sided exit sign and (1) double sided exit sign in each corridor. The new units shall be Chloride #CX L N X G W TP or approved equal.
2. In the main vestibule, change the (2) fixtures from Types Z and Z2 to a Cole Lighting #1408S TP or Kirlin Lighting #RS81146 2 26 W for the Type Z fixture and Cole Lighting #1408S TP EM or Kirlin Lighting #RS81146 2 26 W -74 for the Type Z2 fixture.
3. Change Keyed Note 7 to "Not Used". Do not remove the existing battery packs from the existing fixtures. Provide new 3000 lumen emergency battery packs with the new fixtures as specified.
4. In the main entry and corridor, the Type F fixtures shall be mounted from the existing pendant locations if possible. It has been verified that the equivalent

Peerlite fixture, which is listed on this addendum, can be suspended and powered from the 90 degree corner connection points. Contractor shall confirm that the Alera or Focal Point fixtures can be mounted and powered from these points prior to ordering materials.

Sheet EL1F2

1. Change Keyed Note 6 to "Not Used". Do not remove the existing battery packs from the existing fixtures. Provide new 3000 lumen emergency battery packs with the new fixtures as specified.

All hazardous materials including magnetic ballasts containing PCB's and any fluorescent lamps which contain enough mercury not to pass the TCLP test, shall be properly disposed of per the Environmental Protection Agency's Hazardous Waste Rules.

### **LIST OF APPROVALS ITEMS**

The following items, trade names, products and manufacturers are approved for bidding. Approval does not relieve the bidder from satisfying the intent of the requirements of drawings, specifications, and addenda in every respect. Failure to conform to the design quality and standards specified, established and required may result in later disapproval. If equipment must be disapproved after bidding, supplier shall supply specified equipment at no extra cost to the owner.

Items are listed generally and specific model number, etc. shall be as submitted. Items submitted but not approved either did not satisfy the requirements, or showed insufficient data, or arrived after 8 day deadline established for submittal.

#### Lighting

A	Metalux, Lithonia	P1	Metalux, Lithonia
A1	Metalux, Lithonia	P2	Metalux, Lithonia
B1	Metalux, Lithonia	P3	Metalux
B2	Metalux, Lithonia	P4	Metalux
B4	Metalux, Lithonia	Q	Metalux, Lithonia
C	Metalux, Lithonia	R	CD Lighting
C1	Metalux, Lithonia	R1	CD Lighting
C2	Metalux, Lithonia	S1	Sun Valley, Diversified
D	Metalux, Lithonia	T	Lumark, Lithonia
EM	Surelites, Lithonia	U	Metalux, Lithonia
F	Focal Point, Peerlite	W	Invue, Hydrel
H1	Focal Point	X1	Evenlite
H2	Focal Point	Y	Atlantic, Maxilume
K	Portfolio, Gotham		
N	Neoray, Prudential		
O	Lumark, Diversified		

P Metalux, Lithuania