



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON
Director

ADDENDUM #1

Date: October 4, 2007

To: Contractors

From: Jim Russell, Project Manager, DFCM

Reference: Generator Upgrade – Bonneville Community Correctional Ctr.
Division of Adult Probation & Parole – Salt Lake City, Utah
DFCM Project No.07117120

Subject: Addendum No. 1

| | | | |
|-------|---------------------------|----------|--------------|
| Pages | Addendum | 1 | page |
| | <u>Engineers Addendum</u> | <u>1</u> | <u>page</u> |
| | Total | 2 | pages |

Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.

- 1.1 **SCHEDULE CHANGES** – There are no changes to the Project Schedule.
- 1.2 **GENERAL** – BNA Consulting Specifications.

Memorandum

To: Jim Russell
DFCM

From: Frank G. Knaus

Date: 4 October 2007

Re: DFCM Bonneville AP&P Generator Upgrade

Please issue the following in the next addendum.

SPECIFICATIONS:

Section 16001:

1. The owner shall pay all connections fees issued by Rocky Mountain Power.

LIST OF PRIOR APPROVALS:

The following items, trade names, products and manufacturers are approved for bidding. Approval does not relieve the bidder from satisfying the intent of the requirements of drawings, specifications, and addenda in every respect. Failure to conform to the design quality and standards specified, established and required may result in later disapproval. If equipment must be disapproved after bidding, supplier shall supply specified equipment at no extra cost to the Owner.

Items are listed generally and specific model number, etc. shall be as submitted. Items submitted but not approved either did not satisfy the requirements, or showed insufficient data, or arrived after the 8 day deadline established for submittals.

EMERGENCY ELECTRICAL SYSTEM:

Generac Power Systems Inc.