



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON
Director

ADDENDUM #1

Date: December 17, 2008

To: Contractors

From: Jeff Reddoor, Project Manager, DFCM

Reference: Dolphin Water Treatment System
Central Utah Correctional Facilities – Gunnison, Utah
DFCM Project No. 07118100

Subject: **Addendum No. 1**

Pages	Addendum	1 page
	<u>Engineers Addendum</u>	<u>1 page</u>
	Total	2 pages

Note: *This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.*

While we contend that SB220 should only be potentially applicable to a contract issued after the effective date of said bill, this is to clarify that for purposes of this contract, regardless of the execution or effective dates of this contract, the status of Utah Law and remedies available to the State of Utah and DFCM, as it relates to any matter referred to or affected by said SB220, shall be the Utah law in effect at the time of the issuance of this Addendum.

- 1.1 **SCHEDULE CHANGES** – There are no changes to the project schedule.
- 1.2 **GENERAL** – WHW Engineering – Clarifications and Specifications, please see attachment.

Utah!
Where ideas connect

ADDENDUM

Project Name: Department of Corrections CUCF
Water Treatment System

Addendum No.: 1

DFCM Project # 07118100

Date: 12/04/08

From: WHW Engineering Inc
8619 South Sandy Parkway
Sandy, Utah 84070
Phone (80) 466-4021 Fax (801) 466-8536

To: Jeff Reddoor - DFCM

This Addendum forms and becomes a part of the Contract Documents and modifies the original Bidding Documents dated 08/20/07 as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of 1 page.

I - CHANGES TO PRIOR ADDENDA: N/A

II - CHANGES TO BIDDING REQUIREMENTS: Re-Bid of project

III - CHANGES TO AGREEMENT & OTHER CONTRACT FORMS: N/A

IV – CHANGES/CLARIFICATIONS TO CONDITIONS OF THE CONTRACT: N/A

V - CHANGES/CLARIFICATIONS TO SPECIFICATIONS:

Item V-1. Section 15189 paragraph 2.2 - J add item d “valves may be packaged with Dolphin supplier.”

Item V-2. N/A

VI - CHANGES/CLARIFICATIONS TO DRAWINGS:

Item VI-1. Sheet ME 101 note 17 - add to note the following “valves may be purchased as a packaged from the Dolphin equipment supplier.

Item VI-2. Sheet ME 101 note 18 - add to note the following “valves may be purchased as a package from the Dolphin equipment manufacturer.

Item VI-3. Sheet ME 101 note 23: Delete reference to tie-in to existing building control. Note shall read “water treatment unit shall be protected from operating if there is no water in the system. The 3-way valve shall switch to bypass in a non water situation.

Item VI-4. Sheet ME 101 note 24: add to note the following “Valves my be purchased as a package from the Dolphin equipment supplier.”