



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

F. KEITH STEPAN
Director

ADDENDUM #1

Date: May 9, 2007

To: Contractors

From: Jim Russell, Project Manager, DFCM

Reference: Electrical Power Distribution Upgrade Camp Williams
Utah National Guard – Salt Lake City, Utah
DFCM Project No. 07167480

Subject: **Addendum No. 1**

Pages	Addendum	1	page
	<u>Answers to Questions</u>	<u>1</u>	<u>page</u>
	Total	2	pages

Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.

- 1.1 **SCHEDULE CHANGES** – There has been no changes to the Project Schedule.
- 1.2 **GENERAL** – Engineers answers to questions asked at the mandatory meeting.

End of Addendum #1

**CAMP WILLIAMS
ELECTRICAL POWER DISTRIBUTION UPGRADE
ADDENDUM 1**

ANSWER TO ENGINEERS QUESTIONS:

1. Will the project scope include taking down the existing power poles, or just relocating the power underground?

Answer: Yes, the complete existing overhead system will be removed.

2. Are there any telecommunications or video lines running across the overhead poles?

Answer: No, just primary and secondary power lines.

3. Is there any as-built information on the burial depths of underground utilities?

Answer: No

4. Are there any specific risks identified by the user or DFCM?

Answer: Existing buried lines such as Natural Gas, Sewer, Phone and Pressure Irrigation lines.

END OF ADDENDUM