



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON
Director

ADDENDUM #1

Date: June 10, 2008

To: Contractors

From: Craig Wessman, Project Manager, DFCM

Reference: Boiler Replacement – Administration Building
Department of Corrections – Draper, Utah
DFCM Project No. 07175100

Subject: **Addendum No. 1**

Pages	Addendum Cover Sheet	1 page
	<u>Engineer's Addendum</u>	<u>1 page</u>
	Total	2 pages

Note: *This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.*

While we contend that SB220 should only be potentially applicable to a contract issued after the effective date of said bill, this is to clarify that for purposes of this contract, regardless of the execution or effective dates of this contract, the status of Utah Law and remedies available to the State of Utah and DFCM, as it relates to any matter referred to or affected by said SB220, shall be the Utah law in effect at the time of the issuance of this Addendum.

1.1 **SCHEDULE CHANGES** – There are no schedule changes.

1.2 **GENERAL ITEMS** – Clarifications to specifications and drawings.

Utah!
Where ideas connect

ADDENDUM

Project Name: Department of Corrections

Addendum No.: 1

DFCM Project # 07175100

Date: 06-10-08

From: WHW Engineering Inc
8619 South Sandy Parkway
Sandy, Utah 84070
Phone (80) 466-4021 Fax (801) 466-8536

To: All Bidders

This Addendum forms and becomes a part of the Contract Documents and modifies the original Bidding Documents dated May 2008 as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of 1 page.

I - CHANGES TO PRIOR ADDENDA: NA

II - CHANGES/CLARIFICATIONS TO SPECIFICATIONS:

- Item II-1.** Section 15195 – 3.11.B. shall be modified to read as follows:
“B. Aboveground, distribution piping **2-1/2”** and larger shall be the following:
1. Steel pipe with wrought-steel fittings and welded joints.”

III - CHANGES/CLARIFICATIONS TO DRAWINGS:

- Item III-1.** Drawing ME401 add the following: “ Condensate drains from new boilers shall be collected into a common 1-1/2” PVC condensate drain line, and routed outside of boiler room to adjacent flower beds.

PRIOR APPROVALS

THE FOLLOWING ITEMS, AS SUBMITTED, ARE CONSIDERED, IN GENERAL AND IN NAME ONLY, AS EQUAL TO THOSE ITEMS SPECIFIED. THIS REVIEW DOES NOT RELIEVE THE CONTRACTOR OR SUPPLIER OF THE RESPONSIBILITY OF CONFORMING TO THE DRAWINGS AND SPECIFICATIONS, NOR DOES IT RELIEVE THE CONTRACTOR OF THE REQUIREMENTS OF THE SPECIFICATIONS FOR COORDINATION WITH OTHER TRADES. ALL DIMENSIONS SHALL BE CONFIRMED AND CORRELATED AT THE JOBSITE. THE CONTRACTOR SHALL BE RESPONSIBLE FOR VERIFYING EXISTING CONDITIONS AND THE SUITABILITY OF “EQUAL” PRODUCTS FOR THE SPECIFIED APPLICATION.

Description

Manufacturer

15513 – condensing boilers

Aerco

End of Addendum