



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON
Director

ADDENDUM #1

Date: January 25, 2008

To: Contractors

From: Jeff Reddoor, Project Manager, DFCM

Reference: Boiler/Condenser Replacement – Cedar City DWS
Department of Workforce Services – Cedar City, Utah
DFCM Project No. 07184920

Subject: **Addendum No. 1**

Pages	Addendum	1	page
	<u>Engineer's Addendum</u>	<u>1</u>	<u>page</u>
	Total	2	pages

Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.

- 1.1 **SCHEDULE CHANGES** – There are no changes to the project schedule.
- 1.2 **GENERAL** – WHW Engineering, Inc. – Changes/Clarifications to drawings.

ADDENDUM

Project Name: Department of Workforce Services
Cedar Boiler/Condenser Replacement

Addendum No.: 1 (one)

DFCM Project # 07184920

Date: January 24, 2008

From: WHW Engineering Inc
8619 South Sandy Parkway Suite 101
Sandy, Utah 84070
Phone (80) 466-4021 Fax (801) 466-8536

To: Jeff Reddoor

This Addendum forms and becomes a part of the Contract Documents and modifies the original Bidding Documents dated November 2007 as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of 1 page.

I - CHANGES TO PRIOR ADDENDA: N/A

II - CHANGES TO BIDDING REQUIREMENTS: N/A

III - CHANGES TO AGREEMENT & OTHER CONTRACT FORMS: N/A

IV – CHANGES/CLARIFICATIONS TO CONDITIONS OF THE CONTRACT: N/A

V - CHANGES/CLARIFICATIONS TO SPECIFICATIONS: N/A

VI - CHANGES/CLARIFICATIONS TO DRAWINGS:

Item VI-1. General Note - add the following: The design build Electrical Contractor shall provide the two VFD's required for the air handling units. VFD manufacturers shall be.

1. Reliance.
2. MagnaTech.
3. Advance.