



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON
Director

ADDENDUM #1

Date: September 10, 2007

To: Contractors

From: Wayne Smith, Project Manager, DFCM

Reference: Utah State Fairpark Grand Building Boiler Replacement
Salt Lake City, Utah
DFCM Project No. 07190370

Subject: **Addendum No. 1**

| | | | |
|-------|---------------------------|----------|-------------|
| Pages | Addendum | 1 | page |
| | <u>Engineers Addendum</u> | <u>1</u> | <u>page</u> |
| | Total | 2 | pages |

Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.

1.1 SCHEDULE CHANGES – There are no changes to the Project Schedule.

1.2 GENERAL – WHW Engineering – Specifications and Clarifications to the scope of work.

ADDENDUM

Project Name: Fairpark Grand Building Boiler Replacement

Addendum No.: 1

DFCM Project # 07190370

Date: 09-07-07

From: WHW Engineering Inc
1354 East 3300 South Suite 200
Salt Lake City, Utah 84106
Phone (80) 466-4021 Fax (801) 466-8536

To: All bidders

This Addendum forms and becomes a part of the Contract Documents and modifies the original Bidding Documents dated August 2007 as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of 1 page.

I - CHANGES TO PRIOR ADDENDA: NA

II - CHANGES TO BIDDING REQUIREMENTS: None

III - CHANGES TO AGREEMENT & OTHER CONTRACT FORMS: None

IV – CHANGES/CLARIFICATIONS TO CONDITIONS OF THE CONTRACT: None

V - CHANGES/CLARIFICATIONS TO SPECIFICATIONS:

Item V-1. Section 01100 paragraph 1.9 add the following paragraph:
“Heating water systems shall be coordinated with Fairgrounds personnel, and shall not be for more than 5 days at a time. The system must be operational for all weekends. This may include, at the contractor’s option, working in phases as necessary to maintain operation at all weekends. Heating system shut downs shall not be allowed when weather forecasts anticipate temperatures below 35 degrees F.”

VI - CHANGES/CLARIFICATIONS TO DRAWINGS: None

END OF ADDENDUM