



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON
Director

ADDENDUM #1

Date: November 15, 2007

To: Contractors

From: Tim Parkinson, Project Manager, DFCM

Reference: Farmington Court Security Upgrade
Administrative Office of the Courts – Farmington, Utah
DFCM Project No.07206150

Subject: Addendum No. 1

Pages	<u>Addendum</u>	<u>2</u>	<u>pages</u>
	Total	2	pages

Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.

1.1 **SCHEDULE CHANGES – There are no changes to the Project Schedule.**

1.2 **GENERAL – Question:**

In the meeting I thought there was an agreement to consider Pelco for this project and I didn't think there was any problem with the contractors, but now that the sub contractor wants to use has proposed a substitute (that is not listed in the specs), I believe that to keep everything kosher with the "open" spec rule, I need to add "or equal" to the specification paragraph that Brian has referenced.

Clarification:

Sheet EY601

1. Detail D5. Delete camera type 3 from the camera schedule. There are none of these types currently in the drawings.
2. Detail A3. Clarification. The numbered subscripts labeled on the new cameras are to signify typical camera types and should not be construed as quantities of said cameras. It shall be required to obtain quantity of cameras and other devices directly from the floor drawings.

Specification Section 282300

1. Clarification. There have been no new additions to the approved products list found in Paragraph 2.1 Item A.2.

Section 282300

1. Paragraph 2.2 E. Change the last sentence to read as follows:

"Provide the Pelco DX8100 series with the most recent software revisions or a product from one of the other approved manufacturers that meet or exceed the full set of capabilities of the Pelco DX8100."