



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON
Director

ADDENDUM #1

Date: June 26, 2007

To: Contractors

From: Tim Parkinson, Project Manager, DFCM

Reference: Ogden 2nd District Courts Sewer and Ground Water Ejection Pump Replacement
Administrative Office of the Courts – Ogden, Utah
DFCM Project No. 07208150

Subject: **Addendum No. 1**

Pages	Addendum	1	page
	<u>Engineers Addendum</u>	<u>1</u>	<u>page</u>
	Total	2	pages

Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.

- 1.1 **SCHEDULE CHANGES** – There are no changes to the Project Schedule.
- 1.2 **GENERAL** – WHW Engineering – Specifications.

End of Addendum #1

ADDENDUM

Project Name: Ogden 2nd District Courts
Sewer and Groundwater Ejection Pumps Replacement

Addendum No.: 1

DFCM Project # 07208150

Date: 06-26-07

From: WHW Engineering Inc
1354 East 3300 South Suite 200
Salt Lake City, Utah 84106
Phone (80) 466-4021 Fax (801) 466-8536

To: All Bidders

This Addendum forms and becomes a part of the Contract Documents and modifies the original Bidding Documents dated June 2007 as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of 1 page(s).

I - CHANGES TO PRIOR ADDENDA: None

II - CHANGES TO BIDDING REQUIREMENTS: None

III - CHANGES TO AGREEMENT & OTHER CONTRACT FORMS: None

IV – CHANGES/CLARIFICATIONS TO CONDITIONS OF THE CONTRACT: None

V - CHANGES/CLARIFICATIONS TO SPECIFICATIONS: None

VI - CHANGES/CLARIFICATIONS TO DRAWINGS:

- Item VI-1.** This contractor shall sub-contract with Utah Controls to provide a high water alarm from sewage ejector basin to the existing building management system. This alarm shall be installed immediately upon award of contract because the existing pumps are currently in bad condition, and have no automatic change-over in case of failure.
- Item VI-2.** Any lubrication or grease lines for new pumps shall be ran in copper tubing. No plastic will be allowed.

End of Addendum