



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON
Director

ADDENDUM NO. 1

Date: May 20, 2009

To: Contractors

From: Darrell Hunting, DFCM – Project Manager

Reference: North Parking Lot Improvements Phase II – East Lot Bus Improvements
Bridgerland ATC
DFCM Project No. 07298210

Subject: Addendum No. 1

Pages Total Addendum 2 pages

Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.

While we contend that SB220 should only be potentially applicable to a contract issued after the effective date of said bill, this is to clarify that for purposes of this contract, regardless of the execution or effective dates of this contract, the status of Utah Law and remedies available to the State of Utah and DFCM, as it relates to any matter referred to or affected by said SB220, shall be the Utah law in effect at the time of the issuance of this Addendum.

1.1 **SCHEDULE CHANGES:** No Schedule changes

1.2 **GENERAL ITEMS:**

- 1.2.1 Clean fill can be stockpile at West Campus as long as all debris is removed.
- 1.2.2 Contractor can choose to plant new trees instead of replacing existing trees.
- 1.2.3 There are two existing 4” conduits crossing parking lot in existing trenched area. There is fiber optics in this location. Contractor to coordinate work in this area to avoid damage.
- 1.2.4 The successful contractor will be given a tax exempt certificate for the purchase of all equipment and materials.

1.2.5 The new light pole on the west side of parking lot does not replace existing light. Both lights will be required. They can, however, be mounted on the same base

1.2.6 Question: I am in need of some clarification after reviewing my notes from the pre bid meeting today. I thought I understood that the pulverized asphalt could be used as base under the new asphalt section addition. However, I cannot find a note on the bid documents stating this to be an option. I only see the note that it is to be stockpiled west of the building. If the pulverized material can be used in the new section, does it need to be used as sub-base material or base material?

Answer: Clarification on pulverized asphalt re-uses. The pulverized asphalt can be used as supplement Type A4 Material as indicated in the plans. Pulverized asphalt should be blended at a 1 to 1 ratio with import Type A4 material to produce a uniform combined material. Any extra pulverized material should be stockpiled at location determined by BATC.