



STATE OF UTAH - DEPARTMENT OF ADMINISTRATIVE SERVICES

**Division of Facilities Construction and Management**

**DFCM**

## **STANDARD LOW BID PROJECT**

**February 6, 2008**

# **ELECTRICAL UPGRADES BIG CREEK CAMPGROUND BEAR LAKE STATE PARK**

**DIVISION OF PARKS AND RECREATION  
GARDEN CITY, UTAH**

DFCM Project Number 07333510

JUB ENGINEERS  
1047 South 100 West #180  
Logan, Utah 84321

# TABLE OF CONTENTS

	<u>Page Numbers</u>
Title Sheet	1
Table of Contents	2
Notice to Contractors	3
Project Description and Qualifications	4
Project Schedule	5
Bid Form	6
Instructions to Bidders	8
Bid Bond	12
Instructions and Subcontractors List Form	13
Contractor's Agreement	16
Performance Bond	21
Payment Bond	22
Certificate of Substantial Completion	23
General Contractor Past Performance Rating	

Current copies of the following documents are hereby made part of these contract documents by reference. These documents are available on the DFCM web site at <http://dfcm.utah.gov> or are available upon request from DFCM.

DFCM General Conditions dated May 25, 2005.

DFCM Application and Certification for Payment dated May 25, 2005.

Technical Specifications :

Drawings:

**The Agreement and General Conditions dated May 25, 2005 have been updated from versions that were formally adopted and in use prior to this date. The changes made to the General Conditions are identified in a document entitled Revisions to General Conditions that is available on DFCM's web site at <http://dfcm.utah.gov>**

## NOTICE TO CONTRACTORS

Sealed bids will be received by the Division of Facilities Construction and Management (DFCM) for:

**ELECTRICAL UPGRADES - BIG CREEK CAMP GROUND**  
**BEAR LAKE STATE PARK – GARDEN CITY, UTAH**  
**DFCM PROJECT NO: 07333510**

Bids will be in accordance with the Contract Documents that will be available at 4:00 PM on Wednesday, February 6, 2008 and distributed in electronic format only on CDs from DFCM, 4110 State Office Building, Salt Lake City, Utah and on the DFCM web page at <http://dfcm.utah.gov>. For questions regarding this project, please contact Brian Bales, DFCM, at 801-538-3417. No others are to be contacted regarding this bidding process. The construction budget for this project is \$225,000.00.

A **mandatory** pre-bid meeting will be held at 1:00 PM on Monday, February 11, 2008 at the Big Creek Campground, Bear Lake State Park, Garden City, Utah. All bidders wishing to bid on this project are required to attend this meeting.

Bids will be received until the hour of 2:30 PM on Wednesday, February 20, 2008 at DFCM, 4110 State Office Building, Salt Lake City, Utah 84114. Bids will be opened and read aloud in the DFCM Conference Room, 4110 State Office Building, Salt Lake City, Utah. NOTE: Bids must be received at 4110 State Office Building by the specified time.

A bid bond in the amount of five percent (5%) of the bid amount, made payable to the Division of Facilities Construction and Management on DFCM's bid bond form, shall accompany the bid.

The Division of Facilities Construction and Management reserves the right to reject any or all bids or to waive any formality or technicality in any bid in the interest of DFCM.

DIVISION OF FACILITIES CONSTRUCTION AND MANAGEMENT  
Marla Workman, Contract Coordinator  
4110 State Office Building, Salt Lake City, Utah 84114

## **PROJECT DESCRIPTION**

Project scope of work is to upgrade the electrical services and vehicle pads for the campground recreational vehicle campsites.

The electrical scope of work is comprised of installation of new distribution panels, underground conduit with wire, and new RV pedestals to supply power to the campsites. Demolition of the existing campsite electrical is required.

The civil scope of work is described as increasing the overall size of various recreational vehicle campsites. Excavation, backfill, and asphalt will be required. Removal of existing brush and trees to make room for the pad improvements will be necessary.

Location of utilities not marked by the local public utility location service is the responsibility of the contractor. Those utilities include, but are not limited to, RV pad sewer and water lines.

The contractor is responsible for verifying the scale and distances required for this project prior to submitting their bid.

The contractor shall coordinate with campground management throughout the performance period. These campsites are reserved for use in the summer months requiring the contractor to provide protection of the users from hazards associated with the installation of the improvements.

## **QUALIFICATIONS**

Contractors bidding on this project are required to have completed at least three similar projects in size and scope. They shall have the ability to provide construction schedules with milestones in order to complete this project by the specified completion date.

Contractors bidding on this project shall have the ability to provide the labor and equipment necessary to complete this project by the specified completion date.

Contractors bidding on this project are required to have experience in all phases of this type of construction.

Documentation to substantiate the contractor's qualifications shall be provided if requested by DFCM.

**PROJECT SCHEDULE**

**PROJECT NAME: ELECTRICAL UPGRADES - BIG CREEK CAMPGROUND  
BEAR LAKE STATE PARK  
DIVISION OF PARKS AND RECREATION – GARDEN CITY, UTAH**  
**DFCM PROJECT # 07333510**

<b>Event</b>	<b>Day</b>	<b>Date</b>	<b>Time</b>	<b>Place</b>
Bidding Documents Available	Wednesday	February 6, 2008	4:00 PM	DFCM 4110 State Office Bldg SLC, UT and the DFCM web site *
<b>Mandatory</b> Pre-bid Site Meeting	Monday	February 11, 2008	1:00 PM	Big Creek Campground Bear Lake State Park Garden City, Utah
Last Day to Submit Questions	Wednesday	February 13, 2008	2:00 PM	Brian Bales – DFCM E-mail: brbales@utah.gov Fax 801-538-3267
Addendum Deadline (exception for bid delays)	Friday	February 15, 2008	2:00 PM	DFCM web site *
Prime Contractors Turn In Bid and Bid Bond	Wednesday	February 20, 2008	2:30 PM	DFCM 4110 State Office Bldg SLC, UT
Sub-contractor List Due	Thursday	February 21, 2008	2:30 PM	DFCM 4110 State Office Bldg SLC, UT Fax 801-538-3677
Substantial Completion Date	Friday	May 23, 2008		

\* **NOTE:** DFCM's web site address is <http://dfcm.utah.gov>



## BID FORM

NAME OF BIDDER \_\_\_\_\_ DATE \_\_\_\_\_

To the Division of Facilities Construction and Management  
4110 State Office Building  
Salt Lake City, Utah 84114

The undersigned, responsive to the "Notice to Contractors" and in accordance with the "Instructions to Bidders", in compliance with your invitation for bids for the **ELECTRICAL UPGRADES – BIG CREEK CAMP-GROUND – BEAR LAKE STATE PARK – DIVISION OF PARKS AND RECREATION – GARDEN CITY, UTAH – DFCM PROJECT NO. 07333510** and having examined the Contract Documents and the site of the proposed Work and being familiar with all of the conditions surrounding the construction of the proposed Project, including the availability of labor, hereby proposes to furnish all labor, materials and supplies as required for the Work in accordance with the Contract Documents as specified and within the time set forth and at the price stated below. This price is to cover all expenses incurred in performing the Work required under the Contract Documents of which this bid is a part:

I/We acknowledge receipt of the following Addenda: \_\_\_\_\_

**BASE BID:** For all electrical improvement work, material, and labor shown on the Drawings and described in the Specifications and Contract Documents including but not limited to all trenching, backfill, asphalt replacement for roadway crossings, distribution panels, conduit, wire, RV pedestals with concrete and utility location, I/we agree to perform for the sum of:

\_\_\_\_\_ DOLLARS (\$\_\_\_\_\_)

(In case of discrepancy, written amount shall govern)

**ADDITIVE ALTERNATE NO. 1:** For all campsite civil improvement work, material, and labor shown on the Drawings and described in the Specifications and Contract Documents including but not limited to site layout, site grubbing, excavation, burden removal, imported material, asphalt, drainage improvements, new trees, site restoration, traffic control, and utility location, I/we agree to perform for the sum of:

\_\_\_\_\_ DOLLARS (\$\_\_\_\_\_)

(In case of discrepancy, written amount shall govern)

I/We guarantee that the Work will be Substantially Complete by **May 23, 2008** should I/we be the successful bidder, and agree to pay liquidated damages in the amount of **\$1,000.00** per day for each day after expiration of the Contract Time as stated in Article 3 of the Contractor's Agreement.

PAGE NO. 2

This bid shall be good for 45 days after bid opening.

Enclosed is a 5% bid bond, as required, in the sum of \_\_\_\_\_

The undersigned Contractor's License Number for Utah is \_\_\_\_\_.

Upon receipt of notice of award of this bid, the undersigned agrees to execute the contract within ten (10) days, unless a shorter time is specified in the Contract Documents, and deliver acceptable Performance and Payment bonds in the prescribed form in the amount of 100% of the Contract Sum for faithful performance of the contract.

The Bid Bond attached, in the amount not less than five percent (5%) of the above bid sum, shall become the property of the Division of Facilities Construction and Management as liquidated damages for delay and additional expense caused thereby in the event that the contract is not executed and/or acceptable 100% Performance and Payment bonds are not delivered within the time set forth.

Type of Organization: \_\_\_\_\_ (Corporation, Partnership, Individual, etc.)

Any request and information related to Utah Preference Laws: \_\_\_\_\_

Respectfully submitted,

\_\_\_\_\_  
Name of Bidder

ADDRESS:

\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_  
Authorized Signature

# INSTRUCTIONS TO BIDDERS

## 1. Drawings and Specifications, Other Contract Documents

Drawings and Specifications, as well as other available Contract Documents, may be obtained as stated in the Invitation to Bid.

## 2. Bids

Before submitting a bid, each contractor shall carefully examine the Contract Documents, shall visit the site of the Work; shall fully inform themselves as to all existing conditions and limitations; and shall include in the bid the cost of all items required by the Contract Documents. If the bidder observes that portions of the Contract Documents are at variance with applicable laws, building codes, rules, regulations or contain obvious erroneous or uncoordinated information, the bidder shall promptly notify the DFCM Representative and the necessary changes shall be accomplished by Addendum.

The bid, bearing original signatures, must be typed or handwritten in ink on the Bid Form provided in the procurement documents and submitted in a sealed envelope at the location specified by the Invitation to Bid prior to the deadline for submission of bids.

Bid bond security, in the amount of five percent (5%) of the bid, made payable to the Division of Facilities Construction and Management, shall accompany bid. **THE BID BOND MUST BE ON THE BID BOND FORM PROVIDED IN THE PROCUREMENT DOCUMENTS IN ORDER TO BE CONSIDERED AN ACCEPTABLE BID.**

If the bid bond security is submitted on a bid bond form other than DFCM's required bid bond form, and the bid security meets all other legal requirements, the bidder will be allowed to provide an acceptable bid bond by the close of business on the next business day following notification by DFCM of submission of a defective bid bond security. **NOTE: A cashier's check cannot be used as a substitute for a bid bond.**

## 3. Contract and Bond

The Contractor's Agreement will be in the form found in the specifications. The Contract Time will be as indicated in the bid. The successful bidder, simultaneously with the execution of the Contract Agreement, will be required to furnish a performance bond and a payment bond, both bearing original signatures, upon the forms provided in the procurement documents. The performance and payment bonds shall be for an amount equal to one hundred percent (100%) of the contract sum and secured from a company that meets the requirements specified in the requisite forms. Any bonding requirements for subcontractors will be specified in the Supplementary General Conditions.

**4. Listing of Subcontractors**

Listing of Subcontractors shall be as summarized in the “Instructions and Subcontractor’s List Form”, which are included as part of these Contract Documents. The Subcontractors List shall be delivered to DFCM or faxed to DFCM at (801)538-3677 within 24 hours of the bid opening. Requirements for listing additional subcontractors will be listed in the Contract Documents.

DFCM retains the right to audit or take other steps necessary to confirm compliance with requirements for the listing and changing of subcontractors. Any contractor who is found to not be in compliance with these requirements is subject to a debarment hearing and may be debarred from consideration for award of contracts for a period of up to three years.

**5. Interpretation of Drawings and Specifications**

If any person or entity contemplating submitting a bid is in doubt as to the meaning of any part of the drawings, specifications or other Contract Documents, such person shall submit to the DFCM Project Manager a request for an interpretation thereof. The person or entity submitting the request will be responsible for its prompt delivery. Any interpretation of the proposed documents will be made only by addenda posted on DFCM’s web site at <http://dfcm.utah.gov>. Neither the DFCM nor A/E will be responsible for any other explanations or interpretations of the proposed documents. A/E shall be deemed to refer to the architect or engineer hired by DFCM as the A/E or Consultant for the Project.

**6. Addenda**

Addenda will be posted on DFCM’s web site at <http://dfcm.utah.gov>. Contractors are responsible for obtaining information contained in each addendum from the web site. Addenda issued prior to the submittal deadline shall become part of the bidding process and must be acknowledged on the bid form. Failure to acknowledge addenda may result in disqualification from bidding.

**7. Award of Contract**

The Contract will be awarded as soon as possible to the lowest, responsive and responsible bidder, based on the lowest combination of base bid and acceptable prioritized alternates, provided the bid is reasonable, is in the interests of the State of Utah to accept and after applying the Utah Preference Laws in U.C.A. Title 63, Chapter 56. DFCM reserves the right to waive any technicalities or formalities in any bid or in the bidding. Alternates will be accepted on a prioritized basis with Alternate 1 being highest priority, Alternate 2 having second priority, etc.

**8. DFCM Contractor Performance Rating**

As a contractor completes each DFCM project, DFCM, the architect/engineer and the using agency will evaluate project performance based on the enclosed “DFCM Contractor Performance Rating” form. The ratings issued on this project will not affect this project but may affect the award on future projects.

**9. Licensure**

The Contractor shall comply with and require all of its subcontractors to comply with the license laws as required by the State of Utah.

**10. Permits**

In concurrence with the requirements for permitting in the General Conditions, it is the responsibility of the Contractor to obtain the fugitive dust plan requirements from the Utah Division of Air Quality and the SWPPP requirements from the Utah Department of Environmental Quality and submit the completed forms and pay any permit fee that may be required for this specific project. Failure to obtain the required permit may result in work stoppage and/or fines from the regulating authority that will be the sole responsibility of the Contractor. Any delay to the project as a result of any such failure to obtain the permit or noncompliance with the permit shall not be eligible for any extension in the Contract Time.

**11. Right to Reject Bids**

DFCM reserves the right to reject any or all Bids.

**12. Time is of the Essence**

Time is of the essence in regard to all the requirements of the Contract Documents.

**13. Withdrawal of Bids**

Bids may be withdrawn on written request received from bidder prior to the time fixed for opening. Negligence on the part of the bidder in preparing the bid confers no right for the withdrawal of the bid after it has been opened.

**14. Product Approvals**

Where reference is made to one or more proprietary products in the Contract Documents, but restrictive descriptive materials of one or more manufacturer(s) is referred to in the Contract Documents, the products of other manufacturers will be accepted, provided they equal or exceed the standards set forth in the drawings and specifications and are compatible with the intent and purpose of

the design, subject to the written approval of the A/E. Such written approval must occur prior to the deadline established for the last scheduled addenda to be issued. The A/E's written approval will be in an issued addendum. If the descriptive material is not restrictive, the products of other manufacturers specified will be accepted without prior approval provided they are compatible with the intent and purpose of the design as determined by the A/E.

**15. Financial Responsibility of Contractors, Subcontractors and Sub-subcontractors**

Contractors shall respond promptly to any inquiry in writing by DFCM to any concern of financial responsibility of the contractor, subcontractor or sub-subcontractor.

**16. Debarment**

By submitting a bid, the Contractor certifies that neither it nor its principals, including project and site managers, have been, or are under consideration for, debarment or suspension, or any action that would exclude such from participation in a construction contract by any governmental department or agency. If the Contractor cannot certify this statement, attach to the bid a detailed written explanation which must be reviewed and approved by DFCM as part of the requirements for award of the Project.



**Division of Facilities Construction and****INSTRUCTIONS AND SUBCONTRACTORS LIST FORM**

The three low bidders, as well as all other bidders that desire to be considered, are required by law to submit to DFCM within 24 hours of bid opening a list of **ALL** first-tier subcontractors, including the subcontractor's name, bid amount and other information required by Building Board Rule and as stated in these Contract Documents, based on the following:

**DOLLAR AMOUNTS FOR LISTING**

**PROJECTS UNDER \$500,000: ALL FIRST-TIER SUBS \$20,000 OR OVER MUST BE LISTED**  
**PROJECTS \$500,000 OR MORE: ALL FIRST-TIER SUBS \$35,000 OR OVER MUST BE LISTED**

- Any additional subcontractors identified in the bid documents shall also be listed.
- The DFCM Director may not consider any bid submitted by a bidder if the bidder fails to submit a subcontractor list meeting the requirements of State law.
- List subcontractors for base bid as well as the impact on the list that the selection of any alternate may have.
- Bidder may not list more than one subcontractor to perform the same work.
- If there are no subcontractors for the job that are required to be reported by State law (either because there are no subcontractors that will be used on the project or because there are no first-tier subcontractors over the dollar amounts referred to above), then you do not need to submit a sublist. If you do not submit a sublist, it will be deemed to be a representation by you that there are no subcontractors on the job that are required to be reported under State law. At any time, DFCM reserves the right to inquire, for security purposes, as to the identification of the subcontractors at any tier that will be on the worksite.

**LICENSURE:**

The subcontractor's name, the type of work, the subcontractor's bid amount, and the subcontractor's license number as issued by DOPL, if such license is required under Utah Law, shall be listed. Bidder shall certify that all subcontractors, required to be licensed, are licensed as required by State law. A subcontractor includes a trade contractor or specialty contractor and does not include suppliers who provide only materials, equipment, or supplies to a contractor or subcontractor.

**'SPECIAL EXCEPTION':**

A bidder may list 'Special Exception' in place of a subcontractor when the bidder intends to obtain a subcontractor to perform the work at a later date because the bidder was unable to obtain a qualified or reasonable bid under the provisions of U.C.A. Section 63A-5-208(4). The bidder shall insert the term 'Special Exception' for that category of work, and shall provide documentation with the subcontractor list describing the bidder's efforts to obtain a bid of a qualified subcontractor at a reasonable cost and why the bidder was unable to obtain a qualified subcontractor bid. The Director must find that the bidder complied in good faith with State law requirements for any 'Special Exception' designation, in order for the bid to be considered. If awarded the contract, the Director shall supervise the bidder's efforts to obtain a qualified subcontractor bid. The amount of the awarded contract may not be adjusted to reflect the actual amount of the subcontractor's bid. Any listing of 'Special Exception' on the sublist form shall also include amount allocated for that work.

**GROUNDS FOR DISQUALIFICATION:**

The Director may not consider any bid submitted by a bidder if the bidder fails to submit a subcontractor list meeting the requirements of State law. Director may withhold awarding the contract to a particular bidder if one or more of the proposed subcontractors are considered by the Director to be unqualified to do the Work or for

**INSTRUCTIONS AND SUBCONTRACTORS LIST FORM**  
**Page No. 2**

such other reason in the best interest of the State of Utah. Notwithstanding any other provision in these instructions, if there is a good faith error on the sublist form, at the sole discretion of the Director, the Director may provide notice to the contractor and the contractor shall have 24 hours to submit the correction to the Director. If such correction is submitted timely, then the sublist requirements shall be considered met.

**CHANGES OF SUBCONTRACTORS SPECIFICALLY IDENTIFIED ON SUBLIST FORM:**

Subsequent to twenty-four hours after the bid opening, the contractor may change its listed subcontractors only after receiving written permission from the Director based on complying with all of the following criteria.

- (1) The contractor has established in writing that the change is in the best interest of the State and that the contractor establishes an appropriate reason for the change, which may include, but not is not limited to, the following reasons: the original subcontractor has failed to perform, or is not qualified or capable of performing, and/or the subcontractor has requested in writing to be released.
- (2) The circumstances related to the request for the change do not indicate any bad faith in the original listing of the subcontractors.
- (3) Any requirement set forth by the Director to ensure that the process used to select a new subcontractor does not give rise to bid shopping.
- (4) Any increase in the cost of the subject subcontractor work is borne by the contractor.
- (5) Any decrease in the cost of the subject subcontractor work shall result in a deductive change order being issued for the contract for such decreased amount.
- (6) The Director will give substantial weight to whether the subcontractor has consented in writing to being removed unless the Contractor establishes that the subcontractor is not qualified for the work.

**EXAMPLE:**

Example of a list where there are only four subcontractors:

TYPE OF WORK	SUBCONTRACTOR, "SELF" OR "SPECIAL EXCEPTION"	SUBCONTRACTOR BID AMOUNT	CONTRACTOR LICENSE #
ELECTRICAL	ABCD Electric Inc.	\$350,000.00	123456789000
LANDSCAPING	"Self" *	\$300,000.00	123456789000
CONCRETE (ALTERNATE #1)	XYZ Concrete Inc	\$298,000.00	987654321000
MECHANICAL	"Special Exception" (attach documentation)	Fixed at: \$350,000.00	(TO BE PROVIDED AFTER OBTAINING SUBCONTRACTOR)

\* Bidders may list "self", but it is not required.

**PURSUANT TO STATE LAW - SUBCONTRACTOR BID AMOUNTS CONTAINED IN THIS SUBCONTRACTOR LIST SHALL NOT BE DISCLOSED UNTIL THE CONTRACT HAS BEEN AWARDED.**



SUBCONTRACTORS LIST
FAX TO 801-538-3677

PROJECT TITLE: \_\_\_\_\_

Caution: You must read and comply fully with instructions.

Table with 4 columns: TYPE OF WORK, SUBCONTRACTOR, 'SELF' OR 'SPECIAL EXCEPTION', SUBCONTRACTOR BID AMOUNT, CONT. LICENSE #

We certify that:

- 1. This list includes all subcontractors as required by the instructions, including those related to the base bid as well as any alternates.
2. We have listed 'Self' or 'Special Exception' in accordance with the instructions.
3. All subcontractors are appropriately licensed as required by State law.

FIRM: \_\_\_\_\_

DATE: \_\_\_\_\_

SIGNED BY: \_\_\_\_\_

NOTICE: FAILURE TO SUBMIT THIS FORM, PROPERLY COMPLETED AND SIGNED, AS REQUIRED IN THESE CONTRACT DOCUMENTS, SHALL BE GROUNDS FOR OWNER'S REFUSAL TO ENTER INTO A WRITTEN CONTRACT WITH BIDDER. ACTION MAY BE TAKEN AGAINST BIDDERS BID BOND AS DEEMED APPROPRIATE BY OWNER. ATTACH A SECOND PAGE IF NECESSARY.

**CONTRACTOR'S AGREEMENT**

FOR:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

THIS CONTRACTOR'S AGREEMENT, made and entered into this \_\_\_\_ day of \_\_\_\_\_, 20\_\_, by and between the DIVISION OF FACILITIES CONSTRUCTION AND MANAGEMENT, hereinafter referred to as "DFCM", and \_\_\_\_\_, incorporated in the State of \_\_\_\_\_ and authorized to do business in the State of Utah, hereinafter referred to as "Contractor", whose address is \_\_\_\_\_.

WITNESSETH: WHEREAS, DFCM intends to have Work performed at \_\_\_\_\_.

WHEREAS, Contractor agrees to perform the Work for the sum stated herein.

NOW, THEREFORE, DFCM and Contractor for the consideration provided in this Contractor's Agreement, agree as follows:

**ARTICLE 1. SCOPE OF WORK.** The Work to be performed shall be in accordance with the Contract Documents prepared by \_\_\_\_\_ and entitled "\_\_\_\_\_."

The DFCM General Conditions ("General Conditions") dated May 25, 2005 on file at the office of DFCM and available on the DFCM website, are hereby incorporated by reference as part of this Agreement and are included in the specifications for this Project. All terms used in this Contractor's Agreement shall be as defined in the Contract Documents, and in particular, the General Conditions.

The Contractor Agrees to furnish labor, materials and equipment to complete the Work as required in the Contract Documents which are hereby incorporated by reference. It is understood and agreed by the parties hereto that all Work shall be performed as required in the Contract Documents and shall be subject to inspection and approval of DFCM or its authorized representative. The relationship of the Contractor to the DFCM hereunder is that of an independent Contractor.

**ARTICLE 2. CONTRACT SUM.** The DFCM agrees to pay and the Contractor agrees to accept in full performance of this Contractor's Agreement, the sum of \_\_\_\_\_ DOLLARS AND NO CENTS (\$\_\_\_\_\_.00), which is the base bid, and which sum also includes the cost of a 100% Performance Bond and a 100%

CONTRACTOR'S AGREEMENT  
PAGE NO. 2

Payment Bond as well as all insurance requirements of the Contractor. Said bonds have already been posted by the Contractor pursuant to State law. The required proof of insurance certificates have been delivered to DFCM in accordance with the General Conditions before the execution of this Contractor's Agreement.

**ARTICLE 3. TIME OF COMPLETION AND DELAY REMEDY.** The Work shall be Substantially Complete by \_\_\_\_\_. Contractor agrees to pay liquidated damages in the amount of \$\_\_\_\_\_ per day for each day after expiration of the Contract Time until the Contractor achieves Substantial Completion in accordance with the Contract Documents, if Contractor's delay makes the damages applicable. The provision for liquidated damages is: (a) to compensate the DFCM for delay only; (b) is provided for herein because actual damages can not be readily ascertained at the time of execution of this Contractor's Agreement; (c) is not a penalty; and (d) shall not prevent the DFCM from maintaining Claims for other non-delay damages, such as costs to complete or remedy defective Work.

No action shall be maintained by the Contractor, including its or Subcontractor or suppliers at any tier, against the DFCM or State of Utah for damages or other claims due to losses attributable to hindrances or delays from any cause whatsoever, including acts and omissions of the DFCM or its officers, employees or agents, except as expressly provided in the General Conditions. The Contractor may receive a written extension of time, signed by the DFCM, in which to complete the Work under this Contractor's Agreement in accordance with the General Conditions.

**ARTICLE 4. CONTRACT DOCUMENTS.** The Contract Documents consist of this Contractor's Agreement, the Conditions of the Contract (DFCM General Conditions, Supplementary and other Conditions), the Drawings, Specifications, Addenda and Modifications. The Contract Documents shall also include the bidding documents, including the Invitation to Bid, Instructions to Bidders/ Proposers and the Bid/Proposal, to the extent not in conflict therewith and other documents and oral presentations that are documented as an attachment to the contract.

All such documents are hereby incorporated by reference herein. Any reference in this Contractor's Agreement to certain provisions of the Contract Documents shall in no way be construed as to lessen the importance or applicability of any other provisions of the Contract Documents.

**ARTICLE 5. PAYMENT.** The DFCM agrees to pay the Contractor from time to time as the Work progresses, but not more than once each month after the date of Notice to Proceed, and only upon Certificate of the A/E for Work performed during the preceding calendar month, ninety-five percent (95%) of the value of the labor performed and ninety-five percent (95%) of the value of materials furnished in place or on the site. The Contractor agrees to furnish to the DFCM invoices for materials purchased and on the site but not installed, for which the Contractor requests payment and agrees to

safeguard and protect such equipment or materials and is responsible for safekeeping thereof and if such be stolen, lost or destroyed, to replace same.

Such evidence of labor performed and materials furnished as the DFCM may reasonably require shall be supplied by the Contractor at the time of request for Certificate of Payment on account. Materials for which payment has been made cannot be removed from the job site without DFCM's written approval. Five percent (5%) of the earned amount shall be retained from each monthly payment. The retainage, including any additional retainage imposed and the release of any retainage, shall be in accordance with UCA 13-8-5 as amended. Contractor shall also comply with the requirements of UCA 13-8-5, including restrictions of retainage regarding subcontractors and the distribution of interest earned on the retention proceeds. The DFCM shall not be responsible for enforcing the Contractor's obligations under State law in fulfilling the retention law requirements with subcontractors at any tier.

**ARTICLE 6. INDEBTEDNESS.** Before final payment is made, the Contractor must submit evidence satisfactory to the DFCM that all payrolls, materials bills, subcontracts at any tier and outstanding indebtedness in connection with the Work have been properly paid. Final Payment will be made after receipt of said evidence, final acceptance of the Work by the DFCM as well as compliance with the applicable provisions of the General Conditions.

Contractor shall respond immediately to any inquiry in writing by DFCM as to any concern of financial responsibility and DFCM reserves the right to request any waivers, releases or bonds from Contractor in regard to any rights of Subcontractors (including suppliers) at any tier or any third parties prior to any payment by DFCM to Contractor.

**ARTICLE 7. ADDITIONAL WORK.** It is understood and agreed by the parties hereto that no money will be paid to the Contractor for additional labor or materials furnished unless a new contract in writing or a Modification hereof in accordance with the General Conditions and the Contract Documents for such additional labor or materials has been executed. The DFCM specifically reserves the right to modify or amend this Contractor's Agreement and the total sum due hereunder either by enlarging or restricting the scope of the Work.

**ARTICLE 8. INSPECTIONS.** The Work shall be inspected for acceptance in accordance with the General Conditions.

**ARTICLE 9. DISPUTES.** Any dispute, PRE or Claim between the parties shall be subject to the provisions of Article 7 of the General Conditions. DFCM reserves all rights to pursue its rights and remedies as provided in the General Conditions.

**ARTICLE 10. TERMINATION, SUSPENSION OR ABANDONMENT.** This Contractor's Agreement may be terminated, suspended or abandoned in accordance with the General Conditions.

**ARTICLE 11. DFCM'S RIGHT TO WITHHOLD CERTAIN AMOUNT AND MAKE USE THEREOF.** The DFCM may withhold from payment to the Contractor such amount as, in DFCM's judgment, may be necessary to pay just claims against the Contractor or Subcontractor at any tier for labor and services rendered and materials furnished in and about the Work. The DFCM may apply such withheld amounts for the payment of such claims in DFCM's discretion. In so doing, the DFCM shall be deemed the agent of Contractor and payment so made by the DFCM shall be considered as payment made under this Contractor's Agreement by the DFCM to the Contractor. DFCM shall not be liable to the Contractor for any such payment made in good faith. Such withholdings and payments may be made without prior approval of the Contractor and may be also be prior to any determination as a result of any dispute, PRE, Claim or litigation.

**ARTICLE 12. INDEMNIFICATION.** The Contractor shall comply with the indemnification provisions of the General Conditions.

**ARTICLE 13. SUCCESSORS AND ASSIGNMENT OF CONTRACT.** The DFCM and Contractor, respectively bind themselves, their partners, successors, assigns and legal representatives to the other party to this Agreement, and to partners, successors, assigns and legal representatives of such other party with respect to all covenants, provisions, rights and responsibilities of this Contractor's Agreement. The Contractor shall not assign this Contractor's Agreement without the prior written consent of the DFCM, nor shall the Contractor assign any moneys due or to become due as well as any rights under this Contractor's Agreement, without prior written consent of the DFCM.

**ARTICLE 14. RELATIONSHIP OF THE PARTIES.** The Contractor accepts the relationship of trust and confidence established by this Contractor's Agreement and covenants with the DFCM to cooperate with the DFCM and A/E and use the Contractor's best skill, efforts and judgment in furthering the interest of the DFCM; to furnish efficient business administration and supervision; to make best efforts to furnish at all times an adequate supply of workers and materials; and to perform the Work in the best and most expeditious and economic manner consistent with the interests of the DFCM.

**ARTICLE 15. AUTHORITY TO EXECUTE AND PERFORM AGREEMENT.** Contractor and DFCM each represent that the execution of this Contractor's Agreement and the performance thereunder is within their respective duly authorized powers.

**ARTICLE 16. ATTORNEY FEES AND COSTS.** Except as otherwise provided in the dispute resolution provisions of the General Conditions, the prevailing party shall be entitled to reasonable attorney fees and costs incurred in any action in the District Court and/or appellate body to enforce this Contractor's Agreement or recover damages or any other action as a result of a breach thereof.



**PERFORMANCE BOND**

(Title 63, Chapter 56, U. C. A. 1953, as Amended)

That \_\_\_\_\_ hereinafter referred to as the "Principal" and \_\_\_\_\_, a corporation organized and existing under the laws of the State of \_\_\_\_\_, with its principal office in the City of \_\_\_\_\_ and authorized to transact business in this State and U. S. Department of the Treasury Listed (Circular 570, Companies Holding Certificates of Authority as Acceptable Securities on Federal Bonds and as Acceptable Reinsuring Companies); hereinafter referred to as the "Surety," are held and firmly bound unto the State of Utah, hereinafter referred to as the "Obligee," in the amount of \_\_\_\_\_ DOLLARS (\$) \_\_\_\_\_ for the payment whereof, the said Principal and Surety bind themselves and their heirs, administrators, executors, successors and assigns, jointly and severally, firmly by these presents.

**WHEREAS**, the Principal has entered into a certain written Contract with the Obligee, dated the \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_, to construct \_\_\_\_\_ in the County of \_\_\_\_\_, State of Utah, Project No. \_\_\_\_\_, for the approximate sum of \_\_\_\_\_ Dollars (\$ \_\_\_\_\_), which Contract is hereby incorporated by reference herein.

**NOW, THEREFORE**, the condition of this obligation is such that if the said Principal shall faithfully perform the Contract in accordance with the Contract Documents including, but not limited to, the Plans, Specifications and conditions thereof, the one year performance warranty, and the terms of the Contract as said Contract may be subject to Modifications or changes, then this obligation shall be void; otherwise it shall remain in full force and effect.

No right of action shall accrue on this bond to or for the use of any person or corporation other than the state named herein or the heirs, executors, administrators or successors of the Owner.

The parties agree that the dispute provisions provided in the Contract Documents apply and shall constitute the sole dispute procedures of the parties.

**PROVIDED, HOWEVER**, that this Bond is executed pursuant to the Provisions of Title 63, Chapter 56, Utah Code Annotated, 1953, as amended, and all liabilities on this Bond shall be determined in accordance with said provisions to the same extent as if it were copied at length herein.

**IN WITNESS WHEREOF**, the said Principal and Surety have signed and sealed this instrument this \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_.

**WITNESS OR ATTESTATION:**

\_\_\_\_\_

**PRINCIPAL:**

\_\_\_\_\_

By: \_\_\_\_\_ (Seal)

Title: \_\_\_\_\_

**WITNESS OR ATTESTATION:**

\_\_\_\_\_

**SURETY:**

\_\_\_\_\_

By: \_\_\_\_\_ (Seal)

Attorney-in-Fact

STATE OF \_\_\_\_\_ )  
 ) ss.  
COUNTY OF \_\_\_\_\_ )

On this \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_, personally appeared before me \_\_\_\_\_, whose identity is personally known to me or proved to me on the basis of satisfactory evidence, and who, being by me duly sworn, did say that he/she is the Attorney in-fact of the above-named Surety Company and that he/she is duly authorized to execute the same and has complied in all respects with the laws of Utah in reference to becoming sole surety upon bonds, undertakings and obligations, and that he/she acknowledged to me that as Attorney-in-fact executed the same.

Subscribed and sworn to before me this \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_.

My commission expires: \_\_\_\_\_

Resides at: \_\_\_\_\_

\_\_\_\_\_  
NOTARY PUBLIC

**Agency:** \_\_\_\_\_  
**Agent:** \_\_\_\_\_  
**Address:** \_\_\_\_\_  
**Phone:** \_\_\_\_\_

Approved As To Form: May 25, 2005  
By Alan S. Bachman, Asst Attorney General

**PAYMENT BOND**

(Title 63, Chapter 56, U. C. A. 1953, as Amended)

**KNOW ALL PERSONS BY THESE PRESENTS:**

That \_\_\_\_\_ hereinafter referred to as the "Principal," and \_\_\_\_\_, a corporation organized and existing under the laws of the State of \_\_\_\_\_ authorized to do business in this State and U. S. Department of the Treasury Listed (Circular 570, Companies Holding Certificates of Authority as Acceptable Securities on Federal Bonds and as Acceptable Reinsuring Companies); with its principal office in the City of \_\_\_\_\_, hereinafter referred to as the "Surety," are held and firmly bound unto the State of Utah hereinafter referred to as the "Obligee," in the amount of \_\_\_\_\_ Dollars (\$ \_\_\_\_\_) for the payment whereof, the said Principal and Surety bind themselves and their heirs, administrators, executors, successors and assigns, jointly and severally, firmly by these presents.

**WHEREAS**, the Principal has entered into a certain written Contract with the Obligee, dated the \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_, to construct \_\_\_\_\_ in the County of \_\_\_\_\_, State of Utah, Project No. \_\_\_\_\_ for the approximate sum of \_\_\_\_\_ Dollars (\$ \_\_\_\_\_), which contract is hereby incorporated by reference herein.

**NOW, THEREFORE**, the condition of this obligation is such that if the said Principal shall pay all claimants supplying labor or materials to Principal or Principal's Subcontractors in compliance with the provisions of Title 63, Chapter 56, of Utah Code Annotated, 1953, as amended, and in the prosecution of the Work provided for in said Contract, then, this obligation shall be void; otherwise it shall remain in full force and effect.

That said Surety to this Bond, for value received, hereby stipulates and agrees that no changes, extensions of time, alterations or additions to the terms of the Contract or to the Work to be performed thereunder, or the specifications or drawings accompanying same shall in any way affect its obligation on this Bond, and does hereby waive notice of any such changes, extensions of time, alterations or additions to the terms of the Contract or to the Work or to the specifications or drawings and agrees that they shall become part of the Contract Documents.

**PROVIDED, HOWEVER**, that this Bond is executed pursuant to the provisions of Title 63, Chapter 56, Utah Code Annotated, 1953, as amended, and all liabilities on this Bond shall be determined in accordance with said provisions to the same extent as if it were copied at length herein.

**IN WITNESS WHEREOF**, the said Principal and Surety have signed and sealed this instrument this \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_.

**WITNESS OR ATTESTATION:**

\_\_\_\_\_

**PRINCIPAL:**

\_\_\_\_\_

By: \_\_\_\_\_ (Seal)

Title: \_\_\_\_\_

**WITNESS OR ATTESTATION:**

\_\_\_\_\_

**SURETY:**

\_\_\_\_\_

By: \_\_\_\_\_ (Seal)  
Attorney-in-Fact

STATE OF \_\_\_\_\_ )  
 ) ss.  
COUNTY OF \_\_\_\_\_ )

On this \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_, personally appeared before me \_\_\_\_\_, whose identity is personally known to me or proved to me on the basis of satisfactory evidence, and who, being by me duly sworn, did say that he/she is the Attorney-in-fact of the above-named Surety Company, and that he/she is duly authorized to execute the same and has complied in all respects with the laws of Utah in reference to becoming sole surety upon bonds, undertakings and obligations, and that he/she acknowledged to me that as Attorney-in-fact executed the same.

Subscribed and sworn to before me this \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_.

My commission expires: \_\_\_\_\_  
Resides at: \_\_\_\_\_

NOTARY PUBLIC

**Agency:** \_\_\_\_\_  
**Agent:** \_\_\_\_\_  
**Address:** \_\_\_\_\_  
**Phone:** \_\_\_\_\_

Approved As To Form: May 25, 2005  
By Alan S. Bachman, Asst Attorney General



CERTIFICATE OF SUBSTANTIAL COMPLETION

PROJECT \_\_\_\_\_ PROJECT NO: \_\_\_\_\_

AGENCY/INSTITUTION \_\_\_\_\_

AREA ACCEPTED \_\_\_\_\_

The Work performed under the subject Contract has been reviewed on this date and found to be Substantially Completed as defined in the General Conditions; including that the construction is sufficiently completed in accordance with the Contract Documents, as modified by any change orders agreed to by the parties, so that the State of Utah can occupy the Project or specified area of the Project for the use for which it is intended.

The DFCM - (Owner) accepts the Project or specified area of the Project as Substantially Complete and will assume full possession of the Project or specified area of the Project at \_\_\_\_\_ (time) on \_\_\_\_\_ (date).

The DFCM accepts the Project for occupancy and agrees to assume full responsibility for maintenance and operation, including utilities and insurance, of the Project subject to the itemized responsibilities and/or exceptions noted below:

\_\_\_\_\_

The Owner acknowledges receipt of the following closeout and transition materials:

- As-built Drawings O & M Manuals Warranty Documents Completion of Training Requirements

A list of items to be completed or corrected (Punch List) is attached hereto. The failure to include an item on it does not alter the responsibility of the Contractor to complete all the Work in accordance with the Contract Documents, including authorized changes thereof. The amount of \_\_\_\_\_(Twice the value of the punch list work) shall be retained to assure the completion of the punch list work.

The Contractor shall complete or correct the Work on the list of (Punch List) items appended hereto within \_\_\_\_\_ calendar days from the above date of issuance of this Certificate. The amount withheld pending completion of the list of items noted and agreed to shall be: \$\_\_\_\_\_. If the list of items is not completed within the time allotted the Owner has the right to be compensated for the delays and/or complete the work with the help of independent contractor at the expense of the retained project funds. If the retained project funds are insufficient to cover the delay/completion damages, the Owner shall be promptly reimbursed for the balance of the funds needed to compensate the Owner.

\_\_\_\_\_ by: \_\_\_\_\_ (Signature) DATE

**General Contractor Performance Rating Form**

Project Name:		DFCM Project#	
Contractor:  (ABC Construction, John Doe, 111-111-1111)	A/E:  (ABC Architects, Jane Doe, 222-222-2222)	Original Contract Amount:	Final Contract Amount:
DFCM Project Manager:		Contract Date:	
Completion Date:		Date of Rating:	

Rating Guideline	QUALITY OF PRODUCT OR SERVICES	COST CONTROL	TIMELINESS OF PERFORMANCE	BUSINESS RELATIONS
<b>5-Exceptional</b>	Contractor has demonstrated an exceptional performance level in any of the above four categories that justifies adding a point to the score. Contractor performance clearly exceeds the performance levels described as "Very Good"			
<b>4-Very Good</b>	Contractor is in compliance with contract requirements and/or delivers quality product/service.	Contractor is effective in managing costs and submits current, accurate, and complete billings	Contractor is effective in meeting milestones and delivery schedule	Response to inquiries, technical/service/administrative issues is effective
<b>3-Satisfactory</b>	Minor inefficiencies/errors have been identified	Contractor is usually effective in managing cost	Contractor is usually effective in meeting milestones and delivery schedules	Response to inquires technical/service/administrative issues is somewhat effective
<b>2-Marginal</b>	Major problems have been encountered	Contractor is having major difficulty managing cost effectively	Contractor is having major difficulty meeting milestones and delivery schedule	Response to inquiries, technical/service/administrative issues is marginally effective
<b>1-Unsatisfactory</b>	Contractor is not in compliance and is jeopardizing achievement of contract objectives	Contractor is unable to manage costs effectively	Contractor delays are jeopardizing performance of contract objectives	Response to inquiries, technical/service/administrative issues is not effective

<b>1. Rate Contractors quality of workmanship, management of sub contractor performance, project cleanliness, organization and safety requirement.</b>	<b>Score</b>
<u>Agency Comments:</u>	
<u>A &amp; E Comments:</u>	
<u>DFCM Project Manager Comments:</u>	

<b>2. Rate Contractor administration of project costs, change orders and financial management of the project budget.</b>	<b>Score</b>
<u>Agency Comments:</u>	
<u>A &amp; E Comments:</u>	
<u>DFCM Project Manager Comments:</u>	

<b>3. Rate Contractor's performance and adherence to Project Schedule, delay procedures and requirements of substantial completion, inspection and punch-list performance.</b>	<b>Score</b>
<u>Agency Comments:</u>	
<u>A &amp; E Comments:</u>	
<u>DFCM Project Manager Comments:</u>	

<b>4. Evaluate performance of contractor management team including project manager, engineer and superintendent also include in the rating team's ability to work well with owner, user agency and consultants.</b>	<b>Score</b>
<u>Agency Comments:</u>	
<u>A &amp; E Comments:</u>	
<u>DFCM Project Manager Comments:</u>	

5. Rate success of Contractor's management plan, completion of the plans mitigation of project risks and performance of value engineering concepts.	Score
<u>Agency Comments:</u>	
<u>A &amp; E Comments:</u>	
<u>DFCM Project Manager Comments:</u>	

<b>Signed by:</b>	<b>Date:</b>	<b>Mean Score</b>
-------------------	--------------	-------------------

**Additional Comments:**

# **TECHNICAL SPECIFICATIONS**

FOR

BEAR LAKE BIG CREEK CAMPGROUND

---

ELECTRICAL UPGRADES  
DIVISION OF PARKS AND RECREATION  
DFCM #07333510

---

DOCUMENT 00010

TABLE OF CONTENTS

Section	Title
DIVISION 1 - GENERAL REQUIREMENTS	
01100	Summary of Work
01200	Price and Payment Procedures
01300	Submittals
01400	Quality Control
01500	Construction Facilities and Temporary Controls
01600	Material and Equipment
01700	Execution Requirements
DIVISION 2 - SITE CONSTRUCTION	
02055	Soils
02060	Aggregate
02230	Site Clearing
02311	Rough Grading
02324	Trenching
02721	Aggregate Base Course
02740	Asphaltic Concrete Paving
02923	Landscape Grading
02924	Seeding
DIVISION 16- ELECTRICAL	
16001	Electrical General Provisions
16050	Basic Materials and Methods
16070	Electrical Connections for Equipment
16110	Conduit Raceways
16120	Conductors and Cables
16160	Panelboards
16420	Service Entrance
16452	Grounding

END OF SECTION

SECTION 01100  
SUMMARY OF WORK

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. General Description of Work.
- B. Location
- C. Sequence of Work

1.2 GENERAL DESCRIPTION OF WORK

- A. The Bear Lake Big Creek Campground Electrical Upgrades project consists of the following WORK:

Installation of new power wiring and electrical services to serve 43 camp sites in the camp ground. This project also includes widening and lengthening the asphalt parking spaces at selected camp sites in the campground. Included in this work is the clearing and grubbing of existing surface materials, removal or re-location of some small trees, installation of imported sub base and base material and asphalt surface course. The approximate finished area of new asphalt is 7,300 square feet.

1.3 LOCATION

- A. The WORK is located at the Utah State Park Big Creek Campground next to Rendezvous Beach at the south end of Bear Lake.

1.4 SEQUENCE OF WORK

- A. Install new electrical conduits and wiring to camp sites
- B. Expand asphalt parking spaces for selected camp sites as indicated on the plans

PART 2 PRODUCTS

Not Used

PART 3 EXECUTION

Not Used

END OF SECTION

SECTION 01200

PRICE AND PAYMENT PROCEDURES

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Schedule of values.
- B. Applications for payment.
- C. Change procedures.
- D. Defect assessment.

1.2 RELATED SECTIONS

- A. Section 01300 - Submittals
- B. Section 01300 – Materials and Equipment

1.3 SCHEDULE OF VALUES

- A. Submit printed schedule on AIA Form G703 - Continuation Sheet for G702.
- B. Submit Schedule of Values in duplicate within 15 days after date of Owner-Contractor Agreement.
- C. Format: Utilize Table of Contents of this Project Manual. Identify each line item with number and title of major specification Section.
- D. Include in each line item, amount of Allowances specified in this section.
- E. Include within each line item, direct proportional amount of Contractor's overhead and profit.
- F. Revise schedule to list approved Change Orders, with each Application For Payment.

1.4 APPLICATIONS FOR PAYMENT

- A. Submit three copies of each application on AIA Form G702 - Application and Certificate for Payment and AIA G703 - Continuation Sheet for G702.
- B. Content and Format: Utilize Schedule of Values for listing items in Application for Payment.

- C. Submit updated construction schedule with each Application for Payment.
- D. Payment Period: Submit at intervals stipulated in the Agreement.
- E. Submit with transmittal letter as specified for Submittals in Section 01300.
- F. Substantiating Data: When Architect/Engineer requires substantiating information, submit data justifying dollar amounts in question. Include the following with Application for Payment:
  - 1. Construction progress schedules, revised and current as specified in Section 01300.

#### 1.5 CHANGE PROCEDURES

- A. Submittals: Submit name of individual authorized to receive change documents, and be responsible for informing others in Contractor's employ or Subcontractors of changes to the Work.
- B. The Architect/Engineer will advise of minor changes in the Work not involving adjustment to Contract Sum/Price or Contract Time by issuing supplemental instructions on DFCM Construction Change Directive Form.
- C. The Architect/Engineer may issue a Proposal Request including a detailed description of proposed change with supplementary or revised Drawings and specifications, a change in Contract Time for executing the change. Contractor will prepare and submit estimate within 10 days.
- D. Contractor may propose changes by submitting a request for change to Architect/Engineer, describing proposed change and its full effect on the Work. Include a statement describing reason for the change, and effect on Contract Sum/Price and Contract Time with full documentation and a statement describing effect on Work by separate or other Contractors. Document requested substitutions in accordance with Section 01600.
- E. Stipulated Sum/Price Change Order: Based on Proposal Request and Contractor's fixed price quotation.
- F. Unit Price Change Order: For contract unit prices and quantities, the Change Order will be executed on fixed unit price basis. For unit costs or quantities of units of work which are not pre-determined, execute Work under Construction Change Directive. Changes in Contract Sum/Price or Contract Time will be computed as specified for Time and Material Change Order.
- G. Construction Change Directive: Architect/Engineer may issue directive, on DFCM Form signed by Owner, instructing Contractor to proceed with change in the Work, for subsequent inclusion in a Change Order. Document will describe changes in the Work, and designate method of determining any change in Contract Sum/Price or Contract Time. Promptly execute change.

- H. Time and Material Change Order: Submit itemized account and supporting data after completion of change, within time limits indicated in Conditions of the Contract. Architect/Engineer will determine change allowable in Contract Sum/Price and Contract Time as provided in Contract Documents.
- I. Maintain detailed records of work done on Time and Material basis. Provide full information required for evaluation of proposed changes, and to substantiate costs for changes in the Work.
- J. Document each quotation for change in cost or time with sufficient data to allow evaluation of quotation.
- K. Change Order Forms: DFCM Change Order Form
- L. Execution of Change Orders: Architect/Engineer will issue Change Orders for signatures of parties as provided in Conditions of the Contract.
- M. Correlation Of Contractor Submittals:
  - 1. Promptly revise Schedule of Values and Application for Payment forms to record each authorized Change Order as separate line item and adjust Contract Sum/Price.
  - 2. Promptly revise progress schedules to reflect change in Contract Time, revise sub-schedules to adjust times for other items of work affected by the change, and resubmit.
  - 3. Promptly enter changes in Project Record Documents.

#### 1.6 DEFECT ASSESSMENT

- A. Replace the Work, or portions of the Work, not conforming to specified requirements.
- B. If, in the opinion of the Architect/Engineer, it is not practical to remove and replace the Work, the Architect/Engineer will direct appropriate remedy or adjust payment.
- C. The defective Work may remain, but unit sum/price will be adjusted to new sum/price at discretion of Architect/Engineer.
- D. Defective Work will be partially repaired to instructions of Architect/Engineer, and unit sum/price will be adjusted to new sum/price at discretion of Architect/Engineer and Owner.
- E. Individual specification sections may modify these options or may identify specific formula or percentage sum/price reduction.

- F. Authority of Architect/Engineer to assess defects and identify payment adjustments, is final.
- G. Non-Payment For Rejected Products: Payment will not be made for rejected products for any of the following:
  - 1. Products wasted or disposed of in a manner that is not acceptable.
  - 2. Products determined as unacceptable before or after placement.
  - 3. Products not completely unloaded from transporting vehicle.
  - 4. Products placed beyond lines and levels of required Work.
  - 5. Products remaining on hand after completion of the Work.
  - 6. Loading, hauling, and disposing of rejected products.

PART 2 PRODUCTS

Not Used.

PART 3 EXECUTION

Not Used.

END OF SECTION

## SECTION 01300

### SUBMITTALS

#### PART 1 GENERAL

##### 1.1 SECTION INCLUDES

- A. Submittal procedures.
- B. Construction progress schedules.
- C. Proposed products list.
- D. Shop drawings.
- E. Product data.
- F. Manufacturers' instructions.
- G. Manufacturers' certificates.
- H. Construction photographs.

##### 1.2 RELATED SECTIONS

- A. Section 01400 - Quality Control.
- B. Section 01700 - Contract Closeout.

##### 1.3 SUBMITTAL PROCEDURES

- A. Transmit each submittal with Engineer accepted form.
- B. Sequentially number the transmittal forms. Re-submittals to have original number with an alphabetic suffix.
- C. Identify Project, Contractor, Subcontractor or supplier; pertinent Drawing sheet and detail name or number(s), and specification Section number, as appropriate.
- D. Apply Contractor's stamp, signed or initialed certifying that review, verification of Products required, field dimensions, adjacent construction Work, and coordination of information, is in accordance with the requirements of the Work and Contract Documents.

- E. Schedule submittals to expedite the Project, and deliver to Engineer at 1047 S 100 W Suite 180, Logan, Utah 84321. Coordinate submission of related items.
- F. Identify variations from Contract Documents and Product or system limitations which may be detrimental to successful performance of the completed Work.
- G. Provide space for Contractor and Engineer review stamps.
- H. Revise and resubmit submittals as required, identify all changes made since previous submittal.
- I. Distribute copies of reviewed submittals to affected parties. Instruct parties to promptly report any inability to comply with provisions.

#### 1.4 CONSTRUCTION PROGRESS SCHEDULES

- A. Submit initial progress schedule in duplicate within 10 days after date established in Notice to Proceed for Engineer review. Submit progress schedule no later than pre-construction conference.
- B. Revise and resubmit as required.
- C. Submit revised schedules with each Application for Payment, identifying changes since previous version.
- D. Show complete sequence of construction by activity, identifying Work of separate stages and other logically grouped activities. Indicate the early and late start, early and late finish, float dates, and duration.
- E. Indicate estimated percentage of completion for each item of Work at each submission.
- F. Indicate submittal dates required for shop drawings, product data, samples, and product delivery dates.

#### 1.5 PROPOSED PRODUCTS LIST

- A. Within 15 days after date of Owner-Contractor Agreement, submit complete list of major products proposed for use, with name of manufacturer, trade name, and model number of each product.
- B. For products specified only by reference standards, give manufacturer, trade name, model or catalog designation, and reference standards.

## 1.6 SHOP DRAWINGS

- A. Submit the number of opaque reproductions which Contractor requires, plus five (5) copies which will be retained by Engineer.
- B. Except as may otherwise be indicated herein, the ENGINEER will return prints of each submittal to the CONTRACTOR with its comments noted thereon, within 15 calendar days following their receipt by the ENGINEER. It is considered reasonable that the contractor shall make a complete and acceptable submittal to the engineer by the second submission of a submittal item. The STATE OF UTAH reserves the right to withhold monies due to the contractor to cover additional costs of the engineers for review beyond the second submittal. The engineer's maximum review period for each submittal, including all resubmittals, will be 15 days per submittal. In other words, the maximum review period for that submittal could be 45 days.
- C. After review, distribute in accordance with Article on Procedures above and for Record Documents described in the General Conditions.
- D. Fabrication of an item shall be commenced only after the engineer has reviewed the pertinent submittals and returned approved copies to the contractor.

## 1.7 PRODUCT DATA

- A. Submit the number of copies which the Contractor requires, plus three (3) copies which will be retained by the Engineer.
- B. Mark each copy to identify applicable products, models, options, and other data. Supplement manufacturers' standard data to provide information unique to this Project.
- C. Indicate Product utility and electrical characteristics, utility connection requirements, and location of utility outlets for service for functional equipment and appliances.
- D. After review, distribute in accordance with Article on Procedures above and provide copies for Record Documents described in the General Conditions.

## 1.8 MANUFACTURERS' INSTRUCTIONS

- A. When specified in individual specification Sections, submit manufacturers' printed instructions for delivery, storage, assembly, installation, start-up, adjusting, and finishing, in quantities specified for Product Data.
- B. Indicate special procedures, perimeter conditions requiring special attention, and special environmental criteria required for application or installation.

- C. Identify conflicts between manufacturers' instructions and Contract Documents.

#### 1.9 MANUFACTURER'S CERTIFICATES

- A. When specified in individual specification Sections, submit manufacturer's certificate to Engineer for review, in quantities specified for Product Data.
- B. Indicate material or product conforms to or exceeds specified requirements. Submit supporting reference date, affidavits, and certifications as appropriate.
- C. Certificates may be recent or previous test results on material or Product, but must be acceptable to Engineer.

#### 1.10 CONSTRUCTION PHOTOGRAPHS

- A. Recommended for evaluation of the existing facility after completion of the project.

#### PART 2 PRODUCTS

Not Used

#### PART 3 EXECUTION

Not used

END OF SECTION

SECTION 01400  
QUALITY CONTROL

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Quality assurance/control of installation.
- B. References.
- C. Construction observation and testing laboratory services.
- D. Manufacturers' field services and reports.

1.2 RELATED SECTIONS

- A. Section 01300 - Submittals.
- B. Section 01600 - Material and Equipment.

1.3 QUALITY ASSURANCE/CONTROL OF INSTALLATION

- A. Monitor quality control over suppliers, manufacturers, Products, services, site conditions, and workmanship, to produce Work of specified quality.
- B. Comply fully with manufacturers' instructions, including each step in sequence.
- C. Should manufacturers' instructions conflict with Contract Documents, request clarification from the Engineer.
- D. Comply with specified standards as a minimum quality for the Work except when more stringent tolerances, codes, or specified requirements indicate higher standards or more precise workmanship.
- E. Perform work by persons qualified to produce workmanship of specified quality.
- F. Secure Products in place with positive anchorage devices designed and sized to withstand stresses, vibration, physical distortion or disfigurement.

1.4 REFERENCES

- A. Conform to reference standard by date of issue current on date of Contract Documents.

- B. Should specified reference standards conflict with Contract Documents, request clarification from Engineer.
- C. The contractual relationship of the parties to the Contract shall not be altered from the Contract Documents by mention or inference otherwise in any reference document.

#### 1.5 CONSTRUCTION OBSERVATION AND TESTING LABORATORY SERVICES

- A. Owner will appoint and employ for services of Engineer to perform Construction Observation and testing.
- B. The Engineer will observe all tests run by the Contractor in the field.
- C. The Contractor shall be responsible for providing the equipment and manpower to assist the Engineer in taking tests.
- D. The Contractor shall provide the equipment and manpower to conduct all tests as required in the specifications.
- E. The Contractor shall notify the Engineer of the time in which tests are to be run forty-eight (48) hours prior to testing.
- F. Reports will be submitted by the Engineer, to the Contractor indicating observations and results of tests and indicating compliance or non-compliance with Contract Documents.
- G. Cooperate with Engineer; furnish samples of materials, design mix, equipment, tools, storage and assistance as requested.
  - 1. Notify Engineer 48 hours prior to expected time for operations requiring services.
  - 2. Make arrangements with Engineer and pay for additional samples and tests required for Contractor's use.
- H. Retesting required because of non-conformance to specified requirements shall be performed by the Engineer. Payment for retesting will be charged to the Contractor by deducting inspection or testing charges from the Contract Sum/Price.

#### 1.6 MANUFACTURERS' FIELD SERVICES AND REPORTS

- A. When specified in individual specification Sections, require material or Product suppliers or manufacturers to provide qualified staff personnel to observe site conditions, conditions of surfaces and installation, quality of workmanship, start-up of equipment, test, adjust, and balance of equipment as applicable, and to initiate instructions when necessary.

- B. Individuals to report observations and site decisions or instructions given to applicators or installers that are supplemental or contrary to manufacturers' written instructions.
- C. Submit report in duplicate within 15 days of observation to Engineer for review.

#### 1.7 PROJECT LIMITS

- A. Confine all equipment, tools, and materials to the easements and project sites shown on the plans. Activities and staging are limited to the unimproved site only. Access the site through State of Utah accesses only.

#### PART 2 PRODUCTS

Not Used

#### PART 3 EXECUTION

##### 3.1 INSTALLATION

- A. The contractor shall inspect material or equipment upon the arrival on the job site and immediately prior to installation and reject damaged and defective items.
- B. The contractor shall verify measurements and dimensions of the work as an integral step of starting each installation.
- C. Where installations include manufactured products the contractor shall comply with manufacturer applicable instruction and recommendation for installation, to whatever extent these are more explicit or more stringent than applicable requirement indicated in the Contract Documents.

END OF SECTION

## SECTION 01500

### CONSTRUCTION FACILITIES AND TEMPORARY CONTROLS

#### PART 1 GENERAL

##### 1.1 TEMPORARY SANITARY FACILITIES

- A. Provide temporary facilities on site as necessary.

##### 1.2 TEMPORARY ELECTRICITY

- A. Provide, maintain and pay for temporary electricity as needed for construction. Coordinate amperage and voltage to ensure adequacy for construction.

##### 1.3 BARRIERS

- A. Provide barriers to prevent unauthorized entry to construction areas, to allow for Owner's use of site, to protect public safety, and to protect existing facilities and adjacent properties from damage from construction operations.
- B. Provide protection for plant life designated to remain. Replace damaged plant life.
- C. Protect non-owned vehicular traffic, stored materials, site and structures from damage.

##### 1.4 WATER CONTROL

- A. Grade site to drain. Maintain excavations free of water. Provide, operate, and maintain pumping equipment as needed.
- B. Protect site from puddling or running water. Provide water barriers as required to protect site from soil erosion and puddling.

##### 1.5 DUST CONTROL

- A. This item shall consist of furnishing and applying POTABLE water required in construction and for dust control, in accordance with the requirements of these specifications.
- B. Water, when required, shall be applied at the locations and in the amounts required to properly compact the work. An adequate water supply shall be provided by the Contractor. The equipment used for watering shall be of ample capacity and of such

design as to assure uniform application of water in the amounts required.

- C. If required, watering shall be done at night or at other times when evaporation loss will be at a minimum.
- D. In watering of subgrades, the Engineer may direct the Contractor to apply water in such quantities that the subgrade shall be compacted at a moisture content in excess of "optimum moisture." In no case will the Contractor be required to apply water in excess of three percent (3%) of optimum moisture.
- E. The Contractor shall also apply water during the course of the work to control dust, maintaining all embankment and base courses in a damp condition.
- F. The Contractor shall provide sufficient equipment to apply water as directed for controlling dust caused by construction activities. If dusty conditions continue to exist due to insufficient or inadequate watering practices or lack of watering equipment, it shall cause the closing down of those operations affected until remedied. Watering shall be done on Saturdays, Sundays, and Holidays at the same frequency and amounts as specified for work days at the Contractor's expense.
- G. Watering equipment shall consist of water-tight tanks mounted on trucks, adequately powered, and capable of applying water as required. The water shall be applied under pressure from the tank through a spray apparatus as directed. The spray apparatus shall be equipped as to provide uniform, unbroken spread of water over the surface being watered. A suitable device for positive shut-off and for regulating the flow of water shall be located so as to permit positive drive control from the cab.

#### 1.6 EROSION AND SEDIMENT CONTROL

- A. Plan and execute construction by methods to control surface drainage from cuts and fills, from borrow and waste disposal areas. Prevent erosion and sedimentation.
- B. Minimize amount of bare soil exposed at one time.
- C. Provide temporary measures such as berms, dikes, and drains, to prevent water flow.
- D. Construct fill and waste areas by selective placement to avoid erosion of surface silts or clays.
- E. Periodically inspect earthwork to detect evidence of erosion and sedimentation, promptly apply corrective measures.

## 1.7 POLLUTION CONTROL

- A. Provide methods, means, and facilities to prevent contamination of soil, water, and atmosphere from discharge of noxious, toxic substances, and pollutants produced by construction operations.
- B. Equipment and fuel storage shall be kept secured. Waste oil and waste fluids shall not be stored or changed at any construction site.

## 1.8 SECURITY

- A. Provide security and facilities to protect work from unauthorized entry, vandalism or theft.

## 1.9 NOISE CONTROL

- A. Construction involving noisy operations, including starting and warming up of equipment, shall be restricted to the hours between 7:00 a.m. and 7:00 p.m. on weekdays. Noisy operations shall be scheduled to minimize their duration and to ensure their completion by 7:00 p.m.
- B. Notification of special circumstances or emergency conditions that require work beyond the hours specified above shall be provided as follows:
  - 1. The Contractor shall notify the Engineer 48 hours in advance of any proposed extended work hours for preauthorization. Notification shall include a written request for authorization to perform work specified and the circumstances that warrant this request. This notification shall include any additional measures to mitigate noise generated by this construction activity if deemed necessary by the Engineer.
  - 2. If an emergency situation occurs that warrants extended hours, the Contractor shall notify the Engineer immediately upon determining the need for this work.

## 1.10 TREE AND PLANT PROTECTION

- A. **CULTIVATED AREAS AND OTHER SURFACE IMPROVEMENTS:** All landscaped areas and other surface improvements which are damaged by actions of the Contractor shall be restored to a condition equal to or better than it was prior to construction. Areas shall not be cleared until related construction activities require the work.

#### 1.11 PROTECTION OF INSTALLED WORK

- A. Protect installed Work and provide special protection where specified in individual specification Sections.
- B. Provide temporary and removable protection for installed Products. Control activity in immediate work area to minimize damage.

#### 1.12 ACCESS ROADS

- A. Construct and maintain temporary roads accessing public thoroughfares to serve construction area.
- B. Extend and relocate as Work progress requires. Provide detours necessary for impeded traffic flow in excess of two hours.
- C. Provide and maintain access to fire hydrants, free of obstructions.
- D. Provide and maintain access for emergency vehicles.
- E. Provide means of removing mud from vehicle wheels before entering streets or adjacent parking areas.

#### 1.13 PARKING

- A. Do not allow construction personnel to park in any way which may affect the access of emergency vehicles or owner personnel.
- B. Arrange for temporary surface parking to accommodate construction personnel.
- C. When site space is not adequate, provide additional off-site parking.

#### 1.14 PROGRESS CLEANING

- A. Maintain areas free of waste materials, debris, and rubbish. Maintain site in a clean and orderly condition.
- B. Remove waste materials, debris, and rubbish from site periodically and dispose off-site in approved solid waste facilities at no additional cost to owner.
- B. Provide necessary containment and clean-up of all hazardous/dangerous materials on-site that result from Contractor's actions.

- C. Dispose of all hazardous/dangerous waste in approved hazardous waste facilities that result from Contractor's actions.

#### 1.15 REMOVAL OF UTILITIES, FACILITIES, AND CONTROLS

- A. Remove temporary above grade or buried utilities, equipment, facilities, materials, prior to Substantial Completion.
- B. Clean and repair damage caused by installation or use of temporary work.
- C. Restore existing facilities used during construction to original condition. Restore permanent facilities used during construction to specified condition.

#### PART 2 PRODUCTS

Not Used

#### PART 3 EXECUTION

Not Used

END OF SECTION

SECTION 01600  
MATERIAL AND EQUIPMENT

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Products
- B. Product Delivery
- C. Transportation and Handling
- D. Storage and protection
- E. Product options
- F. Proposed Substitutions or "or equal" Item
- G. Owner furnished equipment

1.2 PRODUCTS

- A. Products: Means new material, machinery, components, equipment, fixtures, and systems forming the Work. Does not include machinery and equipment used for preparation, fabrication, conveying and erection of the Work. Products may also include existing materials or components required for reuse.
- B. Do not use materials and equipment removed from existing premises, except as specifically permitted by the Contract Documents.
- C. Provide interchangeable components of the same manufacturer, or similar components where more than one choice is available.

1.3 PRODUCT DELIVERY

- A. STATE OF UTAH will not accept any deliveries addressed to CONTRACTOR or its Subcontractors.

1.4 TRANSPORTATION AND HANDLING

- A. Transport and handle products in accordance with manufacturer's instructions and deliver to project site in undamaged condition in manufacturer's unopened

containers and packaging.

- B. Promptly review shipments to assure that products comply with requirements, quantities are correct, and products are undamaged. Replace damaged products at no additional cost to OWNER.
- C. Provide equipment and personnel to handle products by methods to prevent soiling, disfigurement, or damage.
- D. The contractor shall provide additional protection during handling to prevent marring and otherwise damaging product, packaging and surrounding surfaces.

#### 1.5 STORAGE AND PROTECTION

- A. Store and protect products in accordance with manufacturer's instructions, with seals and labels intact and legible. Store sensitive products in weather-tight, climate controlled enclosures.
- B. For exterior storage of fabricated products, place on sloped supports, above ground.
- C. Provide off-site storage and protection when site does not permit on-site storage or protection.
- D. Cover products subject to deterioration with impervious sheet covering. Provide ventilation to avoid condensation.
- E. Store loose granular materials on solid flat surfaces in a well-drained area. Prevent mixing with foreign matter.
- F. Provide equipment and personnel to store products by methods to prevent soiling, disfigurement, or damage.
- G. Arrange storage of products to permit access for review. Periodically review to assure products are undamaged and are maintained under specified conditions.

#### 1.6 PRODUCT OPTIONS

- A. Products Specified by Reference Standards or by Description Only: Any product meeting those standards or description.
- B. Products Specified by Naming One or More Manufacturers with a Provision for Substitutions: Submit a request for substitution for any manufacturer not named.

## 1.7 PROPOSED SUBSTITUTIONS OR "OR EQUAL" ITEM

- A. Whenever materials or equipment are indicated in the Contract Documents by using the name of a proprietary item or the name of a particular supplier, the naming of the item is intended to establish the type, function, and quality required. If the name is followed by the words "or equal" indicating that a substitution is permitted, materials or equipment of other suppliers may be accepted if sufficient information is submitted by the CONTRACTOR to allow the ENGINEER to determine that the material or equipment proposed is equivalent or equal to that named, subject to the following requirements:
1. The burden of proof as to the type, function, and quality of any such substitution product, material or equipment shall be upon the CONTRACTOR
  2. The ENGINEER will be the sole judge as to the type, function, and quality of any such substitution and the ENGINEER's decision shall be final.
  3. The ENGINEER may require the CONTRACTOR to furnish additional data about the proposed substitution.
  4. The STATE OF UTAH may require the CONTRACTOR to furnish a special performance guarantee or other surety with respect to any substitution.
  5. Acceptance by the ENGINEER of a substitution item proposed by the CONTRACTOR shall not relieve the CONTRACTOR of the responsibility for full compliance with the Contract Documents and for adequacy of the substitution.
  6. The CONTRACTOR shall be responsible for resultant changes which the accepted substitution requires in the CONTRACTOR'S WORK, the WORK of its subcontractor and of other contractors.
- B. The procedure for review by the ENGINEER will include the following:
1. If the CONTRACTOR wishes to provide a substitution item, the CONTRACTOR shall make written application to the ENGINEER on the "Substitution Request Form."
  2. Unless otherwise provided by law or authorized in writing by the ENGINEER, the "Substitution Request Form(s)" shall be within the 30 day period after award of the Contract.
  3. Wherever a proposed substitution item has not been submitted within said 30-

day period, or wherever the submission of a proposed substitution material or equipment has been judged to be unacceptable by the ENGINEER, the CONTRACTOR shall provide the material or equipment indicated in the Contract Documents.

4. The CONTRACTOR shall certify that the proposed will perform adequately the functions and achieve the results called for by the general design, and be similar and of equal substance to that indicated, and be suited to the same use as that specified.
  5. The ENGINEER will evaluate each proposed substitution within a reasonable period of time.
  6. As applicable, no shop drawing submittals shall be made for a substitution item nor shall any substitution item be ordered, installed, or utilized with out the ENGINEER's prior written acceptance of the CONTRACTOR's "Substitution Request Form."
  7. The ENGINEER will record the time required by the ENGINEER in evaluating substitutions proposed by the CONTRACTOR and in making changes by the CONTRACTOR in the Contract Documents occasioned thereby.
- C. The CONTRACTOR's application using the "Substitution Request Form" shall contain the following statements and information which shall be considered by the ENGINEER in evaluating the proposed substitution:
1. The evaluation and acceptance of the proposed substitution will not prejudice the CONTRACTOR's achievement of substantial completion on time.
  2. Whether or not acceptance of the substitution for use in the WORK will require a change in any of the Contract Documents to adopt the design to the proposed substitution.
  3. Whether or not incorporation or use of the substitution in connection with the WORK is subject to payment of any license fee or royalty.
  4. All Variations of the proposed substitution from the items originally specified will be identified.
  5. Available maintenance, repair, and replacement services will be indicated. The manufacturer shall have a local service agency (within 100 miles of the site) which maintains properly trained personnel and adequate spare parts and is able to respond and complete repairs within 24 hours.

6. Itemized estimate of all costs that will result directly or indirectly from acceptance of such substitution, including cost of redesign and claims of other contractors affected by the resulting change.
- D. Without any increase in cost to the STATE OF UTAH, the CONTRACTOR shall be responsible for and pay all costs in connection with proposed substitutions and of inspections and testing of equipment or materials submitted for review prior to the CONTRACTOR's purchase thereof for incorporation in the WORK, whether or not the ENGINEER accepts the proposed equipment or material. The CONTRACTOR shall reimburse the STATE OF UTAH for the charges of the ENGINEER for evaluating each proposed substitution.

1.8 OWNER FURNISHED EQUIPMENT

- A. No owner furnished equipment will be used on this project.

PART 2 PRODUCTS

Not Used

PART 3 EXECUTION

Not Used

END OF SECTION

SECTION 01700  
EXECUTION REQUIREMENTS

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Closeout procedures.
- B. Final cleaning.
- C. Starting of systems.
- D. Demonstration and instructions.
- E. Protecting installed construction.
- F. Project record documents.
- G. Operation and maintenance data.
- H. Manual for materials and finishes.
- I. Manual for equipment and systems.
- J. Spare parts and maintenance products.
- K. Product warranties and product bonds.

1.2 CLOSEOUT PROCEDURES

- A. Submit written certification that Contract Documents have been reviewed, Work has been inspected, and that Work is complete in accordance with Contract Documents and ready for Architect/Engineer's review.
- B. Provide submittals to Architect/Engineer required by authorities having jurisdiction.
- C. Submit final Application for Payment identifying total adjusted Contract Sum, previous payments, and sum remaining due.
- D. Owner will occupy all of the site as specified in Section 01100.

### 1.3 FINAL CLEANING

- A. Execute final cleaning prior to final project assessment.
- B. Clean interior and exterior glass, surfaces exposed to view; remove temporary labels, stains and foreign substances, polish transparent and glossy surfaces.
- C. Clean equipment and fixtures to sanitary condition with cleaning materials appropriate to surface and material being cleaned.
- D. Clean filters of operating equipment.
- E. Clean debris from roofs, gutters, downspouts, and drainage systems.
- F. Clean site; sweep paved areas, rake clean landscaped surfaces.
- G. Remove waste and surplus materials, rubbish, and construction facilities from site.

### 1.4 STARTING OF SYSTEMS

- A. Coordinate schedule for start-up of various equipment and systems.
- B. Notify Architect/Engineer seven days prior to start-up of each item.
- C. Verify each piece of equipment or system has been checked for proper lubrication, drive rotation, belt tension, control sequence, and for conditions which may cause damage.
- D. Verify tests, meter readings, and specified electrical characteristics agree with those required by equipment or system manufacturer.
- E. Verify wiring and support components for equipment are complete and tested.
- F. Execute start-up under supervision of applicable manufacturer's representative and / or Contractors' personnel in accordance with manufacturers' instructions.
- G. When specified in individual specification Sections, require manufacturer to provide authorized representative to be present at site to inspect, check, and approve equipment or system installation prior to start-up, and to supervise placing equipment or system in operation.
- H. Submit a written report in accordance with Section 01300 that equipment or system has been properly installed and is functioning correctly.

## 1.5 DEMONSTRATION AND INSTRUCTIONS

- A. Demonstrate operation and maintenance of products to Owner's personnel one week prior to date of Substantial Completion.
- B. Utilize operation and maintenance manuals as basis for instruction. Review contents of manual with Owner's personnel in detail to explain all aspects of operation and maintenance.
- C. Demonstrate start-up, operation, control, adjustment, trouble-shooting, servicing, maintenance, and shutdown of each item of equipment at agreed time, at equipment location.
- D. Prepare and insert additional data in operations and maintenance manuals when need for additional data becomes apparent during instruction.
- E. Required instruction time for each item of equipment and system is specified in individual sections.

## 1.6 PROTECTING INSTALLED CONSTRUCTION

- A. Protect installed Work and provide special protection where specified in individual specification sections.
- B. Provide temporary and removable protection for installed products. Control activity in immediate work area to prevent damage.
- C. Provide protective coverings at walls, projections, jambs, sills, and soffits of openings.
- D. Protect finished floors, stairs, and other surfaces from traffic, dirt, wear, damage, or movement of heavy objects, by protecting with durable sheet materials.
- E. Prohibit traffic or storage upon waterproofed or roofed surfaces. When traffic or activity is necessary, obtain recommendations for protection from waterproofing or roofing material manufacturer.
- F. Prohibit traffic from landscaped areas. Unless areas are designated access locations.

## 1.7 PROJECT RECORD DOCUMENTS

- A. Maintain on site one set of the following record documents; record actual revisions to the Work:
  - 1. Drawings.
  - 2. Specifications.
  - 3. Addenda.

4. Change Orders and other modifications to the Contract.
  5. Reviewed Shop Drawings, Product Data, and Samples.
  6. Manufacturer's instruction for assembly, installation, and adjusting.
- B. Ensure entries are complete and accurate, enabling future reference by Owner.
- C. Store record documents separate from documents used for construction.
- D. Record information concurrent with construction progress, not less than weekly.
- E. Specifications: Legibly mark and record at each product section description of actual products installed, including the following:
1. Manufacturer's name and product model and number.
  2. Product substitutions or alternates utilized.
  3. Changes made by Addenda and modifications.
- F. Record Drawings: Legibly mark each item to record actual construction including:
1. Measured depths of foundations in relation to finish floor datum.
  2. Measured horizontal and vertical locations of underground utilities and appurtenances, referenced to permanent surface improvements.
  3. Measured locations of internal utilities and appurtenances concealed in construction, referenced to visible and accessible features of the Work.
  4. Field changes of dimension and detail.
  5. Details not on original Contract drawings.
- G. Submit documents to Architect/Engineer with claim for final Application for Payment.

#### 1.8 OPERATION AND MAINTENANCE DATA

- A. Submit data bound in 8-1/2 x 11 inch (A4) text pages, three D side ring binders with durable plastic covers.
- B. Prepare binder cover with printed title "OPERATION AND MAINTENANCE INSTRUCTIONS", title of project, and subject matter of binder when multiple binders are required.
- C. Internally subdivide binder contents with permanent page dividers, logically organized as described below; with tab titling clearly printed under reinforced laminated plastic tabs.
- D. Drawings: Provide with reinforced punched binder tab. Bind in with text; fold larger drawings to size of text pages.
- E. Contents: Prepare Table of Contents for each volume, with each product or system description identified, typed on white paper, in three parts as follows:

1. Part 1: Directory, listing names, addresses, and telephone numbers of Architect/Engineer, Contractor, Subcontractors, and major equipment suppliers.
2. Part 2: Operation and maintenance instructions, arranged by system and subdivided by specification section. For each category, identify names, addresses, and telephone numbers of Subcontractors and suppliers. Identify the following:
  - a. Significant design criteria.
  - b. List of equipment.
  - c. Parts list for each component.
  - d. Operating instructions.
  - e. Maintenance instructions for equipment and systems.
  - f. Maintenance instructions for finishes, including recommended cleaning methods and materials, and special precautions identifying detrimental agents.
3. Part 3: Project documents and certificates, including the following:
  - a. Shop drawings and product data.
  - b. Air and water balance reports.
  - c. Certificates.
  - d. Photocopies of warranties and bonds.

#### 1.9 MANUAL FOR EQUIPMENT AND SYSTEMS

- A. Submit two copies of preliminary draft or proposed formats and outlines of contents before start of Work. Architect/Engineer will review draft and return one copy with comments.
- B. For equipment, or component parts of equipment put into service during construction and operated by Owner, submit documents within ten days after acceptance.
- C. Submit one copy of completed volumes 15 days prior to final inspection. Draft copy be reviewed and returned after final inspection, with Architect/Engineer comments. Revise content of document sets as required prior to final submission.
- D. Submit two sets of revised final volumes in final form within 10 days after final inspection.
- E. Each Item of Equipment and Each System: Include description of unit or system, and component parts. Identify function, normal operating characteristics, and limiting conditions. Include performance curves, with engineering data and tests, and complete nomenclature and model number of replaceable parts.
- F. Panel board Circuit Directories: Provide electrical service characteristics, controls, and communications; typed.

- G. Include color coded wiring diagrams as installed.
  - H. Operating Procedures: Include start-up, break-in, and routine normal operating instructions and sequences. Include regulation, control, stopping, shut-down, and emergency instructions. Include summer, winter, and special operating instructions.
  - I. Maintenance Requirements: Include routine procedures and guide for preventative maintenance and trouble shooting; disassembly, repair, and reassembly instructions; and alignment, adjusting, balancing, and checking instructions.
  - J. Include servicing and lubrication schedule, and list of lubricants required.
  - K. Include manufacturer's printed operation and maintenance instructions.
  - L. Include sequence of operation by controls manufacturer.
  - M. Include original manufacturer's parts list, illustrations, assembly drawings, and diagrams required for maintenance.
  - N. Include control diagrams by controls manufacturer as installed.
  - O. Include Contractor's coordination drawings, with color coded piping diagrams as installed.
  - P. Include charts of valve tag numbers, with location and function of each valve, keyed to flow and control diagrams.
  - Q. Include list of original manufacturer's spare parts, current prices, and recommended quantities to be maintained in storage.
  - R. Include test and balancing reports as specified in Section 01400.
  - S. Additional Requirements: As specified in individual product specification sections.
  - T. Include listing in Table of Contents for design data, with tabbed dividers and space for insertion of data.
- 1.10 SPARE PARTS AND MAINTENANCE PRODUCTS
- A. Furnish spare parts, maintenance, and extra products in quantities specified in individual specification sections.
  - B. Deliver to Project site; obtain receipt prior to final payment.

#### 1.11 PRODUCT WARRANTIES AND PRODUCT BONDS

- A. Obtain warranties and bonds executed in duplicate by responsible subcontractors, suppliers, and manufacturers, within ten days after completion of applicable item of work.
- B. Execute and assemble transferable warranty documents and bonds from subcontractors, suppliers, and manufacturers.
- C. Verify documents are in proper form, contain full information, and are notarized.
- D. Co-execute submittals when required.
- E. Include Table of Contents and assemble in three D side ring binder with durable plastic cover.
- F. Submit prior to final Application for Payment.
- G. Time Of Submittals:
  - 1. For equipment or component parts of equipment put into service during construction with Owner's permission, submit documents within ten days after acceptance.
  - 2. Make other submittals within ten days after Date of Substantial Completion, prior to final Application for Payment.
  - 3. For items of Work for which acceptance is delayed beyond Date of Substantial Completion, submit within ten days after acceptance, listing date of acceptance as beginning of warranty or bond period.

#### PART 2 PRODUCTS

Not Used.

#### PART 3 EXECUTION

Not Used.

END OF SECTION

## SECTION 02055

### SOILS

#### PART 1 - GENERAL

##### 1.1 SUMMARY

- A. Section Includes:
  - 1. Subsoil materials.
  - 2. Topsoil materials.
  
- B. Related Sections:
  - 1. Section 02060 - Aggregate.
  - 2. Section 02230 - Site Clearing.
  - 3. Section 02311 - Rough Grading.

##### 1.2 REFERENCES

- A. American Association of State Highway and Transportation Officials:
  - 1. AASHTO T180 - Standard Specification for Moisture-Density Relations of Soils Using a 4.54-kg (10-lb) Rammer and a 457-mm (18-in.) Drop.
  
- B. ASTM International:
  - 1. ASTM D1557 - Standard Test Method for Laboratory Compaction Characteristics of Soil Using Modified Effort (6,000 ft-lbf/ft<sup>3</sup> (2,700 kN-m/m<sup>3</sup>)).
  - 2. ASTM D2487 - Standard Classification of Soils for Engineering Purposes (Unified Soil Classification System).

##### 1.3 SUBMITTALS

- A. Section 01300 - Submittals: Requirements for submittals.
  
- B. Materials Source: Submit name of imported materials source.
  
- C. Manufacturer's Certificate: Certify Products meet or exceed specified requirements.

##### 1.4 QUALITY ASSURANCE

- A. Furnish each subsoil material from single source throughout the Work.

## PART 2 - PRODUCTS

### 2.1 SUBSOIL MATERIALS

- A. Subsoil Type S1:
  - 1. Excavated and re-used material.
  - 2. Graded.
  - 3. Free of lumps larger than 3 inches, rocks larger than 2 inches, and debris.
  - 4. Conforming to ASTM D2487 Group Symbol GP.
  
- B. Topsoil Type S2:
  - 1. Topsoil stripped from existing site.
  - 2. Free of sod or other vegetation
  - 3. Free of clumps larger than 2".

### 2.2 SOURCE QUALITY CONTROL

- A. Section 01400 - Quality Control Services: Testing and Inspection Services  
Testing and analysis of soil material.
  
- B. Testing and Analysis of Subsoil Material: Perform in accordance with ASTM D1557.
  
- C. Testing and Analysis of Topsoil Material: Perform in accordance with ASTM D1557.
  
- D. When tests indicate materials do not meet specified requirements, change material and retest.
  
- E. Furnish materials of each type from same source throughout the Work.

## PART 3 - EXECUTION

### 3.1 EXCAVATION

- A. Strip topsoil to full depth of topsoil in construction areas. Excavate subsoil from areas designated.
  
- B. Stockpile excavated material meeting requirements for subsoil materials.
  
- C. Remove excess excavated materials not intended for reuse, from site.
  
- D. Remove excavated materials not meeting requirements for subsoil materials from site.

### 3.2 STOCKPILING

- A. Stockpile materials on site at locations designated by Architect/Engineer.
- B. Stockpile in sufficient quantities to meet Project schedule and requirements.
- C. Separate differing materials with dividers or stockpile apart to prevent mixing.
- D. Stockpile topsoil 8 feet high maximum.
- E. Prevent intermixing of soil types or contamination.
- F. Direct surface water away from stockpile site to prevent erosion or deterioration of materials.
- G. Stockpile unsuitable or hazardous materials on impervious material and cover to prevent erosion and leaching, until disposed of.

### 3.3 STOCKPILE CLEANUP

- A. Remove stockpile, leave area in clean and neat condition. Grade site surface to prevent free standing surface water.

END OF SECTION

## SECTION 02060

### AGGREGATE

#### PART 1 - GENERAL

##### 1.1 SUMMARY

- A. Section Includes:
  - 1. Coarse aggregate materials.
  - 2. Fine aggregate materials.
- B. Related Sections:
  - 1. Section 02055 - Soils: Fill and grading materials.
  - 2. Section 02311 - Rough Grading.
  - 3. Section 02721 - Aggregate Base Course.

##### 1.2 REFERENCES

- A. American Association of State Highway and Transportation Officials:
  - 1. AASHTO M147 - Standard Specification for Materials for Aggregate and Soil-Aggregate Subbase, Base and Surface Courses.
- B. ASTM International:
  - 1. ASTM C136 - Standard Test Method for Sieve Analysis of Fine and Coarse Aggregates.
  - 2. ASTM D1557 - Standard Test Method for Laboratory Compaction Characteristics of Soil Using Modified Effort (6,000 ft-lbf/ft<sup>3</sup> (2,700 kN-m/m<sup>3</sup>)).
  - 3. ASTM D2487 - Standard Classification of Soils for Engineering Purposes (Unified Soil Classification System).
  - 4. ASTM D4318 - Standard Test Method for Liquid Limit, Plastic Limit, and Plasticity Index of Soils.

##### 1.3 SUBMITTALS

- A. Section 01300 - Submittals: Requirements for submittals.
- B. Materials Source: Submit name of imported materials suppliers.
- C. Manufacturer's Certificate: Certify Products meet or exceed specified requirements.

##### 1.4 QUALITY ASSURANCE

- A. Furnish each aggregate material from single source throughout the Work.

## PART 2 - PRODUCTS

### 2.1 COARSE AGGREGATE MATERIALS

- A. Coarse Aggregate Type A1: Natural stone or crushed rock; free of clay, shale, organic matter; graded in accordance with ANSI/ASTM C136, ASTM D2487 Group Symbol GM GC; to the following limits:

Minimum Size: 1/2 inch (25 mm)  
Maximum Size: 1 1/2 inch (50 mm)

Use for free draining gravel material, pipe foundation material as indicated on the Drawings.

- B. Coarse Aggregate Type A4: Durable material free of shale, clay, organic matter, friable material and debris meeting the following limits: (Alternative gradations will be considered)

<u>Sieve Size</u>	<u>Percent Passing</u>
6 inches	100
4 inches	98 to 100
3 inches	95 to 100
2 inches	75 to 100
1 inch	40 to 80
No. 4	25 to 60
No. 200	5 to 12

Use for the Granular Borrow, import trench backfill, structure backfill, site fill material, and where specified elsewhere and shown on the Drawings.

### 2.2 SOURCE QUALITY CONTROL

- A. Section 01400 - Quality Control Services: Testing and inspection services.
- B. Coarse Aggregate Material - Testing and Analysis: Perform in accordance with ASTM D1557. ASTM D4318. ASTM C136.
- C. Fine Aggregate Material - Testing and Analysis: Perform in accordance with ASTM D1557. ASTM D4318. ASTM C136.
- D. When tests indicate materials do not meet specified requirements, change material and retest.

## PART 3 - EXECUTION

### 3.1 EXCAVATION

- A. Stockpile excavated material meeting requirements for coarse aggregate materials and fine aggregate materials.
- B. Remove excess excavated materials not intended for reuse, from site.
- C. Remove excavated materials not meeting requirements for coarse aggregate materials and fine aggregate materials from site.

### 3.2 STOCKPILING

- A. Stockpile materials on site at locations designated by Architect/Engineer.
- B. Stockpile in sufficient quantities to meet Project schedule and requirements.
- C. Separate different aggregate materials with dividers or stockpile individually to prevent mixing.
- D. Direct surface water away from stockpile site to prevent erosion or deterioration of materials.
- E. Stockpile unsuitable and hazardous materials on impervious material and cover to prevent erosion and leaching, until disposed of.

### 3.3 STOCKPILE CLEANUP

- A. Remove stockpile, leave area in clean and neat condition. Grade site surface to prevent free standing surface water.

END OF SECTION

## SECTION 02230

### SITE CLEARING

#### PART 1 - GENERAL

##### 1.1 SUMMARY

- A. Section Includes:
  - 1. Removing surface debris.
  - 2. Removing designated paving, curbs, and slabs.
  - 3. Removing designated trees, shrubs, and other plant life.
  - 4. Removing abandoned utilities.
- B. Related Sections:
  - 1. Section 02311 - Rough Grading.

##### 1.2 SUBMITTALS

- A. Section 01300 - Submittals: Requirements for submittals.

##### 1.3 QUALITY ASSURANCE

- A. Conform to applicable code for environmental requirements and disposal of debris.

#### PART 2 - PRODUCTS

Not Used.

#### PART 3 - EXECUTION

##### 3.1 EXAMINATION

- A. Verification of existing conditions before starting work.
- B. Verify existing plant life designated to remain is tagged or identified.

##### 3.2 PREPARATION

- A. Call Local Utility Line Information service at 800-662-4111 not less than two working days before performing Work.
  - 1. Request underground utilities to be located and marked within and surrounding construction areas.

### 3.3 PROTECTION

- A. Locate, identify, and protect utilities indicated to remain, from damage.
- B. Protect trees, plant growth, and features designated to remain, as final landscaping.
- C. Protect bench marks, survey control points, and existing structures from damage or displacement.

### 3.4 REMOVAL

- A. Remove debris, rock, and extracted plant life from site.
- B. Partially remove paving, curbs, and, slabs as indicated on Drawings. Neatly saw cut edges at right angle to surface.
- C. Remove abandoned utilities. Indicated removal termination point for underground utilities on Record Documents.
- D. Continuously clean-up and remove waste materials from site. Do not allow materials to accumulate on site.
- E. Do not burn or bury materials on site. Leave site in clean condition.

END OF SECTION

## SECTION 02311

### ROUGH GRADING

#### PART 1 - GENERAL

##### 1.1 SUMMARY

- A. Section Includes:
  - 1. Excavating subsoil.
  - 2. Cutting, grading, filling, rough contouring, compacting, site for site structures, building pads, drainage and pavement.
  
- B. Related Sections:
  - 1. Section 02055 - Soils.
  - 2. Section 02060 - Aggregate.
  - 3. Section 02230 - Site Clearing: Excavating topsoil.
  - 4. Section 02740 – Asphaltic Concrete Paving

##### 1.2 REFERENCES

- A. ASTM International:
  - 1. ASTM C136 - Standard Test Method for Sieve Analysis of Fine and Coarse Aggregates.
  - 2. ASTM D1557 - Standard Test Method for Laboratory Compaction Characteristics of Soil Using Modified Effort (6,000 ft-lbf/ft<sup>3</sup> (2,700 kN-m/m<sup>3</sup>)).
  - 3. ASTM D2434 - Standard Test Method for Permeability of Granular Soils (Constant Head).
  - 4. ASTM D2922 - Standard Test Method for Density of Soil and Soil-Aggregate in Place by Nuclear Methods (Shallow Depth).
  - 5. ASTM D3017 - Standard Test Method for Water Content of Soil and Rock in Place by Nuclear Methods (Shallow Depth).

##### 1.3 SUBMITTALS

- A. Section 01300 - Submittals: Requirements for submittals.
- B. Materials Source: Submit name of imported materials suppliers.
- C. Manufacturer's Certificate: Certify Products meet or exceed specified requirements.

##### 1.4 CLOSEOUT SUBMITTALS

- A. Section 01700 – Project Closeout: Requirements for submittals.

- B. Project Record Documents: Accurately record actual locations of utilities remaining by horizontal dimensions, elevations or inverts, and slope gradients.

#### 1.5 QUALITY ASSURANCE

- A. Perform Work in accordance with ASTM C136, ASTM D2419, and ASTM D2434.

### PART 2 - PRODUCTS

#### 2.1 MATERIALS

- A. Subsoil Fill: Type S1 as specified in Section 02055.
- B. Structural Fill: Type S1 A2 A4 as specified in Section 02055, 02060, 02721.
- C. Granular Fill: Type A2 A4 as specified in Section 02060, 02721.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Verification of existing conditions before starting work.
- B. Verify survey bench mark and intended elevations for the Work are as indicated on Drawings.

#### 3.2 PREPARATION

- A. Call Local Utility Line Information service at 800 662-4111 not less than two working days before performing Work.
  - 1. Request underground utilities to be located and marked within and surrounding construction areas.
- B. Identify required lines, levels, contours, and datum.
- C. Protect utilities indicated to remain from damage.
- D. Protect bench marks, survey control point, existing structures, fences, sidewalks, paving, and curbs from excavating equipment and vehicular traffic.

#### 3.3 SUBSOIL EXCAVATION

- A. Excavate subsoil from areas to be further excavated, relandscaped, or regraded.
- B. Do not excavate wet subsoil.

- C. When excavating through roots, perform Work by hand and cut roots with sharp axe.
- D. Remove excess subsoil not intended for reuse, from site.

### 3.4 FILLING

- A. Fill areas to contours and elevations with unfrozen materials.
- B. Place fill material in continuous layers and compact in accordance with schedule at end of this section.
- C. Place material in continuous layers as follows:
  - 1. Subsoil Fill: Maximum 8 inches compacted depth. 95% max density.
  - 2. Structural Fill: Maximum 8 inches compacted depth. 95% max density.
  - 3. Granular Fill: Maximum 8 inches compacted depth. 95% max density.
- D. Maintain optimum moisture content of fill materials to attain required compaction density.
- E. Make grade changes gradual. Blend slope into level areas.
- F. Repair or replace items indicated to remain damaged by excavation or filling.

### 3.5 TOLERANCES

- A. Section 01400 - Quality Control Services: Tolerances.
- B. Top Surface of Subgrade: Plus or minus 1/10 foot from required elevation.

### 3.6 FIELD QUALITY CONTROL

- A. Section 01400 - Quality Control Services: Testing and inspection services.
- B. Perform laboratory material tests in accordance with ASTM D1557.
- C. Perform in place compaction tests in accordance with the following:
  - 1. Density Tests: or ASTM D2922.
  - 2. Moisture Tests: ASTM D3017.
- D. When tests indicate Work does not meet specified requirements, remove Work, replace and retest.
- E. Frequency of Tests: Pavement and Slabs - 1 test per lift per 1000 square feet

END OF SECTION

## SECTION 02324

### TRENCHING

#### PART 1 - GENERAL

##### 1.1 SUMMARY

- A. Section Includes:
  - 1. Excavating trenches for new utilities.
  - 2. Compacted fill from top of utility bedding to subgrade elevations.
  - 3. Backfilling and compaction.
  
- B. Related Sections:
  - 1. Section 02055 - Soils.
  - 2. Section 02060 - Aggregate.
  - 3. Section 02311 - Rough Grading: Topsoil and subsoil removal from site surface.
  - 4. Section 2600110 - Conduit Raceways.

##### 1.2 REFERENCES

- A. ASTM International:
  - 1. ASTM C136 - Standard Test Method for Sieve Analysis of Fine and Coarse Aggregates.
  - 2. ASTM D1557 - Standard Test Method for Laboratory Compaction Characteristics of Soil Using Modified Effort (6,000 ft-lbf/ft<sup>3</sup> (2,700 kN-m/m<sup>3</sup>)).
  - 3. ASTM D2922 - Standard Test Method for Density of Soil and Soil-Aggregate in Place by Nuclear Methods (Shallow Depth).
  - 4. ASTM D3017 - Standard Test Method for Water Content of Soil and Rock in Place by Nuclear Methods (Shallow Depth).

##### 1.3 DEFINITIONS

- A. Utility: Any buried pipe, duct, conduit, or cable.

##### 1.4 SUBMITTALS

- A. Section 01300 - Submittals: Requirements for submittals.
  
- B. Materials Source: Submit name of imported fill materials suppliers.
  
- C. Manufacturer's Certificate: Certify Products meet or exceed specified requirements.

## 1.5 FIELD MEASUREMENTS

- A. Verify field measurements prior to fabrication.

## 1.6 COORDINATION

- A. Section 01040 – Project Coordination: Coordination and project conditions.
- B. Verify Work associated with lower elevation utilities is complete before placing higher elevation utilities.

## PART 2 - PRODUCTS

### 2.1 BEDDING MATERIALS

- . Type B1 - Pea Gravel: Natural stone; free of clay, shale, organic matter; graded in accordance with ANSI/ASTM C136, to the following:
  - 1. Minimum Size: 1/4 inch
  - 2. Maximum Size: 5/8 inch.
- A. Type B2 - Sand: Natural river or bank sand; free of silt, clay, loam, friable or soluble materials, or organic matter; uniform in size with no material larger than 3/4".

### 2.2 FILL MATERIALS

- A. Subsoil Fill: Type S1 as specified in Section 02055.
- B. Structural Fill: Type S1 A2 A4 as specified in Section 02055,02060, 02721.
- C. Granular Fill: Type A2 A4 as specified in Section 02060, 02721.

## PART 3 - EXECUTION

### 3.1 LINES AND GRADES

- A. Lay pipes to lines and grades indicated on Drawings.
  - 1. Architect/Engineer reserves right to make changes in lines, grades, and depths of utilities when changes are required for Project conditions.
- B. Use laser-beam instrument with qualified operator to establish lines and grades.

### 3.2 PREPARATION

- A. Call Local Utility Line Information service at 800 662-4111 not less than two working days before performing Work.

1. Request underground utilities to be located and marked within and surrounding construction areas.
- B. Identify required lines, levels, contours, and datum locations.
- C. Protect plant life, lawns, and other features remaining as portion of final landscaping.
- D. Protect bench marks, existing structures, fences, sidewalks, paving, and curbs from excavating equipment and vehicular traffic.
- E. Maintain and protect above and below grade utilities indicated to remain.
- F. Establish temporary traffic control and detours when trenching is performed in public right-of-way. Relocate controls and reroute traffic as required during progress of Work.

### 3.3 TRENCHING

- A. Excavate subsoil required for utilities to utility service.
- B. Remove lumped subsoil, boulders, and rock up of 1/6 cubic yard, measured by volume.
- C. Perform excavation within 36 inches of existing utility service in accordance with utility's requirements.
- D. Do not advance open trench more than 200 feet ahead of installed pipe.
- E. Cut trenches wider than the outer diameter of the utility. Remove water or materials that interfere with Work.
- F. Excavate trenches to depth indicated on Drawings. Provide uniform and continuous bearing and support for bedding material and utilities.
- G. Do not interfere with 45 degree bearing splay of foundations.
- H. When subsurface materials at bottom of trench are loose or soft, excavate to greater depth as directed by Architect/Engineer until suitable material is encountered.
- I. Cut out soft areas of subgrade not capable of compaction in place. Backfill with Fill Type A4 and compact to density equal to or greater than requirements for subsequent backfill material.
- J. Trim excavation. Hand trim for bell and spigot pipe joints. Remove loose matter.

- K. Correct over excavated areas with compacted backfill as specified for authorized excavation or replace with fill concrete as directed by Architect/Engineer.
- L. Remove excess subsoil not intended for reuse, from site.

### 3.4 SHEETING AND SHORING

- A. Sheet, shore, and brace excavations to prevent danger to persons, structures and adjacent properties and to prevent caving, erosion, and loss of surrounding subsoil.
- B. Support trenches more than 5 feet deep excavated through unstable, loose, or soft material. Provide sheeting, shoring, bracing, or other protection to maintain stability of excavation.
- C. Design sheeting and shoring to be removed at completion of excavation work.
- D. Repair damage caused by failure of the sheeting, shoring, or bracing and for settlement of filled excavations or adjacent soil.
- E. Repair damage to new and existing Work from settlement, water or earth pressure or other causes resulting from inadequate sheeting, shoring, or bracing.

### 3.5 BACKFILLING

- A. Backfill trenches to contours and elevations with unfrozen fill materials.
- B. Systematically backfill to allow maximum time for natural settlement. Do not backfill over porous, wet, frozen, or spongy subgrade surfaces.
- C. Place material in continuous layers as follows:
  - 1. Subsoil Fill: Maximum 8 inches compacted depth.
  - 2. Structural Fill: Maximum 8 inches compacted depth.
  - 3. Granular Fill: Maximum 8 inches compacted depth.
- D. Employ placement method that does not disturb or damage, utilities in trench.
- E. Maintain optimum moisture content of fill materials to attain required compaction density.
- F. Do not leave more than 50 feet of trench open at end of working day.
- G. Protect open trench to prevent danger to Owner.

### 3.6 TOLERANCES

- A. Section 01400 - Quality Control Services: Tolerances.

- B. Top Surface of Backfilling Under Paved Areas: Plus or minus 1 inch from required elevations.
- C. Top Surface of General Backfilling: Plus or minus 1 inch from required elevations.

### 3.7 FIELD QUALITY CONTROL

- A. Section 01400 - Quality Control Services: Testing and inspection services.
- B. Perform laboratory material tests in accordance with ASTM D1557.
- C. Perform in place compaction tests in accordance with the following:
  - 1. Density Tests: or ASTM D2922.
  - 2. Moisture Tests: ASTM D3017.
- D. When tests indicate Work does not meet specified requirements, remove Work, replace, compact, and retest.
- E. Frequency of Tests: 1 Test mid and top of trench at each location where trench crosses asphalt driveway or roadway.

### 3.8 PROTECTION OF FINISHED WORK

- A. Section 01700 – Project Closeout: Protecting finished work.
- B. Reshape and re-compact fills subjected to vehicular traffic during construction.

### 3.9 SCHEDULE

- A. Electrical Conduit:
  - 1. Bed Conduit where directed by the engineer with aggregate type A1.
  - 2. Cover conduit and bedding with Fill Type S1, A4: To subgrade elevation.
  - 3. Compact uniformly to minimum 95 percent of maximum density.

END OF SECTION

SECTION 02721

AGGREGATE BASE COURSE

PART 1 - GENERAL

1.1 WORK INCLUDED

- A. Subgrade preparation to lines and grades shown on the plan.
- B. Place, grade and compact base and sub-base course materials.
- C. Dust and surface water control.

1.2 RELATED WORK

- A. Section 02740 – Asphaltic Concrete Paving.

1.3 REFERENCES

- A. American Society for Testing Materials (ASTM).
- B. American Association of Safety and Highway Transportation Officials (AASHTO)

PART 2 - PRODUCTS

2.1 BASE COURSE MATERIAL: TYPE A2

- A. Granular base for Pavement Preparation:
  - 1. Shall be untreated natural stone.
  - 2. Shall not be lumpy or frozen.
  - 3. Shall be free from noticeable concentrations of alkali, salt, shale, and petroleum products, all roots, sod, limbs, and other vegetative matter, slag, cinders, ashes and rubbish, or other material that, in the opinion of the Engineer, is objectional or deleterious.
  - 4. Shall be graded within the following limits:

<u>Sieve Size</u>	<u>Percent Passing By Weight</u>
1"	100
1/2"	70 - 100
No. 4	41- 68

No. 16	21- 41
No. 40	10 - 27
No. 200	4 - 13

### PART 3 - EXECUTION

#### 3.1 PREPARATION OF SUBGRADE

- B. Prior to placing base course materials, the subgrade shall be scarified to a depth of not less than 6", moistened or dried to optimum moisture content, and compacted to at least 95% maximum Modified Proctor Density as determined in accordance with ASTM D1557 (AASHTO T-180), and shall be within 2% of optimum moisture content.
- C. The subgrade shall then be proof rolled in the presence of the Engineer by passing loaded rubber-tired construction equipment uniformly over the surface at a constant rate. At least two (2) passes shall be made over all subgrade areas.
- D. If excessively soft, loose, or disturbed soils are encountered, they shall be removed as directed by the Engineer to a maximum depth of two feet (2') and replaced and recompact to 95% maximum Modified Proctor Density using approved subgrade stabilizing material.
- E. Ensure subgrade is to required lines and elevations.

#### 3.2 PLACEMENT OF BASE COURSE

- A. Protect against "pumping" moisture to surface by limiting travel on exposed subgrade. Where it is determined by the Owner that construction vehicle traffic (other than proof rolling) has caused subgrade instability, remove disturbed soils and replace with sand backfill at no additional cost to the Owner.
- B. Apply water soluble herbicide for nonselective control of annual and perennial weeds in strict accordance with manufacturer's instructions and all laws and regulations.
- C. Place base course material on the prepared and accepted subgrade. The material shall be back-dumped and spread in a uniform lift thickness.
- D. Handle and spread materials in a manner that will prevent segregation of sizes. When vibrating or other acceptable types of compaction equipment are used, the entire course may be placed in one layer, provided the ability of the equipment to achieve specified compaction to the full layer depth is demonstrated. In no case shall compacted lift thickness be greater than 8".

- E. When base course is constructed in more than one layer, the previously placed layer shall be cleaned of loose and foreign matter. Upper layer of base course shall not be less than 1-1/2", nor shall fine materials be added to reach final grade.
- F. Overstressing the subgrade soil and base course shall be avoided by utilizing equipment in spreading and dumping that exerts only moderate pressure on the soil. Avoid excessive travel on lower base course lifts. Severe rutting, cracking or yielding is an indication of overstressing the soil. Any ruts or cracks which develop in the base course during spreading or compacting shall be repaired as directed at no additional cost to Owner.
- G. Base course shall be compacted to no less than 95% maximum Modified Proctor Density, as determined by ASTM D1557 (AASHTO T-180). Moisture content shall be maintained to within 1.5% of optimum throughout placing and compaction operations.
  - 1. Compaction shall always be commenced along the edge of the area to be compacted and the roller shall gradually advance toward the center of the area to be compacted.
  - 2. Compaction equipment shall be operated along lines parallel or concentric with the centerline of the road being constructed, and no material variation therefrom will be permitted.
- H. Base course shall be substantially true to line and grade as indicated on the drawings. The surface shall be within 1/2" of required grade. Completed thickness of base course shall be within 1/2" of indicated thickness, with average thickness not less than that indicated.
- I. The top surface of compacted base course shall be finished by blading or rolled with equipment designed for that purpose.
- J. Temporary Graded Surface
  - 1. When allowed by the local jurisdiction having authority, where trenches are excavated in paved traffic lanes, the surface course may be temporarily replaced by a surface consisting of base course material. The base course shall be removed and replaced with pavement as soon as conditions permit, or as required by local jurisdiction having authority.
  - 2. The surface shall be maintained to provide for a smooth flow of traffic without holes, bumps, etc. until final acceptance of the work.

### 3.3 DUST AND SURFACE WATER CONTROL

- A. Dust control measures shall be implemented by application of water to all work areas, storage areas, haul and access roads, or other areas affected by work.
- B. All work shall be in compliance with the Federal, State and local air pollution standards, and not cause a hazard or nuisance to personnel and the public in the vicinity of the work.
- C. Provide and operate at least one (1) mobile tank sprinkling unit during the contract period.
- D. Other methods of dust control for haul and access roads may include chemical treatment, light bituminous treatment or other method as approved by the Owner.
- E. Surface water shall be controlled to the extent that the areas to receive pavement, walks or slabs are not allowed to become wet from runoff from adjacent areas. Surface water shall be directed away from these areas but not directed toward adjacent property, buildings, or any improvement that may be damaged by water. Surface water shall not be allowed to enter sanitary sewers.

3.4 FIELD QUALITY CONTROL

- A. Testing and inspection of placed Base Course will be provided by the Owner. Tests provided by the Owner are as follows:

<u>Item</u>	<u>Type</u>	<u>Frequency</u>
Base Course Aggregate Sampling	ASTM D75	Each day or 1 test/500 sq. yd., or as required.
Atterberg Limits	ASTM D2419, D423, and D424	As required
Sieve Analysis	ASTM C136	As required
Bearing Ratio	ASTM D1883	As required
Maximum Density	ASTM D1557, Method D	As required
In-place Density	ASTM D2167, D2922 and D3017	As required

- B. If tests indicate that sub-base and/or base course do not meet specified requirements, remove defective work, replace and retest at no cost to Owner.

END OF SECTION

## SECTION 02740

### ASPHALTIC CONCRETE PAVING

#### PART 1 - GENERAL

##### 1.1 WORK INCLUDED

- A. Place and compact asphaltic concrete paving.
- B. Protection of newly placed pavement.

##### 1.2 RELATED WORK

- A. Section 02230 – Site Clearing
- B. Section 02311 – Rough Grading
- C. Section 02721 – Aggregate Base Course

##### 1.3 QUALITY ASSURANCE

- A. Do not place asphaltic concrete paving when the air temperature in the shade and/or the roadbed temperature are below 50° F, or during rain, when the base course surface is wet, or during other adverse weather conditions.
- B. Do not place tack coat when air temperature in the shade and the roadbase temperature are below 50° F, or during rain, fog, or other adverse weather conditions.
- C. All work shall be performed by experienced and qualified workmen with equipment standard with the industry.
- D. Approval by Engineer of sources of supply of materials shall be obtained prior to delivery of materials.
- E. Comply with federal, state and/or local codes and regulations.

##### 1.4 REFERENCES

- A. American Society for Testing Materials (ASTM):
  - 1. D1557, "Tests for Moisture – Density Relationship of Soils using 10 lb (4.5 kg) Rammer in 18 inch (457 mm) Drop".
  - 2. D1559, "Resistance to Plastic Flow of Bituminous Mixtures Using Marshall Apparatus".

3. D2041, "Standard Test Method for Theoretical Maximum Specific Gravity and Density of Bituminous Paving Mixtures".
  4. D2170, "Kinematic Viscosity of Asphalts (Bitumens)".
- B. THE ASPHALT INSTITUTE (A.I.) Specification Series No. 2 (SS-2).
- C. American Association of State Highway and Transportation Officials (AASHTO):
1. Materials and compaction tests.
    - a. AASHTO T-180
- D. Utah Department of Transportation, "2005 Standard Specifications For Road and Bridge Construction".
1. Section 02741 Hot Mix Asphalt (HMA).

#### 1.5 SUBMITTALS

- A. An asphaltic concrete paving mix design prepared by a certified laboratory and materials certificates signed by material producer and Contractor, certifying that each material item complies with, or exceeds, specified requirements shall be submitted for review and approval at least one week prior to commencement of the work.
- B. Written certification of compliance for pavement marking paint.
- C. Product Data: Submit data for herbicide. Indicate compliance with applicable codes for environmental protection.

#### 1.6 WARRANTY

- A. See General Conditions.

### PART 2 - PRODUCTS

#### 2.1 MATERIALS

- A. Asphaltic cement:
1. Viscosity Graded original, AC-10, conforming to requirements of ASTM D-3381 (AASHTO M-226, Table 2), and Section 02741 – Utah Department of Transportation, "2005 Standard Specifications For Road and Bridge Construction".
  2. Shall not foam when heated to 350° F.
- B. Mineral Aggregate:
1. Shall consist of crushed stone, crushed gravel, or crushed slag, or a combination thereof; free of clay, silt, organic matter or other deleterious materials.
  2. Gradation shall be in accordance with the following:
    - a. Asphaltic concrete surface course:

<u>Sieve Size</u>	<u>Percent Passing by Weight</u>
1/2"	100
3/8"	70 - 100
#4	50 - 78
#16	30 - 48
#50	18 - 31
#200	7 - 13

b. Asphaltic concrete base course:

<u>Sieve Size</u>	<u>Percent Passing by Weight</u>
3/4"	100
3/8"	75 - 91
#4	60 - 80
#16	28 - 38
#50	11 - 23
#200	5 - 9

3. Course aggregate, retained on the No. 4 sieve shall consist of clean, hard, rough, durable and sound fragments, with not less than 50 percent of particles by weight with at least one mechanically fractured face or clean angular face.
4. Fine aggregate passing the No. 4 sieve may be either a natural or manufactured product. The aggregate shall be clean, hard grained and moderately sharp, and shall contain not more than 2 percent by weight of vegetable matter or other deleterious substances.
5. That portion of the fine aggregate passing the No. 40 sieve shall be nonplastic when tested in accordance with ASTM D-424.
6. The weight of minus 200 mesh material retained in the aggregate, as determined by the difference in percent passing a No. 200 sieve by washing and dry sieving without washing, shall not exceed 6 percent of the total sample weight. That portion of the fine aggregate passing the No. 200 sieve shall be determined by washing with water in accordance with ASTM C-117.
7. The aggregate shall be of uniform density and quality and shall have a rodded weight of not less than 100 pounds per cubic foot when tested in accordance with ASTM C-29.
8. The aggregate shall have a percentage of wear not exceeding forty when tested in accordance with ASTM C-131 and C-535.
9. The aggregate shall have a weighted loss not exceeding 12 percent by weight when subject to five cycles of sodium sulfate and tested in accordance with ASTM C-88, D-1073, D-692.

## 2.2 ASPHALTIC CONCRETE PAVING MIXTURE

- A. Combine mineral constituents and asphalt cement in proportions per mix design at a central plant to produce an asphaltic concrete pavement mix.

- B. Mix design shall be based on the Marshall Method. The combined mineral aggregate plus any approved additives when mixed with the asphaltic cement in accordance with ASTM D-1559 shall conform to the following requirements:

<u>Requirement</u>	<u>Value</u>
Percentage of Wear:	40
Marshall Stability:	1200 lb. Minimum
Flow (0.01 inch):	10 -18
Air Voids:	1.5% to 3.0%
Retained Strength:	60% Minimum
Asphalt Cement Content:	4.0% to 6.0% by weight

- C. The asphaltic cement shall be heated at the mixing plant to a temperature at which it can be applied uniformly to the aggregate.
- D. Coarse and fine aggregate shall be stored separately at the mixing plant in a manner that will prevent intermingling.
- E. When it is necessary to blend aggregates from one or more sources to produce the combined gradation, each source or size of aggregate shall be stockpiled individually. Aggregate from the individual stockpiles shall be fed through separate bins to the cold elevator feeders. They shall not be blended in the stockpile.
- F. Cold aggregates shall be fed carefully to the plant so that surpluses and shortages will not occur and cause breaks in the continuous operation.
- G. The aggregate shall be dried and heated to provide a paving mixture temperature in conformance with placing conditions, but not to exceed 163°C (325°F).
- H. The heated and dried aggregates shall not contain enough moisture to cause the mixture to slump, the asphalt to foam, or the aggregate to segregate during hauling and placing.
- I. The shortest mixing time consistent with satisfactory coating of the aggregate shall be used. The mineral aggregate shall be considered satisfactorily coated with asphaltic cement when all of the particles passing the No. 4 sieve and 96 percent of the particles retained on the No. 4 sieve are coated with asphaltic cement. The required mixing time, as determined above, shall be in accordance with ASTM D-2489.
- J. If a dryer drum mixing process is used, the mineral aggregate shall be considered satisfactorily coated with asphaltic cement when all of the particles passing the No. 4 sieve and 98 percent of the particle retained on the No. 4 sieve are coated with asphaltic cement. The moisture content of the asphaltic cement

sampled behind the laydown machine prior to compaction shall not exceed 1 percent by weight.

### 2.3 UDOT ASPHALTIC CONCRETE PAVING MIXTURE

- A. In accordance with UDOT 2005 standard specification 02741.

### 2.4 TACK COAT

- A. Emulsified asphalt CSS-1H or SS-1H.

## PART 3 - EXECUTION

### 3.1 PREPARATION

- A. Clean area in accordance with Section 02230.
- B. Install risers for manholes, valves and cleanouts to match finished grade of asphalt surface course if applicable.
- C. Sawcut all asphalt edges to a clean straight line when patching.
- D. Sawcut 6" minimum past any disturbed base course material.

### 3.2 TRANSPORTING THE ASPHALTIC CONCRETE PAVEMENT

- A. Transport time from the mixing plant to the job site shall not exceed 1 hour.
- B. Hauling truck shall have no direct frame contact with the paver or bear down on the paver during dumping operations.

### 3.3 TACK COAT

- A. Prior to placing pavement, tack coat shall be applied to the vertical edges of concrete and "cold" pavement (over 1/2 hour old) which will be in contact with new pavement. Tack coat shall extend 12 inches onto adjacent base course material. The tack coat shall be carefully applied at a rate of 0.15 gal/SY. Tack coat shall be applied uniformly at the same rate to the horizontal top surface of each lift of bituminous pavement prior to placing the next lift of bituminous pavement to promote a bond between the two courses of pavement. None of the material shall penetrate into the pavement and for this reason the application should be limited.
- B. Prior to applying the material, the surface to be treated shall be swept or flushed free of dust or other foreign material.

- C. Protect all surfaces not required to receive tack coat from any inadvertent application.
- D. The temperature range of the tack coat at the time of application shall be such that the viscosity will be between 50 and 100 centistokes as determined in accordance with ASTM Designation D-2170.
- E. Under no circumstances shall traffic be permitted to travel over the tacked surface. If detours cannot be provided, restrict operation to a width that will permit at least one-way traffic over the remaining portion of the roadbed. If one-way traffic is provided, the traffic shall be controlled in accordance with governing authority.
- F. After application of tack coat, sufficient time shall be given to allow for complete separation of asphalt and water before paving operations begin. The tack coat shall be applied on only as many surfaces as will be paved against in the same day.

#### 3.4 PLACEMENT OF ASPHALTIC CONCRETE PAVEMENT

- A. Place asphalt pavement to provide a compacted depth as indicated on the plans. Placing the pavement shall be a continuous operation. The machine shall spread mixture and shall strike a finish that is smooth, true to cross section, uniform in density and texture, and free from hollows and other irregularities. If any irregularities occur, they shall be corrected before final compaction of the mixture. The paving machine shall be self-propelled, equipped with hoppers, distributing screws, adjustable screeds and equalizing devices, capable of spreading hot asphaltic concrete paving mixture without tearing, shoving or gouging, and of producing a finished surface of specified quality. Place inaccessible and small areas by hand.
- B. Ensure asphalt pavement temperature is between 150 and 300 centistokes as determined with ASTM D-2170 when mixing with a pugmill, or between 220°F and 260°F when using the dryer-drum mixing process, immediately after placing and prior to initial rolling.
- C. Ensure joints made during paving operations are straight, clean, vertical and free of broken or loose material. Carefully make joints to insure a continuous bond between old and new pavement, or between successive day's work. A continuous bond between adjoining work is required.
- D. If more than ½ hour elapses between adjacent paving passes, the "cold joint" shall have tack coat applied to the "cold" pavement prior to placing the adjacent pass.

### 3.5 COMPACTION

- A. Roll and compact to specified density before temperature of the mixture drops below 180°F.
- B. Compact asphalt paving course to required density, with a steel wheeled tandem roller steel three-wheeled roller, vibratory roller, or a pneumatic-tired roller, weighing not less than five tons. Start compaction as soon as pavement will bear equipment without checking or undue displacement. Speed of the roller shall be slow enough to avoid displacement of hot mixture, and any displacements occurring as a result of changing the direction of the roller, or from any other cause, shall at once be corrected by the use of rakes and of fresh mixture where required. Ensure each pass of roller overlaps previous passes by at least  $\frac{1}{2}$  of the roller width to ensure smooth surface free of roller marks. Keep roller wheels sufficiently moist so as not to pick up material. Rolling shall continue until roller marks are eliminated and no further compression is possible. The finished compacted pavement shall have a density of 91% minimum, (no test less than 91% of the density determined in accordance with ASTM D-2041), as determined by ASTM D2170.
- C. Leave pavement with a uniform, dense surface.
- D. Perform hand tamping in areas not accessible to rolling equipment. Thorough compaction must be achieved, and joints between curbs, headers, manholes and similar structures must be effectively sealed.
- E. Do not allow vehicular traffic on newly paved areas until surface has cooled to atmospheric temperature.

### 3.6 PLACEMENT OF UDOT ASPHALTIC CONCRETE PAVEMENT

- A. Place pavement in accordance with UDOT Standard Specification 02741.

### 3.7 SCHEDULE

- A. Asphalt type and thickness:
  - 1. Driveways/parking areas – 3 inches, Regular Asphaltic Surface Course

END OF SECTION

SECTION 02923  
LANDSCAPE GRADING

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
  - 1. Final grade topsoil for finish landscaping.
- B. Related Sections:
  - 1. Section 02055 - Soils.
  - 2. Section 02311 - Rough Grading: Site contouring.
  - 3. Section 02324 - Trenching: Backfilling trenches.
  - 4. Section 02924 - Seeding and Soil Supplements.

1.2 SUBMITTALS

- A. Section 01330 - Submittal Procedures: Submittal procedures

1.3 QUALITY ASSURANCE

- A. Furnish each topsoil material from single source throughout the Work.

PART 2 PRODUCTS

2.1 MATERIAL

- A. Topsoil: Fill Type S2 as specified in Section 02055.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Section 01300 - Administrative Requirements: Verification of existing conditions before starting work.
- B. Verify trench backfilling has been inspected.

3.2 PREPARATION

- A. Protect landscaping and other features remaining as final Work.
- B. Protect existing paving and utilities.

### 3.3 SUBSTRATE PREPARATION

- A. Eliminate uneven areas and low spots.
- B. Remove debris, roots, branches, and large stones. Remove contaminated subsoil.

### 3.4 PLACING TOPSOIL

- A. Place topsoil in areas where seeding is required to nominal depth of 4 inches. Place topsoil during dry weather.
- B. Fine grade topsoil to eliminate rough or low areas. Maintain profiles and contour of subgrade.
- C. Remove roots, weeds, rocks, and foreign material while spreading.
- D. Manually spread topsoil close to trees and buildings to prevent damage.
- E. Lightly compact placed topsoil.
- F. Remove surplus subsoil and topsoil from site.

### 3.5 TOLERANCES

- A. Section 01400 - Quality Requirements: Tolerances.
- B. Top of Topsoil: Plus or minus 1 inch.

### 3.6 PROTECTION OF INSTALLED WORK

- A. Section 01700 - Execution Requirements: Requirements for protecting finished Work.
- B. Prohibit construction traffic over topsoil.

### 3.7 SCHEDULE

- A. Compacted topsoil thickness: 4 inches

END OF SECTION

## SECTION 02924

### SEEDING

#### PART 1 - GENERAL

##### 1.1 SUMMARY

- A. Section Includes:
  - 1. Seeding
  - 2. Maintenance.
- B. Related Sections:
  - 1. Section 02923 - Landscape Grading: Preparation of subsoil and placement of topsoil in preparation for the Work of this section.

##### 1.2 DEFINITIONS

- A. Weeds: Vegetative species other than specified species to be established in given area.

##### 1.3 SUBMITTALS

- A. Section 01330 - Submittal Procedures: Requirements for submittals.
- B. Product Data: Submit data for seed mix, fertilizer, and other accessories.
- C. Manufacturer's Certificate: Certify Products meet or exceed specified requirements.

##### 1.4 QUALITY ASSURANCE

- A. Provide seed mixture in containers showing percentage of seed mix, germination percentage, inert matter percentage, weed percentage, year of production, net weight, date of packaging, and location of packaging.

##### 1.5 DELIVERY, STORAGE, AND HANDLING

- A. Section 01600 - Product Requirements: Product storage and handling requirements.
- B. Deliver grass seed mixture in sealed containers. Seed in damaged packaging is not acceptable.
- C. Deliver fertilizer in waterproof bags showing weight, chemical analysis, and name of manufacturer.

## PART 2 - PRODUCTS

### 2.1 SEED MIXTURE

- A. Seed Mixture:
  - 1. Sheep Fescue: 48 percent.
  - 2. Crested Wheat Grass: 33 percent.
  - 3. Stream Bank Wheat Grass: 13 percent.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Section 01300 - Administrative Requirements: Verification of existing conditions before starting work.
- B. Verify prepared soil base is ready to receive the Work of this section.

### 3.2 SEEDING

- A. Apply seed at rate of 50 lbs per acre evenly in two intersecting directions. Rake in lightly.
- B. Do not sow immediately following rain, when ground is too dry, or when winds are over 12 mph.

### 3.3 SCHEDULE

- A. Place grass seed mixture specified where trenches were created outside of asphalt areas for the installation of new electrical services, and fill slopes for parking pad extensions.

END OF SECTION

SECTION 16001 - ELECTRICAL GENERAL PROVISIONS

PART 1 - GENERAL

RELATED DOCUMENTS:

The general provisions of the Contract, including the Conditions of The Contract (General, Supplementary and other conditions) and Division One apply to the work specified in this Section.

This Section 16001 is a part of all other Sections of this Division 16.

It is understood that Division 16 shall govern and be the direct responsibility of the Electrical Contractor, who shall comply with the specifications and the accompanying drawings to describe and provide for the furnishings, delivering, installing, testing and placing in satisfactory and successful operation all equipment, materials, devices, and necessary appurtenances to provide a complete electrical system for lighting, power and auxiliaries; together with such other equipment and devices furnished and installed under other contracts which shall be wired and connected under this contract.

If a discrepancy occurs between the equipment supplied and the intent or function of the equipment, catalog numbers, discontinued products, drawings, specifications, etc., the Contractor shall bring this to the attention of the Architect or Engineer in writing prior to bidding. Failure to report any conflict does not relieve the Contractor from meeting the intent of the contract documents nor shall it change the contract cost. It shall further be understood that if the contractor is unable to interpret any part of the plans and specifications, or should he find discrepancies therein, he shall call attention of the fact to the Architect prior to bid date. The Architect will issue additional instructions to Bidders before the project is bid.

State Licensed Contractor - All contractors shall have a current state contracting license for the trade engaged in.

DESCRIPTION OF WORK: \* \* \* \* \*

The work covered by these specifications consists of furnishing all labor, materials, equipment, supervision and service necessary for the proper completion of all electrical work shown on the drawings and hereinafter specified. Items shown or described in either the drawings or specifications and/or all

items necessary to make the electrical system complete and workable shall be understood to form a part of the work.

The main items of work are enumerated below. The work shall include but is not necessarily limited to the following items:

1. Power service and distribution.
2. Connection of motors, appliances and owner-furnished equipment.
3. Connections to equipment not supplied in this contract.

Work and materials not included under this Division:

VISITING SITE:

Visit the site during the bidding period to determine existing conditions that will affect the electrical and other work as it pertains to the construction of this structure. All costs arising from site conditions and/or preparation shall be included in the base bid. No additional charges will be allowed due to inadequate site inspection.

INTERPRETATION OF DRAWINGS AND SPECIFICATIONS:

At the time of bidding, contractor shall familiarize himself with the drawings and specifications of this project. Any questions, misunderstandings, conflicts, deletions, etc, shall be submitted to the Architect in writing for clarifications prior to issuance of the final addendum and bidding of the project. After signing the contract, the contractor shall meet the intent, purpose, and function of the contract documents; and any costs of materials, labor, and equipment arising therefrom, to make each system complete and operable, shall be paid by the contractor, which shall not result in any change in contract cost.

At the time of bidding, the electrical contractor shall be responsible to coordinate with the general contractor regarding any references to other divisions or trades on the electrical drawings or specifications.

DRAWING INTERPRETATION:

The electrical contractor shall refer to the architectural and/or mechanical drawings for exact placement of all electrical equipment. The electrical drawings unless specifically dimensioned are to be considered diagrammatic and are not to be scaled for placement of equipment.

CODES-REGULATIONS AND PERMITS:

In the installation of this work, comply in every way with the requirements of the laws, ordinances and rules of the State and National Board of Fire Underwriters, The National Electrical Code, and the rules and regulations of local ordinances.

If a conflict occurs between these rules and this specification, the rules are to govern. Accept this condition upon submitting bid, and no extra charge will be allowed after the electrical contract is awarded. This shall not be construed as relieving the Contractor from complying with any requirements of the plans or specifications which may be in excess of requirements of the hereinbefore mentioned rules and not contrary to same. All materials and equipment installed, including lighting fixtures, shall have been tested and approved by Underwriter's Laboratory and shall be so labeled.

All fees shall be included in the contract price. The Contractor shall furnish a certificate of approval to the Architect from the Inspection Authority at completion of the work.

SUPERVISION:

Workmanship shall be neat, have a good mechanical appearance and conform to the best electrical construction practices. A competent superintendent shall be in charge of the work at all times. Any person employed and found incompetent shall be removed at once and replaced by someone satisfactory when requested by the Architect. All work shall be carried out under the direction of the Architect to fulfill the true intent and meaning of the drawings and specifications. Only licensed master or journeyman craftsmen may be engaged in this project, except apprentice electricians may be used on not more than a 1:1 ratio with the total number of master or journeyman electricians.

FIELD DESIGN CHANGES:

No field changes, additions, or locations shall be made without written approval.

Current red line drawings must be on site at all times.

SHOP DRAWINGS: \* \* \* \* \*

It is understood that, before the manufacture or installation of any equipment under this contract is carried forward, shop drawings of such work shall be submitted for review. It is the

responsibility of the electrical contractor to check the shop drawings for detailed compliance with the contract documents. Prior to submitting the drawings for review, verify that all dimensions, contract document requirements, ballast voltages, and correlation at job site have been checked. **The electrical contractor shall indicate any corrections to the shop drawings or any exceptions to the contract document requirements, by notation on the shop drawings and by cover letter.** IF THIS IS NOT DONE THE DRAWINGS WILL BE RETURNED. At least eight (8) catalog sheets or shop drawings shall be submitted in ample time, no work being executed until each review has been completed.

Verification of Contract Document Requirements. **The Electrical Contractor shall be required to furnish shop drawings with the contract document requirements high-lighted to verify they have been checked.** Items to be high-lighted include, but are not limited to:

Electrical Panels

1. Panel number or designation
2. Panel type
3. Phase
4. Voltage
5. Flush or surface
6. Main lug amps
7. Main breaker amps
8. Fault current capacity
9. Branch circuit breakers

The review of shop drawings by the engineer is only to determine if they are in general compliance with the information given in the contract documents, and serves to determine the contractors understanding of the design concept. If some errors are detected but others are overlooked during the review this does not grant the contractor permission to proceed in error. Regardless of any information contained in the shop drawings, the requirements of the contract documents must be followed and are not waived or superseded in any way by the shop drawing review.

The following shop drawings are required within 20 days after signing of the contract.

1. Panelboards
2. RV Pedestals

One month after the contract is signed, bind and numerically index four (4) complete sets of all shop drawings and submit to the mechanical contractor for inclusion in the operation and

maintenance manual. Each unit type shall have its own individual catalog sheet giving characteristics, data, dimensions, catalog numbers and parts lists.

(Example: If two items of equipment A & D appear on the same sheet, an individual sheet shall be provided for each unit specified.) The manual shall be numerically indexed with an index sheet explaining the contents of each section.

#### QUANTITY TAKE OFF:

The contractor shall be responsible for accurate quantity take-off of all materials shown on the plans. Such things as a number designation for light fixture types (example 6, T-1) are intended to show design intent and/or improve drawing clarity and are NOT intended as an aid in determining a quantity for bidding purposes.

#### GUARANTEE:

The entire electrical system installed under this contract shall be left in proper working order and be in compliance with the drawings, specifications and/or authorized changes to the satisfaction of the Owner's Representative. Without additional charge, replace any work or materials which develop defects, except from ordinary wear and tear, within one year from the date of final acceptance. Exception: Incandescent and fluorescent lamps which shall be guaranteed for a period of two months from acceptance of the installation by the Owner or his agent. A written guarantee covering the above provisions shall be signed and delivered to the Architect after the project has final acceptance by the Inspecting Authority.

#### PART 2 - PRODUCTS

##### SPECIFIED PRODUCTS:

The contractors under this division shall thoroughly familiarize themselves with all specified products and their application relating to their work. Any objections to the use of any specified product shall be submitted to the architect in writing prior to bidding.

##### MATERIALS AND WORKMANSHIP:

All materials and equipment furnished and installed shall be of high quality, new, and meet the standards of NEMA, IPCA, LS, UL, NFPA, IBC, UOSHA, NEC, and shall bear their label wherever

standards have been established and label service is available. Where materials and equipment are specified by manufacturer's name, the type and quality required is thereby denoted. The Architect shall be afforded every facility, deemed necessary to inspect and examine the materials and apparatus being installed to prove their quality, skill and competency of workmanship.

#### SUBSTITUTIONS:

The equipment specified carries brand names and catalog numbers and shall be interpreted as establishing a standard of quality unless otherwise noted. Substitutions will be considered if a duplicate written application (2 copies) is at the offices of the Architect and Engineer at least four (4) working days prior to issue of the final addendum. The application shall include the following: 1) A statement declaring the equipment proposed is equal to that specified by having the same physical characteristics and dimensions and meet the drawings layout and structural conditions as well as load requirements; 2) The specified and submittal catalog numbers of the equipment under consideration; 3) A pictorial and specification brochure.

Any conflict arising from the use of substituted equipment shall be the responsibility of the contractor, who shall bear all costs required to make the equipment comply with the intent of the plans and specifications.

At the option of the Architect, samples may be required for non-standard or substituted items before installation during construction.

No materials or apparatus shall be substituted after the bid opening except where the equipment manufacturer has been discontinued or delivery becomes a problem, then written approval of the Architect is required.

Bidding - only equipment specified in the contract documents and/or approved by an addendum will be used in the base bid.

### PART 3 - EXECUTION

#### PROGRESS AND COORDINATION OF WORK:

The electrical work shall be laid out in advance of construction to eliminate unnecessary cutting, drilling, channeling, etc. Where such cutting and drilling, or channeling becomes necessary for proper installation; perform with care, use skilled mechanics of the trades involved, repair damage to building and equipment

at no additional cost to the Owner. Cutting work of other trades shall be done only with the consent of the General Contractor. Cutting of structural members shall be done only with the approval of the Architect.

Cooperate with other trades to coordinate locations of electrical outlets and apparatus.

Before any electrical panels, disconnects & motor starters or their associated feeders are installed, the electrical contractor shall be responsible to inform all other trades on the job of the requirements of N.E.C. 110-26. If any conflicts are noted he shall notify the architect immediately, along with notification in writing. No additional cost, to the job under the electrical contract, will be allowed for relocating electrical panels after installation.

Perform for other trades the electrical wiring and connections for all devices or apparatus where not specified herein or indicated on the drawings. Consult the Architectural and Mechanical drawings to avoid the location of switches, outlets and other equipment from being hidden behind doors, cabinets, counters, heating equipment, etc. Buried electrical devices and/or connections shall be relocated as directed, at no additional cost to the Owner.

Where conduit, outlets or apparatus is to be cast in concrete or encased, it must be located and secured by a journeyman or foreman present at the point of installation. He shall check the locations of the electrical items before and after the concrete and masonry installation and shall relocate displaced items.

No changes shall be made in the design or location of apparatus unless specifically approved in writing.

#### DRAWINGS:

Architectural and Mechanical drawings are a part of the electrical work insofar as they apply, as if referred to in full.

Since the drawings of floor and ceiling installation are made at small scale, outlets, devices, equipment, etc., are indicated only in their approximate location, unless dimensioned. Locate outlets and apparatus symmetrically on floors, walls and ceilings where not dimensioned, and coordinate such locations with work of other trades to prevent interferences. All dimensions on the job shall be verified. Do not scale the electrical drawings, but refer to the architectural and mechanical drawings and

dimensions.

The standard industry symbols together with the special symbols, noted and instructions indicated on the drawings describe the work, materials, apparatus and outlets required and all are to be included as a part of this specification.

EQUIPMENT CONNECTIONS:

Provide the materials and make the electrical connections to all equipment having electrical requirements as indicated in the Architectural and/or Mechanical section of the specifications and drawings. This includes Owner furnished equipment.

CLEAN-UP:

Clean up all equipment, conduit, fittings, packing cartons and other debris that is a direct result of the installation of the equipment under this contract.

STORAGE AND PROTECTION OF MATERIALS:

Provide storage space for storage of materials and apparatus and assume complete responsibility for all losses due to any cause whatsoever. In no case shall storage interfere with traffic conditions in any public thoroughfare or constitute a hazard to persons in the vicinity. Protect completed work, work underway, and apparatus against loss or damage.

EXCAVATION AND BACKFILLING: \* \* \* \* \*

Do all excavating and backfilling required for installation of any and all parts of the work. Work shall be done according to other applicable Divisions of this specification.

Perform excavation in a manner to protect walls, footings and other structural members from being disturbed or damaged in any way.

All backfill shall be mechanically compacted in 6 inch layers to 95% of maximum soil density per ASTM D-1557.

All surplus earth not needed for backfilling must be removed from the premises.

Scope:

1. Trench for electrical service entrance.
2. Backfilling and compacting.

COMPLETION OF WORK AND TESTS:

Before any underground service entrance circuits or feeder circuits are energized, make megger ground tests on the conductors. Record the readings along with ambient temperature and moisture conditions and submit to the Architect.

Submit with a letter of guarantee a record of all voltage reading and amp meter reading on all feeders and motors. If there are any abnormal conditions, they shall be brought to the attention of the Architect in writing as a part of this submittal.

Leave the job in complete order ready for use. All fixtures and equipment shall be tight, fully equipped and completely cleaned. All equipment shall have been operated, checked and approved by the Owner before the project can be accepted.

At the time of final construction review, the project foreman shall accompany the reviewing party, and remove cover plates, panel covers and other access panels for the reviewing engineer, to allow complete observation of the electrical system.

RECORD DRAWINGS:

When the general contract calls for "Record" or "As-Built" drawings to be furnished by the contractor at job completion, the electrical contractor shall be required to furnish, (for all contractor generated changes, from the drawings as shown), a complete set of "blue print ready" AutoCAD electrical drawings of a clarity equal to the original drawings as judged by the engineer.

The intent is for the electrical systems to be installed as shown on the drawings so that record set changes are kept to a minimum and only include unforeseen items on remodel projects or changes as directed by the architect. If the contractor chooses to change the design and/or routing of circuiting then the contractor shall be responsible to provide record drawings of a quality equal to the original drawings. One copy on CD and one copy on plot bond sheets as required by the architect.

END OF SECTION 16001

SECTION 16050 - BASIC MATERIALS AND METHODS

PART 1 - GENERAL

All wiring shall be run concealed, except at surface mounted panels and apparatus - See raceways for type of materials and additional information. All wiring shall be run in conduit unless specifically noted otherwise.

All branch circuit splices, taps, fixture connections, etc., shall be made with an approved pressure connector or wire nuts such as Ideal Spring type. Pigtails at each outlet or device box shall be 6 inches long.

The phase of each feeder conductor shall be color coded at each end in panels and junction boxes.

Hard surfaces: Whenever demolition or excavation is required for installation of the electrical system, it shall be the responsibility of this contractor to make repairs and/or replacements of hard finish surfaces such as concrete, asphalt, etc.

The method of patching and repair should follow good construction practices and all finished surfaces shall match materials and finish wherein the demolition occurred. Coordinate with other Divisions for patching requirements.

PART 2 - PRODUCTS

Not Used

PART 3 - EXECUTION

Not Used

END OF SECTION 16050

SECTION 16070 - ELECTRICAL CONNECTIONS FOR EQUIPMENT

PART 1 - GENERAL

RELATED DOCUMENTS:

Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification sections, apply to work of this section.

This section is a Division-16 Basic Materials and Methods section, and is part of each Division-16 section making reference to electrical connections.

DESCRIPTION OF WORK:

Extent of electrical connection for equipment includes final electrical connection of all equipment having electrical requirements. Make final connections for all owner furnished equipment. See other applicable portions of specification for building temperature control wiring requirements.

Refer to sections of other Divisions for specific individual equipment power requirements.

QUALITY ASSURANCE:

NEC Compliance: Comply with applicable portions of NEC as to type products used and installation of electrical power connections.

UL-Labels: Provide electrical connection products and materials which have been UL-listed and labeled.

PART 2 - PRODUCTS \* \* \* \* \*

General: For each electrical connection indicated, provide complete assembly of materials, including but not necessarily limited to, raceways, conductors, cords, cord caps, wiring devices, pressure connectors, terminal (lugs), electrical insulating tape, heat-shrinkable insulating tubing, cable ties, solderless wire nuts, and other items and accessories as needed to complete splices, terminations, and connections as required. See Section 16110, Conduit Raceways; and Section 16120 Wire and Cables for additional requirements. Provide final connections for equipment consistent with the following:

Other methods as required by the National Electrical Code and/or as required by special equipment of field conditions.

All electrical equipment for power connections, required for operation of mechanical equipment not furnished as an integral part of that equipment shall be furnished and installed under Division 16.

### PART 3 - EXECUTION

#### INSTALLATION OF ELECTRICAL CONNECTIONS:

Make electrical connections in accordance with connector manufacturer's written instructions and with recognized industry practices, and complying with requirements of NEC and NECA's "Standard of Installation" to ensure that products fulfill requirements.

Connect electrical power supply conductors to equipment conductors in accordance with equipment manufacturer's written instructions and wiring diagrams.

Coordinate installation of electrical connections for equipment with equipment installation work.

Verify all electrical loads (voltage, phase, full load amperes, number and point of connections, minimum circuit ampacity, etc.) for equipment furnished under other Divisions of this specification, by reviewing respective shop drawings furnished under each division. Meet with each subcontractor furnishing equipment requiring electrical service and review equipment electrical characteristics. Report any variances from electrical characteristics noted on the electrical drawings to Architect before proceeding with rough-in work.

Obtain and review the equipment shop drawings to determine particular final connection requirements before rough-in begins for each equipment item.

Location of disconnect switches as shown on the drawings is approximate. Electrical contractor is responsible for proper location for required code clearances.

Electrical contractor to verify motor sizes with mechanical before ordering overload heaters for starters.

Refer to Section 16120, Conductors, for identification of electrical power supply conductor terminations.

END OF SECTION 16070

SECTION 16110 - CONDUIT RACEWAYS

PART 1 - GENERAL

RELATED DOCUMENTS:

Drawings and general provisions of Contract, including General and Supplementary Conditions and Division 1 Specification sections, apply to work of this section.

This section is a Division-16 Basic Materials and Methods section, and is part of each Division-16 section making reference to electrical raceways and specified herein.

DESCRIPTION OF WORK:

Extent of raceways is indicated by drawings and schedules.

Types of raceways in this section include the following:

Liquid-tight Flexible Steel Conduit  
Rigid Metal Conduit  
Plastic Rigid Conduit

QUALITY ASSURANCE:

Manufacturers: Firms regularly engaged in manufacture of raceway systems of types and sizes required, whose products have been in satisfactory use in similar service for not less than three (3) years.

Standards: Comply with applicable portions of NEMA standards pertaining to raceways. Comply with applicable portions of UL safety standards pertaining to electrical raceway systems; and provide products and components which have been UL-listed and labeled. Comply with NEC requirements as applicable to construction and installation of raceway systems.

Submittals: Not required.

PART 2 - PRODUCTS \* \* \* \* \*

Provide and install raceways for the electrical system as shown on the plans, or as required by N.E.C. The raceways shall be concealed except at surface mounted panels and/or apparatus and open truss ceilings. Minimum conduit size is 3/4".

Acceptable raceways (metallic conduit to be galvanized):

Galvanized Rigid Conduit (GRC) - may be used in all locations. When installed in earth, cover with one layer of scotch wrap.

Plastic Rigid Conduit (PVC) - PVC schedule 40 may be used underground, or below concrete. (See ground conductors). All bends greater than 30 degrees shall be GRC. (This includes rising up through the floor). All connections to concrete or structure shall be a minimum of 10' of GRC at the end of the PVC run. All conduits passing horizontally through concrete shall be GRC for 5' before and after passing through the concrete (not applicable to stub up through floor slab). All underfloor conduits shall be run below the concrete slab.

Liquid Tight Flexible Steel Conduit: 1/2" minimum used for outdoor final connections to equipment.

### PART 3 - EXECUTION

All exposed conduit shall be installed parallel with or at right angles to the building structure lines. Raceways above ceilings in accessible attics shall be considered as exposed installations.

All branch circuit conduit runs shall be installed concealed in walls and ceilings. Conduit installation in existing walls that requires cutting and patching shall have patch and finish work done under the Division 16 contract. All work shall be done by the professional finish subcontractor on the job and shall subcontract the work under the Division 16 subcontractor.

When installing conduit, all cuts shall be smooth and square with the run and inside and outside burrs removed. Conduit joints in concrete or in the earth shall be made water tight with compound seal.

Install accessible junction boxes or condulets in conduit runs as required by NEC, and at 100 ft. intervals on long runs. Each junction box shall be supported independent of the conduit. Support vertical conductor runs per NEC 300-19.

The open ends of conduit shall be capped to keep out debris until the project is complete.

All mechanical exterior equipment shall be connected with vinyl covered flexible conduit with accompanying grounding conductor.

Pull a mandril and swab through all conduit before installing conductors.

All empty conduit shall be left with a 200-lb. nylon pull cord installed.

END OF SECTION 16110

SECTION 16120 - CONDUCTORS AND CABLES

PART 1 - GENERAL

RELATED DOCUMENTS:

Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification sections, apply to work of this section.

This section is a Division-16 Basic Materials and Methods section, and is part of each Division-16 section making reference to conductors and cables specified herein.

DESCRIPTION OF WORK:

Extent of electrical conductor and electrical cable work is indicated by drawings and schedules.

Types of conductors and cables in this section include the following:

Copper conductors (600V)

Applications for conductors and cables required for project include:

Power Service and Distribution  
Feeders  
Branch Circuits

QUALITY ASSURANCE:

Comply with NEC as applicable to construction and installation of electrical conductors and cable. Comply with UL standards and provide electrical conductors and cables which have been UL-listed and labeled.

Comply with applicable portions of NEMA/Insulated Cable Engineers Association standards pertaining to materials, construction and testing of conductors and cable.

Comply with applicable portions of ANSI/ASTM and IEEE standards pertaining to construction of conductors and cable.

SUBMITTALS:

Product Data: Submit manufacturer's data on electrical wire, cable and connectors.

PART 2 - PRODUCTS: \* \* \* \* \*

COPPER CONDUCTORS (600V): Insulation types THHN, THWN, XHHW as required by application.

Provide factory-fabricated conductors of sizes, ratings, materials, and types indicated for each service. Where not indicated provide proper selection to comply with project's installation requirements and NEC standards.

Provide color and coding of conductors as follows:

Wire sizes of #8 and smaller shall be factory colored throughout. Larger conductors shall be identified with a minimum of 6" of color wrapped tape at junction boxes and termination.

120/240V

A-Phase - Black  
C-Phase - Red  
Neutral - White  
Ground - Green

Switch legs and travellers shall be colors other than those listed above.

PART 3 - EXECUTION

INSTALLATION:

General: Install electrical conductors and cables as indicated, in compliance with manufacturer's written instructions, applicable requirements of NEC and NECA's "Standards of Installation", and in accordance with recognized industry practices.

Coordinate installation work with electrical raceway and equipment installation work, as necessary for proper interface.

Use pulling compound or lubricant, where necessary; compounds must not deteriorate conductor or insulation.

Keep conductor splices to minimum.

Install splices and tapes which have mechanical strength and insulation rating equivalent-or-better than conductor.

Use splice and tap connectors which are compatible with conductor material.

FIELD QUALITY CONTROL:

Prior to energization, test cable and wire for continuity of circuitry, and also for short circuits. Correct malfunctions when detected.

Subsequent to wire and cable connections, energize circuitry and demonstrate functioning in accordance with requirements.

END OF SECTION 16120

## SECTION 16160 - PANELBOARDS

### PART 1 - GENERAL

#### RELATED DOCUMENTS:

Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification sections, apply to work of this section.

This section is a Division-16 Basic Materials and Methods section, and is part of each Division-16 section making reference to panelboards specified herein.

#### DESCRIPTION OF WORK:

Extent of panelboard and enclosure work, is indicated by drawings and schedules.

Types of panelboards and enclosures in this section include lighting and appliance panelboards, and power distribution panelboards.

#### QUALITY ASSURANCE:

Provide units which have been UL listed and labeled. Comply with NEC as applicable to installation of panelboards, cabinets, and cutout boxes. Comply with NEC pertaining to installation of wiring and equipment in hazardous locations. Comply with NEMA stds. Pub No. 250, "Enclosures for Electrical Equipment (1000 volt maximum)". Pub No. 1, "Instructions for Safe Installation, Operation and Maintenance of Panelboards Rated 600 Volts or Less".

#### SUBMITTALS:

Product Data: Submit manufacturer data including specifications, installation instructions and general recommendations, for each type of panelboard required.

Shop Drawings: Submit dimensioned drawings of panelboards and enclosures showing accurately scaled layouts of enclosures and required individual panelboard devices, including but not necessarily limited to, circuit breakers, fusible switches, fuses, ground-fault circuit interrupters, and accessories. Panel dimensions shown on the drawings are one manufacturer's dimensions. Panel dimensions submitted by other manufacturers shall not exceed the panel dimensions shown on the drawings.

PART 2 - PRODUCTS \* \* \* \* \*

ACCEPTABLE MANUFACTURERS

Manufacturers: Subject to compliance with requirements, provide one of the following:

General Electric Company  
Square D Company

Panel sizes shown on drawings are for Square D panels. If other panels are substituted, the contractor shall verify proper clearances per N.E.C. Unless otherwise noted, main and distribution panels shall be a minimum 36" wide.

\* \* \* \* \*

Panelboards: General: Except as otherwise indicated, provide panelboards, enclosures and ancillary components, of types, sizes, and ratings indicated. Equip with number of unit panelboard devices as required for complete installation. Fully equip "spaces" with hardware to receive breaker or switch of size indicated.

Lighting and Appliance Panelboards: Provide dead-front safety type lighting and appliance panelboards as indicated, with switching and protective devices in quantities, ratings, types, and arrangement shown. Provide bolt-on thermal magnetic type branch breakers. Where multiple breakers are indicated provide with common trip handle. Equip with copper bus bars, neutral bus, and ground bus.

All breakers in the main distribution panels shall have sufficient interrupting capacity to safely interrupt the available short circuit current from the transformer bank, as noted on the drawings. Panels and breakers are to be fully rated unless otherwise noted.

Manufacturer: All distribution and branch panels, breakers, and associated equipment shall be of the same manufacturer.

Buss bracing shall be as required to handle fault current as shown on the drawings.

"Space" denotes a space fully equipped to receive a breaker of the type noted.

Panelboard Enclosures: Provide galvanized sheet steel cabinet type enclosures, in sizes and NEMA types as indicated, code-gage minimum 16-gage thickness. Provide fronts with adjustable indicating trim clamps, and doors with flush locks and keys, all panelboard enclosures keyed alike, with concealed door hinges and door swings as indicated. Equip with interior circuit-directory frame, and card with clear plastic covering. Provide baked gray enamel finish over a rust inhibitor. Provide enclosures fabricated by same manufacturer as overcurrent devices contained therein. Bolt engraved Formica labels indicating panel name and voltage on the interior and exterior of panelboards.

Finish: Coat interior and exterior of surface with manufacturer's standard color; baked on enamel finish.

Identification: Provide 1/16" thick black Formica labels with 1/4" high white lettering on the interior of each panelboard; include panelboard name and voltage. Provide red Formica labels on emergency system panels.

### PART 3 - EXECUTION

#### INSTALLATION OF PANELBOARDS:

General: Install panelboards and enclosure where indicated, in accordance with manufacturer's written instructions, applicable requirements of NEC and NECA's "Standard of Installation", in compliance with recognized industry practices to ensure products fulfill requirements.

Panelboard Makeup: In making up a panel, the conductors shall be neatly formed therein. Wires shall be protected from sharp metal edges or corners.

Coordinate installation of panelboards and enclosures with cable and raceway installation work. Anchor enclosures firmly to walls and structural surfaces, ensuring they are permanently and mechanically secure. Arrange conductors neatly within enclosure, and secure with suitable nylon ties.

Branch panels shall generally be installed with the top of the panel at 6 ft. above floor.

Fill out panelboard's circuit directory card upon completion of installation work. Utilize actual final building room numbers, not architectural numbers used on drawings. Identify individual lighting circuits and individual receptacle circuits by room served. Include room number with equipment circuit designations.

All directories to be typewritten.

Provide stand off wall brackets for surface wall mounted panels and/or gutters as required to bring front edges flush with each other as required by NEC 110-16A.

Provide identification of disconnecting means as required by NEC 225-37 or 230-2.

All subpanels shall be labeled to identify the main panel that supplies the feeder circuit.

All feeder circuit breakers shall be labeled to identify the location of the subpanel or equipment supplied.

END OF SECTION 16160

SECTION 16420 - SERVICE ENTRANCE

PART 1 - GENERAL

RELATED DOCUMENTS:

Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification sections, apply to work of this section.

Division-16 Basic Materials and Methods sections apply to work specified in this section.

DESCRIPTION OF WORK: \* \* \* \* \*

Extent of service-entrance work is indicated by drawings and schedules.

Switchboards, panels, disconnects, transformers, etc., used for service-entrance equipment are specified in applicable Division-16 sections, and are included as work of this section.

Consult local utility relative to all costs for line extensions, connections, etc., and include all costs for bringing service to the facility in base bid. Confirm location of point of service before bidding.

Provide labor and materials as required to accomplish power company metering in accordance with power company standards and requirements.

Provide concrete pads of size and type required for service transformers including any utility required primary conduit stub outs. Verify location, size, openings, reinforcing requirements with local utility before beginning work. Comply with local utility clearance requirements. Location of pads shown on the drawings are approximate only.

QUALITY ASSURANCE:

Comply with NEC and NEMA standards as applicable to construction and installation of service-entrance equipment and accessories. Provide service-entrance equipment and accessories which are UL-listed and labeled, and equipment marked, "Suitable for use as Service Equipment".

SUBMITTALS:

Product Data: Submit manufacturer's data on service-entrance equipment and accessories.

Shop Drawings: Submit dimensioned layouts of service-entrance equipment and spatial relationships to proximate equipment.

Maintenance Stock, Fuses: For types and ratings required, furnish additional fuse, amounting to one unit for every 2 installed units, but not less than one unit of each.

PART 2 - PRODUCTS \* \* \* \* \*

SERVICE - ENTRANCE EQUIPMENT:

General: Provide service-entrance equipment and accessories of types, sizes, ratings and electrical characteristics indicated, which comply with manufacturer's standard materials, design and construction in accordance with published product information, and as required for complete installation, and as herein specified. Each service disconnect shall be marked to identify it as a service disconnecting means. Where more than one service disconnect is used, all disconnects shall be labeled as required by NEC.

OVERCURRENT PROTECTIVE DEVICES:

General: Provide overcurrent protective devices as indicated on drawings.

Meter Sockets and Current Transformer cabinets: Provide meter sockets and current transformer cabinets which comply with requirements of local utility company supplying electrical power to service-entrance equipment of building project.

RACEWAYS AND CONDUCTORS:

General: Provide raceways and conductors complying with applicable Division-16 Basic Materials and Methods sections.

Wall and Floor Seals: Provide wall and floor seals complying with Division-16 Basic Materials and Methods section "Raceways".

PART 3 - EXECUTION

Provide and install an electric service to the facility as shown on the drawings and specified herein. The electrical contractor

shall be responsible for any cost assessed by the serving utility to provide an electric service as shown on the plans and/or specified herein.

The service metering shall be as per the local power company or as specified herein.

Construction Lighting and Power shall be arranged for as specified under the General Conditions.

Before purchase of any service entrance equipment the contractor shall review with the power company the proposed service as shown on the drawings and the probable date when the service connection from the power company will be needed.

Transformer Pad: The electrical contractor shall be responsible to confirm the transformer pad & specifications, and clearance from other equipment and structures with the serving power company before beginning installation.

Installation of Service-entrance Equipment: Install service-entrance equipment as indicated, in accordance with equipment manufacturer's written instructions, and with recognized industry practices, to ensure that service-entrance equipment fulfills requirements. Comply with applicable installation requirements of NEC and NEMA standards.

Coordinate with other work, including utility company wiring, as necessary to interface installation of service-entrance equipment work with other work.

Install all floor standing service equipment on 4" high concrete curb and bolt equipment to curb with 5/8" anchors at each corner and at intervals not to exceed 48" along perimeter. Install wiring trench under floor standing equipment; 12" deep, and 4" smaller in length and width than equipment base. Install grounding bushings on conduits penetrating trench.

Grounding: Provide system and equipment grounding and bonding connections for service-entrance equipment and conductors, as required.

Adjust and clean: Adjust operating mechanisms for free mechanical movement.

Touch-up scratched or marred enclosure surfaces to match original finishes.

Provide a neutral from the service transformer to all main service disconnects including 3 phase service disconnects for motor circuits whether or not they are shown on the drawings.

Provide bonding bushings on all conduits.

Field Quality Control: Upon completion of installation of service-entrance equipment and electrical circuitry, energize circuitry and demonstrate capability and compliance with requirements. Where possible, correct malfunctioning units at site, then retest to demonstrate compliance; otherwise, remove and replace with new units, and proceed with retesting.

END OF SECTION 16420

SECTION 16452 - GROUNDING

PART 1 - GENERAL

RELATED DOCUMENTS:

Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification sections, apply to work of this section.

Division-16 Basic Materials and Methods sections apply to work specified in this section.

DESCRIPTION OF WORK: \* \* \* \* \*

Provide grounding as specified herein, and as indicated on drawings.

Types of grounding in this section include the following:

Underground metal water piping  
Metal building frames  
Grounding electrodes  
Grounding rods  
Service equipment  
Enclosures  
Systems  
Equipment  
Other items indicated on drawings

Requirements of this section apply to electrical grounding work specified elsewhere in these specifications.

QUALITY ASSURANCE:

Comply with NEC as applicable to electrical grounding and ground fault protection systems. Comply with applicable ANSI and IEEE requirements. Provide products which have been UL listed and labeled.

SUBMITTALS:

None required.

PART 2 - PRODUCTS

GROUNDING:

Materials and Components: General: Except as otherwise indicated, provide each electrical grounding system as specified herein, and as shown on drawings, including but not necessarily limited to, cables/wires, connectors, terminals (solderless lugs), grounding rods/electrodes and plate electrodes, bonding jumper braid, and other items and accessories needed for complete installation.

Where Materials or Components are not otherwise indicated, comply with NEC, NEMA and established industry standards for applications indicated.

Electrical Grounding Conductors: Unless otherwise indicated, provide electrical grounding conductors for grounding connections matching power supply wiring materials and sized according to NEC.

Ground Rods: Steel with copper welded exterior, 3/4" dia. x 10'.

Footing Ground: Install 75 ft. of 3/0 bare copper wire in footings and connect to footing rebar.

PART 3 - EXECUTION \* \* \* \* \*

The electrical service entrance and conduit system throughout the project shall be grounded as required by N.E.C. Connect to all available electrodes per N.E.C. 250-50.

All rotating equipment shall be grounded in compliance with the N.E.C.

All plastic conduit runs shall include a grounding conductor as per N.E.C. requirements. Conduit sizes shown are for steel conduit. If plastic conduit is used the contractor shall verify conduit size to accommodate the required grounding conductor.

Provide full size ground in each conduit of parallel conduit systems per N.E.C. 250-122.

Separate neutrals shall be installed on all GFI breakers.

## INSTALLATION OF GROUNDING SYSTEMS:

Install electrical grounding systems in accordance with manufacturer's written instructions and with recognized industry practices to ensure grounding devices comply with requirements.

Install braided type bonding jumpers with ground clamps on water meter piping to electrically bypass water meter.

Install clamp-on connectors only on thoroughly cleaned and metal contact surfaces, to ensure electrical conductivity and circuit integrity.

Provide grounding for the entire raceway, enclosure, equipment and device system in accordance with NEC. All non-metallic raceways shall include copper grounding conductor sized in accordance with NEC.

Provide service entrance grounding by means of ground rods (quantity of two, driven exterior to building), by means of bonding to water main, by means of bonding to building structural steel, and by means of footing ground. Drive ground rods a minimum of 15 ft. apart.

Provide grounding conductors for dimming systems in accordance with manufacturer's requirement.

Install bonding bushings on all main service and feeder conduit terminations where metallic conduit connects to panels, wireways, etc.

Grounding electrode conductors shall be bonded to the exterior of the service equipment cabinet and interior through the grounding buss bonding strap. If metallic protection conduit is used over the grounding electrode conductor it shall be bonded to the grounding electrode at the point of entrance with a UL approved fitting. The conduit shall be continuous from the point of conductor entry to the service equipment cabinet where the conduit shall penetrate the cabinet and be secured with double lock nuts. The secondary conductor raceway between the transformers and the service equipment shall not be bonded to the transformer primary and secondary grounding system at the transformer and shall be electrically isolated from the transformer enclosures and ground system.

See drawings for additional grounding requirements.

END OF SECTION 16452