



State of Utah

JON M. HUNTSMAN, JR.  
Governor

GARY R. HERBERT  
Lieutenant Governor

## Department of Administrative Services

KIMBERLY K. HOOD  
Executive Director

### Division of Facilities Construction and Management

DAVID G. BUXTON  
Director

# ADDENDUM NO. 1

Date: May 20, 2009

To: Contractors

From: Brian Bales, Project Manager, DFCM

Reference: Generator Upgrade – Cannon Health Building  
Department of Health – Salt Lake City, Utah  
DFCM Project No. 08082390

Subject: **Addendum No. 1**

Pages	<u>Addendum Cover Sheet</u>	<u>1 page</u>
	Total	1 page

**Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.**

**While we contend that SB220 should only be potentially applicable to a contract issued after the effective date of said bill, this is to clarify that for purposes of this contract, regardless of the execution or effective dates of this contract, the status of Utah Law and remedies available to the State of Utah and DFCM, as it relates to any matter referred to or affected by said SB220, shall be the Utah law in effect at the time of the issuance of this Addendum.**

1.1 **SCHEDULE CHANGES:** No schedule changes.

1.2 **GENERAL ITEMS:**

1.2.1 The Cannon Health Building is constructed by use of post tension cable methods. Prior to cutting or drilling building structural components, the contractor shall be responsible to identify the location of post tension cables. The contractor shall not cut any post tension cables. If x-rays are used to locate the post tension cables, the contractor shall x-ray during non standard State working hours. The Cannon Health Building is not open on Fridays, but can be accessed for contractor needs.

1.2.2 All power outages shall occur on Fridays, weekends or non occupied evenings.