



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON
Director

ADDENDUM NO. 1

Date: 20 May 2009

To: Contractors

From: Darrell Hunting, DFCM – Project Manager

Reference: Security Upgrade - Davis ATC
DFCM Project No. 08083220

Subject: **Addendum No. 1**

Pages Total Addendum 2 pages

Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.

While we contend that SB220 should only be potentially applicable to a contract issued after the effective date of said bill, this is to clarify that for purposes of this contract, regardless of the execution or effective dates of this contract, the status of Utah Law and remedies available to the State of Utah and DFCM, as it relates to any matter referred to or affected by said SB220, shall be the Utah law in effect at the time of the issuance of this Addendum.

1.1 **SCHEDULE CHANGES:** No Schedule changes

1.2 **GENERAL ITEMS:**

- 1.2.1 All mounting hardware for project needs to be included in bid.
- 1.2.2 Contractor should review all spaces for racks; some areas have very tight space.
- 1.2.3 There has been some remodels since the drawings were completed. Contractors should view the cosmetology area for floor plan changes.
- 1.2.4 The successful contractor will be given a tax exempt certificate for the purchase of all equipment and materials.

- 1.2.5 Question: Would it be acceptable to the State of Utah (DFCM) and DATC to substitute the specified access control system for the same type used in the Barlow Building? This would add the Imron access control software and HID Vertx IP controllers as an option to the system specified in the current designed. Attached are data sheet for the purposed alternates.

Answer: I have no objection to this approach as long as it is remembered and provided for that the existing access doors with card readers will still be functional with the new core system to be provided. That means in a nutshell that the existing readers are either compatible with the new system controllers or new card readers will be provided for those existing doors as part of this contract.

1.3 SPECIFICATIONS

- 1.3.1 Section 282300, Part 2. The following changes (shown in **BOLD**) shall be made to Paragraph 2.1, A.2 and Paragraph 2.2, A.
- 1.3.2 Manufacturers: Subject to compliance with requirements, provide video surveillance system products of one of the following (for each type of product):

1.3.2.1 Video Surveillance Wire/Cable:

- a. Belden Corp.
- b. CommScope
- c. Mohawk
- d. Superior Essex
- e. West Penn

1.3.2.2 Video Surveillance Equipment

- a. Milestone XProtect Corporate software
- b. Cameras by Axis
- c. ACTI
- d. Pelco
- e. Vivotek

- 1.3.2.3 Video Surveillance Systems: Provide video surveillance systems, of types, sizes, capacities and electrical characteristics indicated, consisting of IP cameras and signal transmission media as required for complete installation. Except as otherwise indicated, provide manufacturer's standard video surveillance system components as indicated by published product information, designed and constructed as recommended by manufacturer. Provide video surveillance systems with the following functional and construction features as indicated **by the Axis camera model listed: (The Axis camera line of products was used only as a basis of design.)**

End of Addenda