



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON
Director

ADDENDUM #1

Date: September 11, 2008

To: Contractors

From: Vic Middleton, Project Manager, DFCM

Reference: UBATC Vernal Campus Underpass
Uintah Basin ATC– Vernal, Utah
DFCM Project No. 08176250

Subject: **Addendum No. 1**

Pages	Addendum	2	pages
	<u>Revised Schedule</u>	<u>1</u>	<u>page</u>
	Total	3	pages

Note: *This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.*

While we contend that SB220 should only be potentially applicable to a contract issued after the effective date of said bill, this is to clarify that for purposes of this contract, regardless of the execution or effective dates of this contract, the status of Utah Law and remedies available to the State of Utah and DFCM, as it relates to any matter referred to or affected by said SB220, shall be the Utah law in effect at the time of the issuance of this Addendum.

1.1 **SCHEDULE CHANGES** – There are changes to the project schedule.

Project Completion Date – April 30, 2009

1.2 **GENERAL** –

Item #1: The new completion date will be April 30th 2009

Item #2: All utility re-location (Phone, both fiber and copper, gas, sewer) will be contracted directly with the DFCM. The contractor will be responsible for protecting and covering these utilities during the construction progress.

Item #3: The handrail will be powder-coated steel. Not aluminum.

Item #4: The sidewalk will be eliminated from the project with curb and gutter only.

Item #5: The cost of the UDOT permit will be covered by the DFCM. If the contractor is responsible for obtaining the permit the cost will be reimbursed.

Note: The contractor needs to pay special attention to the drain line for the tunnel ground water. It is a 18"RCP pipe that drains to the east appx. 1000' and ties into the Bureau of Reclamation manhole.





**REVISED – PROJECT SCHEDULE
AS PER ADDENDUM NO. 1 DATED – September 11, 2008**

PROJECT NAME:		UBATC VERNAL CAMPUS UNDERPASS		
DFCM PROJECT NO. :		08176250		
Event	Day	Date	Time	Place
Document Available, including Plans and Specifications	Wednesday	August 20, 2008	10:00 AM	DFCM 4110 State Office Building SLC, UT and DFCM web site*
Mandatory Pre-Submittal Meeting	Wednesday	September 3, 2008	10:00 AM	DFCM 4110 State Office Building SLC, UT
Non-mandatory Site Visit	Tuesday	September 9, 2008	12:30 PM	UBATC Vernal Campus 500 North 1919 West Vernal, Utah
Last Day to Submit Questions on Shortlisting (In Writing)	Wednesday	September 10, 2008	4:00 PM	<u>Vic Middleton</u> - DFCM E-mail: vmiddlet@utah.gov
Addendum on Shortlisting	Thursday	September 11, 2008	3:00 PM	DFCM web site*
List of References, Statement of Qualifications, Project Management Plan, and Termination/Debarment Certification Due	Tuesday	September 16, 2008	12:00 NOON	DFCM 4110 State Office Building SLC, UT
Interviews by Selection Committee (if necessary)			To Be Announced	
Short-List Announced	Thursday	September 18, 2008	2:00 PM	
Notice: Only Short-Listed Firms Will Be Allowed To Bid On This Project				
Last Day to Submit Questions (In Writing)	Tuesday	September 23, 2008	3:00 PM	<u>Vic Middleton</u> - DFCM E-mail: vmiddlet@utah.gov
Final Addendum (exception for bid delays)	Thursday	September 25, 2008	2:00 PM	DFCM web site*
Prime Contractors Turn in Bid and Bid Bond/Bid Opening in DFCM Conference Room	Tuesday	September 30, 2008	3:00 PM	DFCM 4110 State Office Building SLC, UT
Subcontractors List Due	Wednesday	October 1, 2008	3:00 PM	DFCM 4110 State Office Building SLC, UT Fax (801)-538-3677
Project Completion Date		April 30, 2009		