



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON
Director

ADDENDUM #3

Date: 17 February 2009

To: Contact: Contractor: Fax Number:

<u>Contact:</u>	<u>Contractor:</u>	<u>Fax Number:</u>
Troy Jorgensen	Cameron Construction	268-3678
Jason Lockett	Intermountain Plantings	523-6113
Jeremy Gardner	Hughes General Contractors	295-0530
Jon Lemon / Robyn Ralphs	RBI	553-0525
Craig Saunders	Saunders, Inc	801-782-7856
Mike Lee	Ray Ward Construction	801-782-1453
Judy / Bob Morgensen	Kier Construction	801-866-1450
Bruce Cunninyton	Big-D Construction	801-629-2700
Bryce Wilcox	Wilcox Landscape	801-732-2570
David Rawson	Rawson Development	801-732-9566
Matt McAllister	Hadco Construction	801-766-7604
Mike Lavin	Peck Ormsby Construction	801-766-1715
Marcus Green	Green Construction	936-0840
John Peterson	JDP Construction	801-766-0739
Ken Warnick	R&O Construction	801-399-1480
David Wakefield	Highmark Commercial Construction	435-752-3116
Blake Knight	Onyx Construction	878-8922
Brett Hillam	MSCI	801-292-5229
Mike Sivulich	Jacobsen Construction	956-0403
Ron	Erickson Landscaping	262-2995
Kurt Young	Turf Sprinkler Company	942-8978
Randy Ropelato	Rope's Landscaping	801-731-3980
Shawn Beal	Legacy Landscape Construction	466-1085
Adam Schoonmaker	Schoonmaker Electro Mechanical	801-731-3638
Brock	Bailey Construction	435-753-3660
Teresa or Cal	Cal Wadsworth Construction	801-208-1975
Randy	Randy Marriott Construction	801-731-1008
Joey Ulm	Regency Excavation	801-782-5940
Brent Walton	Layton Construction	569-5451
Joe Reynolds	SIRQ Inc	253-7663

Shane White	US General Construction	801-294-8923
Brian Evert	Allstate Construction	563-3373
Ryan Park	Bodell Construction	261-1020
Jared Dixon	Spindler Construction	435-753-0728
Rick Dutson	Dutson Builders	978-0300
Tim Waterlyn / Chris Bullock	TCB Landscaping	435-615-6690
Scott Lindsay	Staker Parsons	801-409-2687
Scott Mecham	Mecham Brothers	801-985-0423

From: Bill Bowen, Project Manager, DFCM

Reference: Weber State University
Women's Softball Field Venue

DFCM Project #: 08240810

Subject: **Addendum No. 3**

Pages:	DFCM Addendum	2 page
	Revised Project Schedule	1 page
	<u>MHTN Architects Addendum</u>	1 page
	Total Pages	4 pages

Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

While we contend that SB220 should only be potentially applicable to a contract issued after the effective date of said bill, this is to clarify that for purposes of this contract, regardless of the execution or effective dates of this contract, the status of Utah Law and remedies available to the State of Utah and DFCM, as it relates to any matter referred to or affected by said SB220, shall be the Utah law in effect at the time of the issuance of this Addendum.

1. **SCHEDULE CHANGES** – See revised Project Schedule for highlighted changes.

2. **Project Construction Schedule**

2.1. Start Date: Monday, May 4, 2009

2.2. Substantial Completion Date: Wednesday, July 22, 2009

End of Addendum



PROJECT SCHEDULE – Revised
Per Addendum No. 3, dated February 17, 2009

PROJECT NAME: Women’s Softball Field Venue – Weber State University – Ogden, Utah				
DFCM PROJECT NO. 08240810				
Event	Day	Date	Time	Place
Request for Proposals and Construction Documents Available	Monday	January 26, 2009	12:00 Noon	DFCM 4110 State Office Bldg SLC, UT and the DFCM web site *
Mandatory Pre-Proposal Site Meeting	Thursday	February 5, 2009	10:00 AM	Weber State University ** Dee Events Center Rich Lounge
Last Day to Submit Questions prior to submittal of Statements of Qualifications	Tuesday	February 10, 2009	2:00 PM	DFCM billbowen@utah.gov
Addendum Deadline	Thursday	February 12, 2009	2:00 PM	DFCM web site *
Prime Contractors turn in References, Statements of Qualifications, Management Plans, Schedules and Termination Debarment Certifications	Thursday	February 26, 2009	12:00 Noon	DFCM 4110 State Office Bldg SLC, UT
Short Listing by Selection Committee (if applicable)	Thursday	March 5, 2009	4:00 PM	To be determined
Last Date to Submit Questions for Final Addendum	Tuesday	March 10, 2009	2:00 PM	DFCM billbowen@utah.gov
Final Addendum Deadline (exception for bid delays)	Thursday	March 12, 2009	2:00 PM	DFCM web site *
Prime Contractors Turn In Cost Proposals and Cost Reduction Proposals	Tuesday	March 17, 2009	12:00 Noon	DFCM 4110 State Office Bldg SLC, UT
Subcontractor List Due	Wednesday	March 18, 2009	12:00 Noon	DFCM 4110 State Office Bldg SLC, UT Fax 801-538-3677
Interviews	Tuesday	March 24, 2009	TBD	DFCM
Announcement	Thursday	March 26, 2009	4:00 PM	DFCM web site * and vial Fax
Substantial Completion Date	Wednesday	July 22, 2009		

* DFCM’s web site address is <http://dfcm.utah.gov>

** Map to WSU Dee Events Center: <http://www.weber.edu/WeberStateMap/OgdenCampusMap.html>



MHTN
ARCHITECTS

Addendum No. 2

Issued: 2/11/09

**Addendum No. Two
for the
WSU Women Softball Venue
MHTN Project No. (2008547)**

All Contractors submitting proposals on the above captioned project shall be governed by the following addendum, changes and explanations to the bidding documents and shall submit their bids in accordance therewith:

Changes to the Project Manual:

A2.1 Section 02810 – Irrigation Systems:

- a. Paragraph 2.8 - Flow Sensor revise to read as follows:
Provide a Rainmaster 4" flow sensor compatible with the Rainmaster DX48 Controller.
- b. Paragraph 2.9 - Filter revise to read as follows: Provide an Amiad 4" 2-0420-1110-4030 super steel inline filter assembly with brushaway cleaning system and weavewire screen (300 micron) in aluminum enclosure.

A2.2 Section 02930 – Playing Field Turf:

- a. **Paragraph 2.05.D - Gravel** shall be deleted its entirety.
- b. **Paragraph 2.02 B2** - revise to read as follows:
Current lab mechanical analysis of the proposed gravel and sand, using U.S.G.A. standards

Changes to the Drawings:

A2.3 Sheet AS101 - General Notes add Note 9

9. All construction shall conform to Weber State University Standards.

A2.4 Sheet CS101 – Description Change to Note

- Delete the text "Hilltopper" in two locations.

Attachments: None

End of Addendum No. 2