



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON
Director

ADDENDUM NO. 1

Date: January 22, 2009

To: Contractors

From: Craig Wessman, Project Manager, DFCM

Reference: Dryer Relocation – Multiple Buildings
Utah State Developmental Center
DFCM Project No. 08311410

Subject: **Addendum No. 1**

Pages	Addendum Cover Sheet	1 page
	<u>Engineer's Addendum</u>	<u>1 pages</u>
	Total	2 pages

Note: *This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.*

While we contend that SB220 should only be potentially applicable to a contract issued after the effective date of said bill, this is to clarify that for purposes of this contract, regardless of the execution or effective dates of this contract, the status of Utah Law and remedies available to the State of Utah and DFCM, as it relates to any matter referred to or affected by said SB220, shall be the Utah law in effect at the time of the issuance of this Addendum.

- 1.1 **SCHEDULE CHANGES:** No schedule changes.
- 1.2 **GENERAL ITEMS:** Engineer's Addendum containing clarifications.

ADDENDUM

Project Name: Utah State Developmental Center
Dryer Relocation Project

Addendum No.: 1

DFCM Project # 08311410

Date: 1-22-09

From: WHW Engineering Inc
8619 S Sandy Parkway Suite 101
Sandy, Utah 84070
Phone (801) 466-4021 Fax (801) 466-8536

To: All Bidders

This Addendum forms and becomes a part of the Contract Documents and modifies the original Bidding Documents dated December 2008 as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of 1 page.

I - CHANGES TO DRAWINGS:

Item I-1: Provide electrical power to new exhaust fans in Sunset, Quailrun, Oakridge from existing electrical panel from room behind kitchen.

Item I-2: Replace existing sprinkler head in dryer room with high heat type head.

End of Addendum