



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON
Director

ADDENDUM NO. 1

Date: March 30, 2009

To: Contractors

From: Wayne Smith, Project Manager, DFCM

Reference: Rooftop Unit Improvements – Draper Complex
Utah National Guard
DFCM Project No. 09019480

Subject: **Addendum No. 1**

Pages	Addendum Cover Sheet	1 page
	<u>Engineer's Addendum</u>	<u>2 pages</u>
	Total	3 pages

Note: *This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.*

While we contend that SB220 should only be potentially applicable to a contract issued after the effective date of said bill, this is to clarify that for purposes of this contract, regardless of the execution or effective dates of this contract, the status of Utah Law and remedies available to the State of Utah and DFCM, as it relates to any matter referred to or affected by said SB220, shall be the Utah law in effect at the time of the issuance of this Addendum.

- 1.1 **SCHEDULE CHANGES:** No Schedule changes
- 1.2 **GENERAL ITEMS:** See attached Engineer's Addendum.

ADDENDUM

Project Name: Utah National Guard Draper Headquarters
Rooftop Unit Addition

Addendum No.: 1

DFCM Project # 09019480

Date: March 30th, 2009

From: WHW Engineering Inc
8619 South Sandy Parkway
Sandy, Utah 84070
Phone (80) 466-4021 Fax (801) 466-8536

To: Wayne Smith

This Addendum forms and becomes a part of the Contract Documents and modifies the original Bidding Documents dated March 2009 as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of 2 pages.

I - CHANGES TO PRIOR ADDENDA: N/A

II - CHANGES TO BIDDING REQUIREMENTS: N/A

III - CHANGES TO AGREEMENT & OTHER CONTRACT FORMS: N/A

IV – CHANGES/CLARIFICATIONS TO CONDITIONS OF THE CONTRACT: N/A

V - CHANGES/CLARIFICATIONS TO SPECIFICATIONS:

Item V-1. Section 15950 - the entire existing system shall be balanced including existing rooftop units, new roof top units, existing diffusers.

VI - CHANGES/CLARIFICATIONS TO DRAWINGS:

Item VI-1. Sheet ME 101 - Roof top manufacturer shall field verify exact dimensions of existing support structure and provide a curb to match.

PRIOR APPROVALS

THE FOLLOWING ITEMS, AS SUBMITTED, ARE CONSIDERED, IN GENERAL AND IN NAME ONLY, AS EQUAL TO THOSE ITEMS SPECIFIED. THIS REVIEW DOES NOT RELIEVE THE CONTRACTOR OR SUPPLIER OF THE RESPONSIBILITY OF CONFORMING TO THE DRAWINGS AND SPECIFICATIONS, NOR DOES IT RELIEVE THE CONTRACTOR OF THE REQUIREMENTS OF THE SPECIFICATIONS FOR COORDINATION WITH OTHER TRADES. ALL DIMENSIONS SHALL BE CONFIRMED AND CORRELATED AT THE JOBSITE. THE CONTRACTOR SHALL BE RESPONSIBLE FOR VERIFYING EXISTING CONDITIONS AND THE SUITABILITY OF "EQUAL" PRODUCTS FOR THE SPECIFIED APPLICATION.

Description
15752 Humidifiers

Manufacturer
Carnes