



State of Utah

GARY R. HERBERT  
Governor

GREGORY S. BELL  
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD  
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON  
Director

## ADDENDUM #2

Date: February 25, 2010

To: Contractors

From: Matt Boyer, Project Manager, DFCM

Reference: Stewart Library Reroof  
Weber State University – Ogden, Utah  
Project No. 09073810

Subject: **Addendum No. 2**

Pages	Addendum	1 page
	<u>Architects Addenda</u>	<u>1 page</u>
	Total	2 pages

**Note:** *This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.*

While we contend that SB220 should only be potentially applicable to a contract issued after the effective date of said bill, this is to clarify that for purposes of this contract, regardless of the execution or effective dates of this contract, the status of Utah Law and remedies available to the State of Utah and DFCM, as it relates to any matter referred to or affected by said SB220, shall be the Utah law in effect at the time of the issuance of this Addendum.

2.1 **SCHEDULE CHANGES** – There are no changes to the project schedule.

2.2 **GENERAL** – Richard Bott Architect - Please see attached.

**Utah!**  
Where ideas connect

## addendum #1

date: 02.24.10

project name: WSU - Stewart Library Reroof  
project designation: 09073810 / 0910

from: Richards / Bott Architects

to: Contractors

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated 01.18.10, as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of 1 page.

### I - Changes to drawings:

- Item I-1.** Sheet a1.1 - Provide a temporary fence along the east side of the building to completely enclose the south-east corner of the building. The east portion of the fence is to be 20'-0" from the existing edge of sidewalk.
- Item I-2.** Sheet a1.1 - At the two elevator enclosures, raise the threshold as required for the new tapered insulation. Provide a new insulated hollow core door to fit the new opening.
- Item I-3.** The roof has been inspected by a Structural Engineer and a tear-off graveling tractor with a weight of less than 400 lbs. is approved.
- Item I-4.** The two glass vent at the south-east side of the roof need to be replaced with schedule 80 pvc.

### II - Changes to specifications:

- Item II-1.** Section 07531 Single Ply Membrane Roofing - The following is a list of approved Manufactures. This approved list does not alleviate the Manufacture from meeting all the specified requirements.
  - 2.2.11.a. KEE Approved Manufactures with a 42.5 mil minimum:
    - Fibertite-SM
  - 2.2.12.a. PVC Approved Manufactures with 57 mil minimum, unless manufacture requires a greater mil thickness in order to get 20 year warranty:
    - Versico
    - JM
    - GAF
    - Carlisle

end of addendum