



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON
Director

ADDENDUM NO. 1

Date: July 29, 2009

To: Contractors

From: Craig Wessman – Project Manager

Reference: Steam and Condensate Piping Replacement – Price District Facility
Utah Department of Transportation – Price, Utah
DFCM Project No. 09095900

Subject: **Addendum No. 1**

| | | |
|-------|----------------------------|---------------|
| Pages | Addendum Cover Sheet | 1 page |
| | <u>Engineer's Addendum</u> | <u>1 page</u> |
| | Total | 2 pages |

Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.

While we contend that SB220 should only be potentially applicable to a contract issued after the effective date of said bill, this is to clarify that for purposes of this contract, regardless of the execution or effective dates of this contract, the status of Utah Law and remedies available to the State of Utah and DFCM, as it relates to any matter referred to or affected by said SB220, shall be the Utah law in effect at the time of the issuance of this Addendum.

- 1.1 **SCHEDULE CHANGES:** No Project Schedule changes.
- 1.2 **GENERAL ITEMS:** See attached Engineer's Addendum.

ADDENDUM

Project Name: Steam and Condensate Piping
Replacement - Price District Facility UDOT
Price UT

Addendum No.: 1 (one)

DFCM Project # 09095900

Date: July 28, 2009

From: WHW Engineering Inc
8619 South Sandy Parkway
Sandy, Utah 84070
Phone (80) 466-4021 Fax (801) 466-8536

To: Craig Wessman

This Addendum forms and becomes a part of the Contract Documents and modifies the original Bidding Documents dated _____ as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of 1 page.

I - CHANGES TO PRIOR ADDENDA: N/A

II - CHANGES TO BIDDING REQUIREMENTS: N/A

III - CHANGES TO AGREEMENT & OTHER CONTRACT FORMS: N/A

IV – CHANGES/CLARIFICATIONS TO CONDITIONS OF THE CONTRACT: N/A

V - CHANGES/CLARIFICATIONS TO SPECIFICATIONS:

Item V-1. Delete section "01230 Alternates". There will be no alternates on this project.

VI - CHANGES/CLARIFICATIONS TO DRAWINGS:

Item VI-1. Sheet ME101. Delete the two piping guides between anchor #7 and anchor #6.

Item VI-2. Sheet ME101. Delete the one pipe guide closest to anchor #2.

Item VI-3. Sheet ME 101. Provide an addition expansion loop #3 between anchor #4 and the new tie-in serving the district office. Use same expansion loop as loop #2.

Item VI-4. Sheet ME 502. Remove the two pipe guides shown on detail C4.

Item VI-5. Sheet ME 502. Remove the one pipe guide at top right of detail C1.

Item VI-6. Coordinate with manufacturer for cushion requirements before bidding.