



State of Utah

GARY R. HERBERT
Governor

GREG BELL
Lieutenant Governor

Department of Administrative Services

Kimberly K. Hood
Executive Director

Division of Facilities Construction and Management

David G. Buxton
Director

ADDENDUM

Date: 27 May 2010

To: Contractors

From: Brent Lloyd, DFCM – Project Manager

Reference: Cedar City Courts Parking Lot Improvements
Administrative Office of the Courts
DFCM Project No. 09104150

Subject: **Addendum No. 01**

Pages	Cover Page	1 page
	<u>Addendum</u>	<u>1 pages</u>
	Total	2 pages

Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

1.1 SCHEDULE CHANGES – No Schedule changes

1.2 GENERAL – See attached “Addendum No. 01”

ADDENDUM NO. 01
STATE OF UTAH
DFCM
Cedar City Courts Parking Lot Improvements
DFCM PROJECT # 09104150
May 26, 2010

TO ALL PROSPECTIVE BIDDERS, CONTRACTORS, OR OTHER INTERESTED PERSONS:

The following changes have been made to the Contract:

1. **Entrance Gates**

Contractor will be required to re-install the loop vehicle detection system located at both entrance gates to the secured parking lot. Work will include the following:

1. Saw cutting 1 1/4-inch in depth to the existing detection dimensions.
2. Place 14 gauge AWG stranded 2 conductor twisted, shielded cable with a polyethylene insulation jacket and connect to the existing detection system.
3. Place backer rod to secure wire, and place crack sealer in top 3/8-inch of the saw cut.

Installation of the detection wiring for the entrance gates will be subsidiary to Item #2 (HMA 2-inch Overlay) and will not be paid for separately.

YOU ARE ADVISED that the final contract will be supplemented by the fore-going addendum and that proper acknowledgment will be required on the bid.