



State of Utah

GARY R. HERBERT
Governor

GREGORY S. BELL
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON
Director

ADDENDUM #1

Date: March 4, 2010

To: Contractors

From: Jeff Reddoor, Project Manager, DFCM

Reference: Utility Tunnel Entry/Exit Hatchways
Southern Utah University – Cedar City, Utah
Project No. 09116730

Subject: **Addendum No. 1**

Pages	<u>Addendum</u>	2 pages
	Total	2 pages

Note: *This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.*

While we contend that SB220 should only be potentially applicable to a contract issued after the effective date of said bill, this is to clarify that for purposes of this contract, regardless of the execution or effective dates of this contract, the status of Utah Law and remedies available to the State of Utah and DFCM, as it relates to any matter referred to or affected by said SB220, shall be the Utah law in effect at the time of the issuance of this Addendum.

1.1 **SCHEDULE CHANGES** – There are no changes to the project schedule.

1.2 **GENERAL** – Please see attached document.

Utah!
Where ideas connect



Stanley Consultants INC.

A Stanley Group Company
Engineering, Environmental and Construction Services - Worldwide

March 3, 2010

Jeff Reddoor
Project Manager
DFCM
4110 State Office Building
Salt Lake City, UT. 84114

Dear Jeff:

Subject: DFCM Project No. 09116730 Addendum No.1

The following are items that need to be added/modified to the original construction documents:

1. This project is to be tax exempt.
2. "Grade rings" shall be replaced with "pre-cast or cast-in-place grade rings" in the drawings/specifications.
3. Sheets SP1, SP2, and SP3 General Note 2 – replace note to read as follows:
 - a. Contractor to remove and replace sidewalks and curbs surrounding vault lids to match existing as required (with a minimum thickness of 6-inches) to install new precast or cast in place lids and provide uniform walking surface.
4. Contractor shall secure tunnel/vault openings as necessary for security and safety purposes. Coordinate with Owner as required.

Please call with any questions or comments regarding the addendum items.

Sincerely,

Stanley Consultants, Inc.

Cheol Kim, PE
Mechanical Engineer

cc: Bryan Baggaley
Tiger Funk
Ben Johnson

This document was sent electronically