



State of Utah

GARY R. HERBERT
Governor

GREGORY S. BELL
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON
Director

ADDENDUM NO. 2

Date: February 11, 2010

To: Contractors

From: Darrell Hunting, Project Manager, DFCM

Reference: Hyrum State Park – Restroom Replacement
Division of Parks and Recreation - Hyrum, Utah
Project No. 09198510

Subject: **Addendum No. 2**

Pages	Addendum Cover Sheet	1 page
	<u>A/E Addendum No. 2</u>	<u>2 pages</u>
	Total	3 pages

Note: *This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.*

While we contend that SB220 should only be potentially applicable to a contract issued after the effective date of said bill, this is to clarify that for purposes of this contract, regardless of the execution or effective dates of this contract, the status of Utah Law and remedies available to the State of Utah and DFCM, as it relates to any matter referred to or affected by said SB220, shall be the Utah law in effect at the time of the issuance of this Addendum.

- 2.1 **SCHEDULE CHANGES** – There are no changes to the project schedule.
- 2.2 **GENERAL** – Please see attached A/E 's Addendum No. 2 dated February 11, 2010.





ADDENDUM #2

DATE: February 11, 2010

JOB NAME: Hyrum State Park Restroom Replacement

JOB NUMBER: 09-126

CONTRACT BID DATE: 08-13-08

CONTRACT DOCUMENT DATE: 12-29-09

You are hereby advised to make the following additions, deletions, and or corrections to the contract documents. This addendum shall become part of the contract documents.

All remaining portions of the contract documents shall remain in full force and effect.

CHANGES TO THE DRAWINGS:

<u>Item</u>	<u>Dwg.</u>	<u>Description</u>
1.	A101	Added Key Note #24 - 1/2" moisture resistant gypsum board at ceiling location. This note applies to the following rooms: #103 Shower #1, #104 Shower #2, #106 ADA Shower.
2.	A401	Revise Key Note #2 to read as follows: Architectural asphalt shingles class "C" over #30 roofing felt over 5/8" plywood sheathing.
3.	A501	Revise Key Note #1 to read as follows: Architectural asphalt shingles class "C" over #30 roofing felt over 5/8" plywood sheathing.
4.	MH101	See attached sheet.

Failure to recognize receipt of this addendum on the bid proposal form may result in rejection of your bid.

END OF ADDENDUM #2

Skyline A,E,S, Inc.

By:

Hyrum State Park
Restroom Replacement
Mechanical Addenda
Carrillo Engineering, P.C.
February 11, 2010

1. MH101:

A. Sequence of Operation for Supply Fan SF-1, Exhaust Fan EF-1, Duct Furnace F-1:

Provide and install a line voltage timer switch to operate the toilet room ventilation system. Duct Furnace F-1 shall be complete with Maxitrol solid state electronic modulating system to provide continuous blower operation of SF-1 and control of space temperature by a wall mounted "Selectrastat" thermostat. Exhaust fan EF-1 shall be interlocked with SF-1 to operate whenever SF-1 is in operation.

Coordinate exact location of timer switch and wall thermostat with owner.