



State of Utah

GARY R. HERBERT  
Governor

GREGORY S. BELL  
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD  
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON  
Director

## ADDENDUM #4

Date: May 11, 2010

To: Contractors

From: Jeff Reddoor, Project Manager, DFCM

Reference: Boiler #1 Replacement – Southern Utah University  
Cedar City, Utah  
Project No.09239730

Subject: **Addendum No. 4**

|       |                           |               |
|-------|---------------------------|---------------|
| Pages | Addendum Coversheet       | 1 page        |
|       | <u>Engineers Addendum</u> | <u>1 page</u> |
|       | Total                     | 2 pages       |

**Note:** *This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.*

While we contend that SB220 should only be potentially applicable to a contract issued after the effective date of said bill, this is to clarify that for purposes of this contract, regardless of the execution or effective dates of this contract, the status of Utah Law and remedies available to the State of Utah and DFCM, as it relates to any matter referred to or affected by said SB220, shall be the Utah law in effect at the time of the issuance of this Addendum.

**4.1 SCHEDULE CHANGES** – There are no changes to the project schedule.

**4.2 GENERAL** – WHW Engineers - Please see attached.

**Utah!**  
Where ideas connect

# ADDENDUM

---

Project Name: SUU Boiler

Addendum No.: #2

DFCM Project # 09239730

Date: May 11, 2010

From: WHW Engineering Inc  
8619 S Sandy Parkway Suite 101  
Sandy, Utah 84070  
Phone (80) 466-4021 Fax (801) 466-8536

To: Jeff Reddoor

---

This Addendum forms and becomes a part of the Contract Documents and modifies the original Bidding Documents dated 3/1/10 as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of 1 page.

---

**I - CHANGES TO PRIOR ADDENDA:** Item 111-b alternate No. 2 - Add laborer to the list of hourly rates. Required for Alternate No. 2.

**II - CHANGES TO BIDDING REQUIREMENTS:** N/A

**III - CHANGES TO AGREEMENT & OTHER CONTRACT FORMS:** N/A

**IV - CHANGES/CLARIFICATIONS TO CONDITIONS OF THE CONTRACT:** N/A

**V - CHANGES/CLARIFICATIONS TO SPECIFICATIONS:** N/A

**VI - CHANGES/CLARIFICATIONS TO DRAWINGS:**

**Item VI-1.** Drawing MD101 note 4: Demolition of existing stack: The existing stack shall be removed from existing boiler No. 1 to 1'-0" below the roof by the asbestos contractor. He shall be responsible for supporting the existing stack until this contractor makes the new stack tie-in from the new boiler to the existing stack 1'-0" below roof.