



State of Utah

GARY R. HERBERT  
Governor

GREGORY S. BELL  
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD  
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON  
Director

## ADDENDUM NO. 5

Date: August 16, 2010

To: Contractors

From: Michael Ambre

Reference: New Facilities/Planning Center  
Utah Valley University – Orem, Utah  
Project No.09247790

Subject: **Addendum No. 5**

Pages	<u>Addendum</u>	2 pages
	Total	2 pages

**Note:** *This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.*

**5.1 SCHEDULE CHANGES** – There are no changes to the project schedule.

**5.2 GENERAL** – P+A Architects – Clarification on Specifications, please see attached sheet.

**Utah!**  
Where ideas connect

**ADDENDUM NO. 5**

**Date: August 16th, 2010**

**PROJECT:**

Utah Valley University  
New Facilities and Parking Building  
Orem, Utah

**ARCHITECT:**

**P+A ARCHITECTS  
821 EAST KENSINGTON AVENUE  
SALT LAKE CITY, UT 84105**

The original Contract Documents issued for the above noted project are amended as noted in this Addendum. It shall be the sole responsibility of the bidder to appropriately disseminate this information to all concerned prior to the assigned bid time and date, and to coordinate the Addendum with the Contract Documents.

This Addendum consists of a total of **One (1)** 8 ½" x 11" documents, including this document.

If there are still unresolved questions after examining this addendum, please submit those questions via telephone or facsimile as soon as possible so that an addendum can be issued to clarify those issues in a timely manner.

**Architectural:**

1. See architectural drawings A-WS400, A-WS401 and A-WS402. All exterior walls shall be framed with a minimum of 20 gauge metal studs as per specification. Where heavier gauge metal stud framing is indicated, general contractor shall use the heavier gauge.
2. G.F.R.C. panel framing to be 14 gauge as per specification.

**Mechanical:**

1. None

**Electrical:**

1. None

**Structural:**

1. None

**Geotechnical:**

1. None

**End of Addendum I**