



State of Utah

GARY R. HERBERT
Governor

GREGORY S. BELL
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON
Director

ADDENDUM #3

Date: June 24, 2010

To: Contractors

From: Matt Boyer, Project Manager, DFCM

Reference: Technology Building Re-roof
Southern Utah University – Cedar City, Utah
Project No.09257730

Subject: **Addendum No. 3**

Pages	Addendum	1 page
	<u>Architects Addenda</u>	<u>1 page</u>
	Total	2 pages

Note: *This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.*

While we contend that SB220 should only be potentially applicable to a contract issued after the effective date of said bill, this is to clarify that for purposes of this contract, regardless of the execution or effective dates of this contract, the status of Utah Law and remedies available to the State of Utah and DFCM, as it relates to any matter referred to or affected by said SB220, shall be the Utah law in effect at the time of the issuance of this Addendum.

3.1 SCHEDULE CHANGES – There are no changes to the project schedule.

3.2 GENERAL – Mesa Consulting, Clarifications to Specifications, please see attached.

Utah!
Where ideas connect

ADDENDUM #3 – June 24, 2010

Addendum to the **CONTRACT DOCUMENTS** for the Construction of:

**SOUTHERN UTAH UNIVERSITY
TECHNOLOGY RE-ROOF
DFCM PROJECT # 09257730**

The amendments of this addendum shall be subject to the general quality and intent as specified and shown with the original and new Contract Documents.

AMENDMENTS:

Architectural

ITEM #1: (Addendum #1 Item 8 and Drawing Sheet A201)

Addendum #1 item #8 is to be ignored. Detail call out A6/A202 shown along the transition of the low and high roof, south side is to be changed to A1/A204

ITEM #2: (Reference Specification 220548- I)

Specification Section 220548 –It can be eliminated. Spring hangers are not a requirement.

ITEM #3: (Reference Specification 220548-E)

Specification Section 220548-E Spring Isolators can be eliminated. Spring isolators are not required on this project.

ITEM #4: (Reference Addendum #1 and Drawing Sheet A202 Section A11)

Addendum #1 Item #9 is to be ignored. The entire roof is to have the insulation indicated on the drawings. The mechanical well does not have new insulation added. (See drawings E8/A203 and G11/A203

Page 1 of 1