



State of Utah

GARY R. HERBERT
Governor

GREGORY S. BELL
Lt. Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON
Director

ADDENDUM NO. 2

Date: November 29, 2010
To: Short-Listed Contractors

<u>Company</u>	<u>Contact</u>	<u>Fax</u>
Continental Engineering & Construction	Brian Bagnell	801-484-4040
John Orton Excavating Inc	John Orton	435-586-1492
Terry R Brotherson Excavating Inc	Terry Brotherson	435-462-3745

From: Bob Anderson - Project Manager
Reference: Spring Redevelopment – Loa Fish Hatchery
Division of Wildlife Resources – Wayne County, Utah
DFCM Project No. 10050520
Subject: **Addendum No. 2**

Pages	Addendum Cover Sheet	1 page
	<u>Engineer's Addendum</u>	<u>1 page</u>
	Total	2 pages

Note: *This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.*

While we contend that SB220 should only be potentially applicable to a contract issued after the effective date of said bill, this is to clarify that for purposes of this contract, regardless of the execution or effective dates of this contract, the status of Utah Law and remedies available to the State of Utah and DFCM, as it relates to any matter referred to or affected by said SB220, shall be the Utah law in effect at the time of the issuance of this Addendum.

- 2.1 SCHEDULE CHANGES:** There are no Project Schedule changes.
- 2.2 GENERAL ITEMS:** See attached Engineer's Addendum No. 1 dated November 29, 2010.

LOA FISH HATCHERY
SPRING REDEVELOPMENT
LOA, UTAH

State of Utah
Division of Facilities Construction & Management
DFCM Project No: 10050520

ADDENDUM #1
November 29, 2010

PLANHOLDER:

This Addendum #1 shall become part of the plans, specifications and contract documents of the above referenced project, and all provisions of the contract shall apply hereto.

Bidders shall acknowledge receipt of all addenda by number in the space provided in the bid documents.

Item #1 - The Quantity and Unit for Add Alternate Bid Item #23 in the bid schedule shall be changed from 335 and SY to 1 and LS, respectively.

Item #2 - A square pre-cast or cast-in-place collection box may be substituted for the circular 84" diameter collection manhole shown on sheet D4. In the event of a substitution, all of the project requirements shall still be maintained and adjustments shall be coordinated with the Engineer.

Item #3 - Site access has been coordinated and approved by the County Road Department. No further permitting will be required.

Item #4 - Per the discussion at the pre-bid site tour, the spring collection box and collection manhole shall be pre-cast or cast-in-place but shall have no joints except that the lid may be poured or set on and appropriately sealed.

Item #5 - Pipe inlets and outlets cast into the spring collection box and collection manhole shall include seep rings. Pipes installed through cored openings shall be sealed with link-seal or approved equal per manufacturer recommendations.

Prospective bidders should take note of these changes in the CONTRACT DOCUMENTS while preparing to submit their BIDS. This addendum shall be acknowledged on the BID documents in accordance with the CONTRACT DOCUMENTS by each BIDDER, and shall become part of the CONTRACT.

Sincerely,



Joseph K. Phillips, P.E.
Project Engineer
Sunrise Engineering, Inc.

