



State of Utah

GARY R. HERBERT  
Governor

GREGORY S. BELL  
Lt. Governor

Department of Administrative Services

KIMBERLY K. HOOD  
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON  
Director

## ADDENDUM NO. 2

Date: October 11, 2011

To: Contractors

From: Tim Parkinson – Project Manager

Reference: Chillers Replacement – Dee Event Center  
Weber State University – Ogden, Utah  
DFCM Project No. 10225810

Subject: **Addendum No. 2**

Pages	Addendum Cover Sheet	1 page
	<u>Engineer's Addendum No. 2</u>	<u>1 pages</u>
	Total	2 pages

**Note:** *This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.*

While we contend that SB220 should only be potentially applicable to a contract issued after the effective date of said bill, this is to clarify that for purposes of this contract, regardless of the execution or effective dates of this contract, the status of Utah Law and remedies available to the State of Utah and DFCM, as it relates to any matter referred to or affected by said SB220, shall be the Utah law in effect at the time of the issuance of this Addendum.

**2.1 SCHEDULE CHANGES:** There are no Project Schedule changes.

**2.2 GENERAL ITEMS:** See attached Engineer's Addendum No. 2 dated October 6, 2011.

**ADDENDUM NO. 2**

**WSU Dee Events Center Chiller Replacement**

**DFCM Project Nr. 10225810**

**CEA PROJECT NO. 2010-065.00**

**October 6, 2011**

All contractors submitting proposals for this project shall be governed by the following addendum, changes, and explanations to the bidding documents. Bids shall be submitted in accordance with the following:

<b>Item No.</b>	<b>Add, Delete or Clarify</b>	<b>Specification Section or Drawing No.</b>	<b>Reference / Description:</b>
2.1	Clarify	230810	Harmonics filters will not be required for the 6 variable frequency drives scheduled on sheet M601. Drives shall include means of harmonics mitigation already identified in specification section 230810.
2.2	Clarify	232113	-All condenser water piping on this project shall be schedule 80 PVC pipe conforming to ASTM D1785, fittings conforming to ASTM D2467, and solvent joints conforming to ASTM D2855. Do not use metallic pipe for condenser water. -Provide a corrugated aluminum jacket on all outdoor condenser water piping and fittings in accordance with specification section 230700, part 3.2 E 2. Although the pipe is not insulated, the jacket is required to protect the PVC pipe and fitting material from UV damage.

**END OF ADDENDUM NO. 2**