



State of Utah

GARY R. HERBERT
Governor

GREGORY S. BELL
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON
Director

ADDENDUM No. 1

Date: September 22, 2010

To: Contractors

From: Tim Parkinson

Reference: Stream Channel and Pond Feature
Weber State University - Ogden, Utah

Project No. 10238810

Subject: **Addendum No. 1**

Pages	<u>Addendum</u>	3 pages
	Total	3 pages

Note: *This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.*

1.1 SCHEDULE CHANGES – There are no schedule changes for this project.

DOCUMENT 00 91 13.1 ADDENDUM No. 1

PART 1 GENERAL

1.1 DOCUMENT INCLUDES

A. Changes to the Bid Documents.

1.2 CONSTRUCTION CONTRACT

- A. The Construction Contract is known as: Stream Channel and Pond Feature, Weber State University, Ogden, Utah. DFCM Project Number: 10238810.
- B. Date of this Addendum: September 22, 2010.

PART 2 CHANGES

2.1 CHANGES TO PRIOR ADDENDA

- A. None

2.2 CHANGES TO BIDDING REQUIREMENTS

- A. None

2.3 CHANGES TO AGREEMENT AND OTHER CONTRACT FORMS

- A. None

2.4 CHANGES TO CONDITIONS OF THE CONTRACT

- A. None

2.5 CHANGES TO SPECIFICATIONS

- A. Yes. (see 2.7)

2.6 CHANGES TO DRAWINGS

- A. None

2.7 ADDITIONAL BIDDING INFORMATION

- A. Question from Contractor: What rock can be used on this project?
Answer: The boulders and rock material to be used on this project shall be similar in color and form to those found on the WSU Bell Tower and Plaza project. The Contractor must determine his own source and whether or not it matches the Bell Tower rock. Final determination will be made by WSU Project officials. The rock material used on the Bell Tower project came from Stansbury Island.
- B. The rock used shall conform to the following specification for durability: Wear not greater than 40 percent when tested, ASTM C 535. (See 2007 APWA Specifications, Section 31 37 00, 2.3 Source Quality Control.)
- C. Dimensions given for primary and secondary anchor boulders are the greatest dimension required for those rocks. Minimum dimensions in other directions of the rock shall be at least 75% of the greatest dimension.
- D. Excavate all existing rocks and remove from site and dispose of legally. The only exception pertains to the rock on the pond side of the road. There, the existing rock may be reused, and additional rocks from the other side of the road may be used as needed.
- E. The project site shall be fenced off for security reasons. Use temporary 6' tall chain link fencing and t-posts or equivalent as needed to secure the work site.
- F. Staging shall be accommodated in the access road leading to the parking lot. The Contractor shall provide his own fencing, barricades, and control for this staging area.
- G. Power to the site for the irrigation controller shall be provided by the Contractor. With coordination and direction from the WSU Project Manager, power shall be pulled from the nearest 277 volt light fixture circuit. Provide the appropriate transformer to obtain 120 volt service. This service shall be permanent in nature and waterproof.

END OF ADDENDUM 1

