



State of Utah

GARY R. HERBERT
Governor

SPENCER J COX
Lt. Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

P. JOSHUA HAINES
Director

Addendum No. 1

Date: December 20, 2013

To: Contractors

From: Darrell Hunting, Project Manager

Reference: Wireless Access Control System Improvements - Bridgerland ATC
Utah College of Applied Technology – Logan, Utah
DFCM Project No. 13102210

Subject: **Addendum No. 1**

Pages Total Addendum 1 page

Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.

1.1 SCHEDULE CHANGES: There are no Project Schedule changes.

1.2 GENERAL ITEMS:

1.2.1 Clarification: Spec section 271100 has footer title COMMUNICATIONS BACKBONE CABLING. Correct footer is COMMUNICATIONS CABLING consistent with section title

1.2.2 Clarification: Spec section 271100-3.2(A) says that communications cabling can be installed in cable trays. Communications cabling shall be installed in conduit in open ceiling areas and areas with hard ceilings. Installation in cable trays or other open wiring methods such as j-hooks is limited to areas with accessible ceiling spaces.

1.2.3 RFP – page 9 item 16 Management Plan & Qualifications – Contractors should add tab Eight – “Hardware, Equipment and Software”. You will be allowed up to six pages to identify specifics about the Hardware, Equipment and Software you are proposing to use on this project.