



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lt. Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

BRUCE WHITTINGTON
Interim Director

Addendum No. 1

Date: October 19, 2015

To: Commissioning Agents

From: Darrell Hunting – Project Manager, DFCM

Reference: Clinical Services Building
Utah State University
DFCM Project No. 15128770

Subject: **Addendum No. 1**

Pages Total Addendum 1 page

Note: *This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.*

- 1.1 **SCHEDULE:** There are no project schedule changes.
- 1.2 **GENERAL ITEMS:** Question and Answer
1. Please clarify delivery method, single delivery or by phase? *CMGC, R&O Construction has been selected. It will be phased construction.*
 2. Will the commissioning scope include acoustical performance in sound-sensitive spaces? *Acoustical Commissioning is not anticipated at this time.*
 3. Will there be any commissioning responsibility associated with the temporary relocation for the existing CPD building? *It is not anticipated at this time.*
 4. As discussed during the pre-bid, the building will be using campus chilled water, with the building going for LEED Silver Certification, are we required to commission the chilled water system serving the new Clinical Services Building. *It is not anticipated at this time.*